



LEAD-BASED PAINT INSPECTION
OF
MIAMI UNIFIED SCHOOL DISTRICT #40 - INSPIRATION SCHOOL
FUNDED BY: COPPER CORRIDOR BLIGHT BUSTERS BROWNFIELDS
COALITION ASSESSMENT GRANT



912 WEST ROSE ROAD
MIAMI, GILA COUNTY, ARIZONA 85539
APN: 206-22-034A

ATLAS PROJECT NO. 1052000242, PHASE 5

REPORT DATE: JUNE 8, 2023

TESTING SUMMARY	
Testing Combinations	956
Positives	144
Buildings Tested	2

Prepared by:

Atlas Technical Consultants LLC
9185 South Farmer Avenue, Suite 111
Tempe, Arizona 85284
Phone: (480) 894-2056
Fax: (480) 894-2497

Prepared for:

Copper Corridor Blight Busters
Brownfields Coalition
1400 East Ash Street
Globe, Gila County, Arizona 85501
Phone: (928) 402-4392

TABLE OF CONTENTS

1.0	EXECUTIVE SUMMARY.....	ES-1
1.1	Certification of Results and Signatures.....	ES-3
2.0	IDENTIFYING INFORMATION AND PURPOSE OF LBP INSPECTION	1
3.0	SCOPE OF WORK	2
4.0	PROPERTY DESCRIPTION	3
5.0	IDENTIFIED LEAD HAZARDS.....	4
6.0	LEAD-BASED PAINT INSPECTION METHODS.....	7
6.1	Inspection Personnel.....	7
6.2	Testing Procedures – Viken Detection Corporation Model Pb200i	7
6.3	Interpretation of XRF Sampling Data	8
6.4	Confirmatory Paint Chip Analysis	9
6.5	Interpretation of Field Survey Reports	9
6.6	Paint Chip Sampling.....	10
7.0	SUMMARY OF FINDINGS	11
7.1	Testing Results.....	11
8.0	RECOMMENDATIONS.....	9

APPENDICES:

Appendix A:	Definitions of Key Regulatory Terms and Component Pictures
Appendix B:	<i>XRF Performance Characteristic Sheet</i>
Appendix C:	Laboratory Certifications for Fiberquant, EPA Certifications for Fiberquant and Atlas Personnel
Appendix D:	XRF Positive Summary Report Table D-1, LBP Hazards Summary Table D-2, and Fiberquant XRF Survey Results
Appendix E:	Figures
Appendix F:	EPA LBP Disclosure Requirements
Appendix G:	EPA Pamphlet “Protect Your Family From Lead in Your Home”

1.0 EXECUTIVE SUMMARY

A Lead-Based Paint (LBP) Inspection was conducted on the two (2) buildings that make-up the Inspiration School Campus (the “subject property” or “property”) located at 912 West Rose Road in Miami, Arizona for the Copper Corridor Blight Busters Brownfields Coalition (CC BB Brownfields Coalition) on March 7, 8, and 13, 2023. The LBP Inspection was conducted by Atlas Technical Consultants LLC (Atlas), located at 9185 South Farmer Avenue, Suite 111, Tempe, Arizona 85284.

The purpose of the LBP Inspection was to identify the presence of LBP inside and outside the property, as well as to identify which buildings and components contain LBP.

The LBP Inspection was performed according to the United States Department of Housing and Urban Development’s (HUD) *Guidelines for the Evaluation and Control of Lead-Based Paint Hazards in Housing (HUD Guidelines)*, dated 2012. This report was prepared by Atlas using trained and experienced lead-based paint inspectors and/or risk assessors.

The buildings and their paint were generally in intact condition during the LBP Inspection. LBP is defined as paint or other surface coatings that contain lead equal to or exceeding 1.0 milligram per square centimeter (mg/cm²). The results from the paint that was tested showed 144 LBP hazards exist among the two buildings located on the property, as defined in the Residential LBP Hazard Reduction Act of 1992 (Title X) and as defined by the Environmental Protection Agency (EPA) regulation published in the January 5, 2001 Federal Register.

TESTING SUMMARY	
Testing Combinations	956
Positives	144
Buildings Tested	2

Disclosure Status:

Based on the results of the LBP Inspection, Atlas has provided interim control options, abatement options, and recommended hazard control options in the LBP Hazards Summary (Appendix D).

Additionally, Atlas provides the following recommendations:

- **Disclosure Requirements** – A copy of this complete report must be made available to new lessees (tenants) and/or must be provided to purchasers of the property buildings under Federal law before they become obligated under any future lease or sales contract transactions (Section 1018 of Title X-found in 24 CFR Part 35 and 40 CFR Part 745), until the demolition of this Site. Appendix F includes a copy of the EPA Lead Disclosure. As applicable, Landlords (Lessors) and/or sellers are also required to distribute an educational pamphlet developed by the EPA entitled “Protect Your Family From Lead in Your Home” (Appendix G) and include standard warning language in their leases or sales contract to ensure that parents have the information they need to protect their children from LBP hazards.
- **Future Remodelling Precautions** – The LBP Inspection conducted on the property buildings will help the Client and owner to ensure the health and safety of the occupants. Details concerning lead-safe work techniques and approved hazard control methods can be found

Lead-Based Paint Inspection
Miami Unified School District #40 – Inspiration School
912 West Rose Road
Miami, Arizona 85539

in the HUD publication entitled: “Guidelines for the Evaluation and Control of LBP Hazards in Housing” (www.hud.gov/offices/lead). Future remodelling, repair, renovation and painting at the structure beyond the scale of minor repair and maintenance activities must be conducted in accordance with the EPA’s website on the Renovation, Repair and Painting (RRP) Rule at <http://www.epa.gov/lead/pubs/renovation.htm> for the scope and requirements of the Rule. Future LBP abatement or LBP hazard abatement at the structure must be conducted in accordance with the EPA’s Lead Abatement Rule (also within 40 CFR 745); see the EPA’s website for Lead Abatement Professionals.

1.1 Certification of Results and Signatures


This report has been prepared for the exclusive use of the CC BB Brownfields Coalition. Atlas acknowledges that the CC BB Brownfields Coalition may rely on this report in the management of the property. Photocopying of this document, in part or whole, by parties other than those designated by the CC BB Brownfields Coalition, or use of this document for purposes other than it is intended, is prohibited.

Respectfully submitted this 8th day of June 2023.

Atlas Technical Consultants LLC



Chad Wells, Industrial Hygiene Technician
EPA Lead Risk Assessor # LBP-R-80-2



Julie M. Powers, Environmental Department Manager
EPA Lead Risk Assessor # LBP-R-13956-2

2.0 IDENTIFYING INFORMATION AND PURPOSE OF LBP INSPECTION

A LBP Inspection was conducted at the property known as the former Inspiration School campus located at 912 West Rose Road in Miami, Arizona for the CC BB Brownfields Coalition on March 7, 8, and 13, 2023. The LBP Inspection was conducted by Atlas located at 9185 South Farmer Avenue, Suite 111, Tempe, Arizona 85284.

The purpose of the LBP Inspection was to identify the presence of LBP inside and outside the buildings, as well as to identify which buildings and components contain LBP.

3.0 SCOPE OF WORK

Atlas was retained by the CC BB Brownfields Coalition to perform a LBP Inspection in accordance with the United States Department of HUD “Guidelines for the Evaluation and Control of Lead-Based Paint Hazards in Housing” (HUD Guidelines), dated 2012.

The purpose of this report is to present the lead paint testing results and to assist the CC BB Brownfields Coalition in its compliance with the EPA and HUD final rule titled “Lead; Requirements for Disclosure of Known Lead-Based Paint and/or Lead-Based Paint Hazards in Housing” (24 CFR 35 Subpart H) herein referred to as the “Disclosure Rule,” and managing any LBP hazards identified. Atlas has also provided, in Appendix A, definitions of key regulatory terms and component pictures used or referenced in this report.

4.0 PROPERTY DESCRIPTION

The property tested is classified as a former high school campus relative to the requirements of the HUD/EPA Disclosure Rule. The following property buildings description information was obtained from the property building contact and from on-site observations by Atlas:

Classification:	Proposed community center
Property Owner:	Town of Superior
Property Identification:	Inspiration School Campus
Construction Date:	Building A around 1915 and building B around 1976
Number of Buildings:	Two
Type of Construction:	Building A- Stucco exteriors; painted wood and metal window and door trim; plaster, panel, and drywall wall and ceiling systems; carpet, wood, ceramic tile, vinyl floor tile, and sheet vinyl flooring. Building B- Stucco exteriors; painted wood and metal window and door trim; plaster, panel, and drywall wall, brick and mortar, and ceiling systems; ceramic tile, and vinyl floor tile
Representative Testing:	Testing was conducted on the interior and exterior of the property buildings.

5.0 IDENTIFIED LEAD HAZARDS

The buildings and their paint were generally in intact condition during the LBP Inspection. LBP was identified in Buildings A and B.

The results from the paint that was tested showed LBP exists, as defined in the Residential LBP Hazard Reduction Act of 1992 (Title X) and as defined by the EPA regulation published in the January 5, 2001 Federal Register. LBP is defined as paint or other surface coatings that contain lead equal to or exceeding 1.0 milligram per square centimeter (mg/cm^2). LCP is defined as paint or other surface coatings that contain lead less than 1.0 milligram per square centimeter (mg/cm^2).

One-hundred and forty-four (144) X-Ray Fluorescence readings were detected as positive from components on the exterior and interior of the property buildings A and B, which were equal to or exceeded $1.0 \text{ mg}/\text{cm}^2$ for lead in paint. Seven hundred and ninety-four (794) XRF readings were detected as LCP components on the exterior and interior of the property buildings A and B, which were less to $1 \text{ mg}/\text{cm}^2$ for lead in paint. Eighteen (18) XRF readings had no detection of LBP or LCP for components on the exterior and interior of the property buildings A and B, which were equal to $0 \text{ mg}/\text{cm}^2$ for lead in paint.

The XRF Positive Summary Report (Table D-1) is included in Appendix D. The LBP Hazard Summary (Table D-2) is included in Appendix D.

Figures 2 through 7 in Appendix E have the location of the positive paint locations.

6.0 LEAD-BASED PAINT INSPECTION METHODS

Atlas subcontracted with Fiberquant Analytical Services (Fiberquant) to perform the XRF LBP inspection for the LBP Inspection. Fiberquant utilized the representative testing and sampling procedures identified in the 2012 HUD Guidelines as the representative testing methodology. As part of this testing procedure, X-Ray Fluorescence (XRF) testing instruments must be utilized according to the procedures of the manufacturer-specific *Performance Characteristic Sheet* (PCS). This document, included in Appendix B, defines acceptable operating specifications and procedures for each model of XRF analyzer.

The following sections identify the personnel who performed these testing services, the methodology utilized, and technical information on the XRF data interpretation and laboratory analysis.

6.1 Inspection Personnel

The investigative survey was conducted on March 7, 8, and 13, 2023, by Fiberquant experienced and licensed inspector, Mr. Michael Breu and Mr. Mark Jefferson. The work was performed under the direction of Atlas personnel Mr. Chad Wells.

The following table 6.1 summarizes the inspector's training and certification to perform lead paint inspections. Certifications for Fiberquant and the Fiberquant staff are provided in Appendix C.

Table 6.1 Atlas Subcontracted Project Personnel	
Name	EPA Certification Number
Mr. Michael Breu	LBP-R-4219-3
Mr. Mark Jefferson	LBP-R-I180947-2

6.2 Testing Procedures – Viken Detection Corporation Model Pb200i

Viken Detection Corporation Model Pb200i (Viken Pb200i), serial number 1116 (cobalt 57 source assay date 10/1/2021) XRF analyzer was used during the LBP inspection by Fiberquant.

The Viken Pb200i is a complete lead paint analysis system, which quickly, accurately, and non-destructively measures the concentration of LBP on surfaces. The LPA-1 relies on the measurement of the K-shell X-rays to determine the amount of lead present in the painted surface. K-shell X-rays can penetrate many layers of paint and allow a good measurement of the lead content of paint to be made without being significantly affected by the thickness or number of layers of paint on the surface of the sample.

The Viken Pb200i has the ability to analyze and compute corrections for the differences in the energy spectrums relating to different substrates. This analysis of the energy spectrum means that the lead paint reading displayed on the instrument already accounts for any substrate effects and no correction is required by the operator. The Viken Pb200i 's field of view is limited to a depth of 3/8", deep enough to handle virtually all painted surfaces, but not prone to detect lead objects located behind the surface.

There are two measurement modes of operation in the Viken Pb200i analyzer namely the "Standard Mode"

and the "Quick Mode." In the "Standard" mode, the operator selects a fixed measurement time which remains constant irrespective of the lead signal. In the "Quick" mode, the analyzer automatically adjusts the measurement time to be the least time that is needed to make a definitive measurement with a 95% confidence level (2 sigma). The Viken Pb200i analyzer will finish a measurement once the 2 sigma confidence level is achieved, and the data is statistically meaningful. This time period for conclusive measurements is typically between 1 to 5 seconds, but can extend to a measurement of 60 seconds depending on the action level for abatement. Fiberquant utilized the Viken Pb200i in the "Quick" mode for the testing performed.

Upon arrival at the job the Subject Property and after the day's inspection work was completed, a "validation test" was performed to assure that the instrument was operating properly. A series of three test measurements using the nominal time which was used during the inspection were taken on the National Institute of Standards and Technology (NIST) Paint Film Standard (SRM No. 2579) as required by the instrument's Performance Characteristic Sheet (PCS). The individual readings and an average of the three readings were recorded and compared to the standards.

In all cases the instrument was functioning within the standard deviation as defined by the manufacturer and the PCS. All validation readings were recorded in a log book which accompanies the instrument. If for any reason the XRF does not pass the quality control procedures, it is Atlas' policy to replace that instrument with an XRF that passes the above criteria for calibration.

6.3 Interpretation of XRF Sampling Data

6.3.1 Classification of XRF Data

The parameters used to interpret XRF results are outlined in the HUD Guidelines and the PCS in Appendix F. According to the PCS, each XRF result is classified as **positive**, **negative**, or **inconclusive** as follows:

- Positive:** A positive classification indicates that lead is present on the testing combination at or above the HUD/EPA standard of 1.0 milligrams per square centimeter (mg/cm^2). A positive XRF result is any value greater than or equal to the threshold, as specified on the applicable XRF PCS.
- Negative:** A negative classification indicates that lead is not present on the testing combination at or above the HUD/EPA standard. A negative XRF result is any value less than the threshold specified on the PCS.
- Inconclusive:** Per the PCS, there is no inconclusive range for the Viken Pb200i.

Table 6.3 indicates the thresholds for the Viken Pb200i when using the Quick Mode for testing:

Table 6.3 Viken Pb200i	
SUBSTRATE	THRESHOLD (mg/cm ²)
Brick	1.0
Concrete	1.0
Drywall	1.0
Metal	1.0
Plaster	1.0
Wood	1.0

6.3.2 Classification for Disclosure

Atlas has reviewed the XRF sampling data provided by Fiberquant for each building component to identify positive, negative, and inconclusive readings.

The buildings and their paint were generally in intact condition during the LBP Inspection. The results from the paint that was tested showed LBP exists, as defined in the Residential LBP Hazard Reduction Act of 1992 (Title X) and as defined by the EPA regulation published in the January 5, 2001 Federal Register. LBP is defined as paint or other surface coatings that contain lead equal to or exceeding 1.0 mg/cm².

The XRF Positive Summary Report (Table D-1) is included in Appendix D. The LBP Hazard Summary (Table D-2) is included in Appendix D.

6.4 Confirmatory Paint Chip Analysis

As required by the HUD Guidelines, high inconclusive XRF readings must be verified with Atomic Absorption Spectrometry (AAS) analysis. However, there is no inconclusive range for the Viken Pb200i.

6.5 Interpretation of Field Survey Reports

Atlas reviewed the following Fiberquant reports:

- *Survey of Commercial Structure for Lead-Based Paint: Inspiration School, Building A*, dated March 7 & 8, 2023
- *Survey of Commercial Structure for Lead-Based Paint: Inspiration School, Building B*, dated March 8 & 13, 2023

These reports are included in Appendix D, which specify surfaces that were tested and XRF results for each surface.

For exterior and interior surfaces, when facing the main entrance of the property, the front entrance side is 'A', and, proceeding clockwise, the left side is 'B', the rear side is 'C', and the right side is 'D'. The property Site Plan is included in Appendix E.

Within the buildings, the sides of each room are assigned letters in the same way as the interior as a whole. That is, when standing in any interior room, with the main entrance of the property behind where one is standing, the side which is parallel to the main entrance is designated side 'A', and, again proceeding clockwise, the side on the left is 'B', the side one is facing (parallel to the rear side of the building) is 'C', and the right side is 'D'.

Finally, each building inspected had a designated number, each room within the buildings were assigned a

number or name. The name and number assigned each room are indicated on the Site Plan shown on the first page of the inspection reports.

6.6 Paint Chip Sampling

According to the Fiberquant XRF, one (1) inconclusive XRF readings was detected (there is no inconclusive range for the XRF device utilized by Fiberquant for this inspection); therefore, the reading was retaken. No paint chip samples were collected or analyzed.

7.0 SUMMARY OF FINDINGS

7.1 Testing Results

As a result, of the lead inspection conducted on March 7, 8, and 13, 2023, **144 LBP surface coatings** were identified on the property buildings as of the date of the survey. The **XRF Positive Summary Report** is located in Appendix D.

8.0 RECOMMENDATIONS

Based on the results of the LBP Inspection, Atlas has provided interim control options, abatement options and recommended hazard control options in the LBP Hazards Summary (Appendix D).

Additionally, Atlas provides the following recommendations:

- **Disclosure Requirements** – A copy of this complete report must be made available to new lessees (tenants) and/or must be provided to purchasers of this Subject Property under Federal law before they become obligated under any future lease or sales contract transactions (Section 1018 of Title X-found in 24 CFR Part 35 and 40 CFR Part 745), until the demolition of this Site. Appendix F includes a copy of the EPA Lead Disclosure. As applicable, Landlords (Lessors) and/or sellers are also required to distribute an educational pamphlet developed by the EPA entitled “Protect Your Family From Lead in Your Home” (Appendix G) and include standard warning language in their leases or sales contract to ensure that parents have the information they need to protect their children from LBP hazards.
- **Future Remodelling Precautions** – The LBP Inspection conducted on this Subject Property will help the Client and owner to ensure the health and safety of the occupants and the neighbourhood. Details concerning lead-safe work techniques and approved hazard control methods can be found in the HUD publication entitled: “Guidelines for the Evaluation and Control of LBP Hazards in Housing” (www.hud.gov/offices/lead). Future remodelling, repair, renovation and painting at the structure beyond the scale of minor repair and maintenance activities must be conducted in accordance with the EPA’s website on the Renovation, Repair and Painting (RRP) Rule at <http://www.epa.gov/lead/pubs/renovation.htm> for the scope and requirements of the Rule. Future LBP abatement or LBP hazard abatement at the structure must be conducted in accordance with the EPA’s Lead Abatement Rule (also within 40 CFR 745); see the EPA’s website for Lead Abatement Professionals.

APPENDIX A

DEFINITIONS OF KEY REGULATORY TERMS AND COMPONENT PICTURES

DEFINITIONS OF KEY REGULATORY TERMS


1. *Abatement*: A measure or set of measures designed to permanently eliminate lead-based paint hazards or lead-based paint. Abatement strategies include the removal of lead-based paint, enclosure, encapsulation, replacement of building components coated with lead-based paint, removal of lead-contaminated dust, and removal of lead-contaminated soil or overlaying of soil with a durable covering such as asphalt (grass and sod are considered interim control measures.) All of these strategies require preparation; cleanup; waste disposal; post abatement clearance testing; recordkeeping; and, if applicable, monitoring. (For full EPA definition, see 40 CFR 745.223.)
2. *Available* means in the possession of or reasonably obtainable by the seller or lessor at the time of the disclosure.
3. *Bare Soil*: Soil not covered with grass, sod, some other similar vegetation or paving, including the sand in sandboxes.
4. *Chewable surface*: An interior or exterior surface painted with lead-based paint that a young child can mouth or chew. A chewable surface is the same as an “accessible surface” as defined in 42 U.S.C. 4851b(2). Hard metal substrates and other materials that cannot be dented by the bite of a young child are not considered chewable.
5. *Deteriorated paint*: Any paint coating on a damaged or deteriorated surface or fixture, or any interior or exterior lead-based paint that is peeling, chipping, blistering, flaking, worn, chalking, alligating, cracking, or otherwise becoming separated from the substrate.
6. *Dripline/foundation area*: The area within 3 feet out from the building wall and surrounding the perimeter of the building.
7. *Dust-lead hazard*: Surface dust in residence that contains an area or mass concentration of lead equal to or in excess of the standard established by the EPA under Title IV of the Toxic Substances Control Act. EPA standards for dust-lead hazards, which are based on wipe samples, are published at 40 CFR 745.65(b); as of the publication of this edition of these Guidelines, these are 40 µg/ft² on floors and 250 µg/ft² on interior window sills. Also, called lead-contaminated dust.
8. *Evaluation* means a risk assessment and/or inspection.
9. *Friction surface*: Any interior or exterior surface, such as window or stair tread, subject to abrasion or friction.
10. *Garden Area*: An area where plants are cultivated for human consumption or for decorative purposes.
11. *Impact surface*: An interior or exterior surface, such as surfaces on doors, subject to damage by repeated impact or contact.
12. *Inspection* means: A surface-by-surface investigation to determine the presence of lead-based paint as provided in Section 302(c) of the Lead-Based Paint Poisoning and Prevention Act [42 U.S.C. 4822], and the provision of a report explaining the results of the investigation.
13. *Interim Controls*: A set of measures designed to temporarily reduce human exposure or possible exposure to lead-based paint hazards. Such measures include, but are not limited to, specialized cleaning, repairs, maintenance, painting, temporary containment, and the establishment and operation of management and resident education programs. Monitoring, conducted by the owners, and reevaluations, conducted by professionals, are integral elements of interim control. Interior controls include dust removal; paint film stabilization; treatment of friction and impact surfaces; installation of soil coverings, such as grass or sod; and land use controls. Interim controls that disturb painted surfaces are renovation activities under EPA’s Renovation, Repair and Repainting Rule.

Lead-Based Paint Inspection
Miami Unified School District #40 – Inspiration School
912 West Rose Road
Miami, Arizona 85539


14. *Lead-based paint* means paint or other surface coatings that contain lead equal to or in excess of 1.0 milligrams per square centimeter or 0.5 percent by weight.
15. *Lead-based paint free housing* means target housing that has been found to be free of paint or other surface coatings that contain lead equal to or in excess of 1.0 milligrams per square centimeter or 0.5 percent by weight.
16. *Lead-based paint hazard*: A condition in which exposure to lead from lead-contaminated dust, lead-contaminated soil, or deteriorated lead-based paint would have an adverse effect on human health (as established by the EPA at 40 CFR 745.65, under Title IV of the Toxic Substances Control Act.) Lead-based paint hazards include, for example, paint-lead hazards, dust-lead hazards, and soil-lead hazards.
17. *Owner* means any entity that has legal title to target housing, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations, except where a mortgagee holds legal title to property serving as collateral for a mortgage loan, in which case the Owner would be the mortgagor.
18. *Paint-lead hazard*: Lead-based paint on a friction surface that is subject to abrasion and where a dust-lead hazard is present on the nearest horizontal surface underneath the friction surface (e.g. the window sill, or from a related building component; a chewable lead-based painted surface on which there is evidence of teeth marks; or any other deteriorated lead-based paint in any residential building or child-occupied facility or on the exterior of any residential building or child-occupied facility.
19. *Play Area*: An area or frequent soil contact by children under the age of 6 as indicated by, but not limited to, such factors including the following: the presences of outdoor play equipment (e.g., sandboxes, swing sets, and sliding boards), toys or other children’s possessions, observation of play patterns, or information provided by parents, residents, caregivers, or property owners.
20. *Soil-lead hazard*: Bare soil on residential property that contains lead in excess of the standard established by the EPA under Title IV of the Toxic Substance Control Act. EPA standards for soil-lead hazards, published at 40 CFR 745.65(c), as part of the publication of this edition of these Guidelines, is 400 µg/g in play areas and 1,200 µg/g in the rest of the yard. Also referred to as lead-contaminated soil.
21. *Target housing* means any housing constructed prior to 1978, except housing for the elderly or persons with disabilities (unless any child who is less than 6 years of age resides or is expected to reside in such housing) or any 0-bedroom dwelling.

COMPONENT PICTURES


Drawing # 1




Drawing # 2



Drawing # 3



Drawing # 4



APPENDIX B

XRF PERFORMANCE CHARACTERISTIC SHEET

Performance Characteristic Sheet

EFFECTIVE DATE: December 1, 2020

MANUFACTURER AND MODEL:

Make: ***Viken Detection*** (previously Heuresis)
 Models: ***Model Pb200i***
 Source: ***⁵⁷Co, 5 mCi (nominal – new source)***

FIELD OPERATION GUIDANCE

ACTION LEVEL SETTING:

0.5 mg/cm²

OPERATING PARAMETERS:

Action Level mode

XRF CALIBRATION CHECK LIMITS:

0.8 to 1.2 mg/cm² (inclusive) at Action Level setting = 1.0 mg/cm²

SUBSTRATE CORRECTION:

Not applicable

INCONCLUSIVE RANGE OR THRESHOLD:

ACTION LEVEL MODE READING DESCRIPTION	SUBSTRATE	INCONCLUSIVE RANGE (mg/cm ²)
Results not corrected for substrate bias on any substrate	Brick	0.4 – 0.6
	Concrete	0.4 – 0.6
	Drywall	0.4 – 0.6
	Metal	0.4 – 0.6
	Plaster	0.4 – 0.6
	Wood	0.4 – 0.6

BACKGROUND INFORMATION

EVALUATION DATA SOURCE AND DATE:

This sheet is supplemental information to be used in conjunction with Chapter 7 of the HUD *Guidelines for the Evaluation and Control of Lead-Based Paint Hazards in Housing*, 2012 Edition ("HUD Guidelines"). Performance parameters shown on this sheet are calculated using test results on building components in the HUD archive. Testing was conducted on 146 test samples in January 2020, with two separate instruments running software version Pb200i 5.0 (DEBUG version) in Action Level test mode. The actual source strength of each instrument on the day of testing was approximately 2.9 mCi; source ages were approximately 9 months.

OPERATING PARAMETERS

Performance parameters shown in this sheet are applicable only when properly operating the instrument using the manufacturer's instructions and procedures described in Chapter 7 of the HUD Guidelines.

XRF CALIBRATION CHECK:

The calibration of the XRF instrument should be checked **with the Action Level set to 1.0 mg/cm²** using the paint film nearest 1.0 mg/cm² in the NIST Standard Reference Material (SRM) used (e.g., for NIST SRM 2579, use the 1.02 mg/cm² film; for NIST SRM 2579a, use the 1.04 mg/cm² film).

If the average (rounded to 1 decimal place) of three readings is outside the acceptable calibration check range, follow the manufacturer's instructions to bring the instrument into control before XRF testing proceeds.

EVALUATING THE QUALITY OF XRF TESTING:

Randomly select ten testing combinations for retesting from each house or from two randomly selected units in multifamily housing.

Conduct XRF re-testing at the ten testing combinations selected for retesting.

Determine if the XRF testing in the units or house passed or failed the test by applying the steps below. Compute the Retest Tolerance Limit by the following steps:

Determine XRF results for the original and retest XRF readings. In single-family and multi-family housing, a result is defined as a single reading. Therefore, there will be ten original and ten retest XRF results for each house or for the two selected units.

Calculate the average of the original XRF result and the retest XRF result for each testing combination.

Square the average for each testing combination.

Add the ten squared averages together. Call this quantity C.

Multiply the number C by 0.0072. Call this quantity D.

Add the number 0.032 to D. Call this quantity E.

Take the square root of E. Call this quantity F.

Multiply F by 1.645. The result is the Retest Tolerance Limit.

Compute the average of all ten original XRF readings.

Compute the average of all ten re-test XRF readings.

Find the absolute difference of the two averages.

If the difference is less than the Retest Tolerance Limit, the inspection has passed the retest. If the difference of the overall averages equals or exceeds the Retest Tolerance Limit, this procedure should be repeated with ten new testing combinations. If the difference of the overall averages is equal to or greater than the Retest Tolerance Limit a second time, then the inspection should be considered deficient.

Use of this procedure is estimated to produce a spurious result approximately 1% of the time. That is, results of this procedure will call for further examination when no examination is warranted in approximately 1 out of 100 dwelling units tested.

TESTING TIMES:

The instrument time to take a reading varied within a narrow range from 5 to 6 seconds, with a small number (3%) of longer times from 7 to 11 seconds. The longer readings were almost all on wood substrates. This range of reading times applies only to instruments with the same source strength as those tested (2.9 mCi at the time of PCS testing). Instruments with stronger sources will have shorter reading times and those with weaker sources, longer reading times.

CLASSIFICATION OF RESULTS:

XRF results are classified as **positive** if they are **greater than or equal** to 0.6 mg/cm², **negative** if they are **less than or equal** to 0.4 mg/cm² and **inconclusive** if they are **equal** to 0.5 mg/cm².

DOCUMENTATION:

This XRF Performance Characteristic Sheet (PCS) was developed by QuanTech, Inc., under a contract with the U.S. Department of Housing and Urban Development, Office of Lead Hazard Control and Healthy Homes.

A report titled *Methodology for XRF Performance Characteristic Sheets* (EPA 747-R-95-008) provides an explanation of the statistical methodology used to develop Performance Characteristic Sheets at the Federal standard (Action Level) of 1.0 mg/cm², and provides empirical results from using the recommended inconclusive ranges or thresholds for specific XRF instruments. The report may be downloaded at <http://www2.epa.gov/lead/methodology-xrf-performance-characteristic-sheets-epa-747-r-95-008-september-1997>. The methodology was subsequently generalized by QuanTech for application to other Action Levels.

APPENDIX C

LABORATORY CERTIFICATIONS FOR FIBERQUANT & EPA CERTIFICATIONS FOR FIBERQUANT AND ATLAS PERSONNEL

United States Environmental Protection Agency

This is to certify that

Fiberquant Analytical Services

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires February 25, 2024

LBP-2033-2

Certification #

September 22, 2020

Issued On



A handwritten signature in black ink that reads "Michelle Price".

Michelle Price, Chief

Lead, Heavy Metals, and Inorganics Branch

United States Environmental Protection Agency

This is to certify that



Michael A Breu

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226 as:

Risk Assessor

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires March 30, 2025

LBP-R-4219-3

Certification #

October 29, 2021

Issued On



A handwritten signature in black ink, appearing to read "Adrienne Priselac".

Adrienne Priselac, Manager, Toxics Office

Land Division

United States Environmental Protection Agency

This is to certify that



Mark C Jefferson

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226 as:

Risk Assessor

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires November 23, 2023

LBP-R-1180947-2

Certification #

February 07, 2020

Issued On




A handwritten signature in black ink, appearing to read "Adrienne Priselac".

Adrienne Priselac, Manager, Toxics Office

Land Division

United States Environmental Protection Agency

This is to certify that



Chad D Wells

has fulfilled the requirements of the Toxic Substances Control Act (TSCA) Section 402, and has received certification to conduct lead-based paint activities pursuant to 40 CFR Part 745.226 as:

Risk Assessor

In the Jurisdiction of:

All EPA Administered Lead-based Paint Activities Program States, Tribes and Territories

This certification is valid from the date of issuance and expires September 30, 2024

LBP-R-80-2

Certification #

August 31, 2021

Issued On



A handwritten signature in black ink, appearing to read "Adrienne Priselac".

Adrienne Priselac, Manager, Toxics Office

Land Division

APPENDIX D

Table D-1 XRF POSITIVE SUMMARY REPORT

Table D-2 LBP HAZARD SUMMARY

Fiberquant XRF Surveys (2 Reports)



**Survey of School Buildings for Lead-Based Paint:
Inspiration School, Miami, AZ 85339**

Prepared for: Teresa Harris
ATC Group Services/Atlas
9185 S Farmer Ave Ste 111
Tempe, AZ 85284

Fiberquant Job #202301331 (XRF)

Introduction

At the client's request, the two buildings at the Inspiration School were screened for lead-based paint (LBP). The analytical methodology was as described in the HUD guidelines (*Guidelines for the Evaluation and Control of Lead-based Paint Hazards in Housing*, July 2012). The property surveyed was located at 901-999 Rose Rd. Miami, AZ 85339. The school was built in 1921 and belongs to the Miami Unified School District, telephone (928) 425-3271.

The survey was conducted and interpreted by Mark Jefferson and Michael Breu under the employment of Fiberquant Analytical Services (EPA firm certification number AZ-LBP-2033-2, expires 02/25/2024). Mark (LBP-R-1180947-2, Expires 11/23/2023) and Michael (LBP-R-4219-2, Expires 03/30/2025) have successfully completed the Federal EPA course and testing for lead-based paint for the State of Arizona.

Executive Summary

Several interior and exterior components tested were found to be positive for lead-based paint (i.e., containing $\geq 1.0\text{mg Pb/cm}^2$ with 95% confidence).

Procedures

The site was visited on March 6th, 7th and 13th. Selected sites in each room (nominally one for each type of component except that all walls are tested) and exterior were surveyed for the presence of lead-based-paint (LBP) using a spectrum analyzer portable X-ray fluorescence (XRF) paint tester, Viken Detection Corporation model Pb200i, serial number 02627 (cobalt 57 source assay date 7/26/2022) and serial number 3355 (cobalt 57 source assay date 2/2/2023). The performance characteristic sheet for this instrument is available on the Internet at https://www.hud.gov/sites/documents/HEURESISPCS_JUNE17.PDF. The spectrum analyzer automatically subtracts from a spectrum the fluorescence from the substrate of the paint so as to give an accurate reading of lead content without taking of samples or stripping of paint. This is performed via a computer program stored in the analyzer, which gives an instantaneous readout of the lead content of a site in mg/cm^2 . The instrument performance is checked before and after the job or unit (minimum every 4 hours) by reading a 1.0 mg/cm^2 sample three times.

According to the EPA Performance Characteristics Sheet for the Viken Pb200i, the quick mode gives correct threshold-type readings needing no substrate corrections. That is, the instrument counts a sufficient amount of time to determine to 95% confidence whether a given site is >1.0 mg/cm². The closer the site is to 1.0, the longer the counting time. Per the PCS, there is no inconclusive range.

The report of data is attached.

Results

Multiple interior and exterior components tested were found to be positive for lead-based paint (i.e., containing ≥ 1.0 mg Pb/cm² with 95% confidence). They are listed on the attached spreadsheets.

It is important to note that the *HUD Guidelines for the Reduction of Lead Hazards in Public and Indian Housing, 2012 revision*, stipulates that one of each component/substrate combination be tested in each room equivalent with the exception of the walls, in which case all four are to be tested. There are many occasions where a particular component/substrate combination tests positive in one room and then negative in another room despite indistinguishable construction histories. In these cases it is impossible to positively ascertain whether or not every member of a component/substrate combination is positive or negative for lead-based paint without actually testing every member in the home. As such, one can assume that if a combination is found to be positive for lead-based paint in a home, then every similar but untested combination is also positive unless proven otherwise.

The Occupational Safety and Health Administration (OSHA) Lead in Construction Standard states that "negative" readings (i.e. those below the HUD/EPA definition of what constitutes LBP (1.0 mg/cm²) do not relieve contractors from performing exposure assessments (personal air monitoring) on their employees per the OSHA Lead Standard, and should not be interpreted as lead free. Although a reading may indicate "negative", airborne lead concentrations still may exceed the OSHA Action Level or the OSHA Permissible Exposure Limit (PEL) depending on the work activity.



3/17/2023

Mark Jefferson

Company Viken Detection
 Model Pb200i
 Instrument Type XRF Lead Paint Analyzer
 Serial Number 2627
 App Version Pb200i-4.1-11

Reading #	Concentration	Units	Result	Date	Time	Analytic Mode	Job name	Interior/exterior	Room	Substrate	Color	Condition	Wall	Location	Member	Component
1	0.9	mg/cm2	Negative	3/7/2023	11:24:53	Lead Paint		Calibration								
2	0.8	mg/cm2	Negative	3/7/2023	11:25:10	Lead Paint		Calibration								
3	0.9	mg/cm2	Negative	3/7/2023	11:25:24	Lead Paint		Calibration								
4	0.1	mg/cm2	Negative	3/7/2023	11:25:41	Lead Paint		Calibration								
5	0.1	mg/cm2	Negative	3/7/2023	11:25:49	Lead Paint		Calibration								
6	0.1	mg/cm2	Negative	3/7/2023	11:25:55	Lead Paint		Calibration								
7	1.2	mg/cm2	Positive	3/7/2023	11:27:36	Lead Paint	202301331	Interior	1-r	Plaster	Offwhite	Intact	A	Center	Room	Wall
8	1.1	mg/cm2	Positive	3/7/2023	11:29:33	Lead Paint	202301331	Interior	1-r	Plaster	Offwhite	Intact	B	Center	Room	Wall
9	1.6	mg/cm2	Positive	3/7/2023	11:30:04	Lead Paint	202301331	Interior	1-r	Plaster	Brown	Intact	C	Center	Room	Wall
10	2.1	mg/cm2	Positive	3/7/2023	11:30:23	Lead Paint	202301331	Interior	1-r	Plaster	Brown	Intact	D	Center	Room	Wall
11	1.2	mg/cm2	Positive	3/7/2023	11:31:36	Lead Paint	202301331	Interior	1-r	Plaster	Gray	Intact	D	Center	Room	Baseboard
12	0.2	mg/cm2	Negative	3/7/2023	11:32:48	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	A	Center	Door	Door
13	0.3	mg/cm2	Negative	3/7/2023	11:33:05	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	A	Center	Door	R Casing
14	0.2	mg/cm2	Negative	3/7/2023	11:33:20	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	A	Center	Door	R Jamb
15	0.2	mg/cm2	Negative	3/7/2023	11:33:48	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	A	Center	Door	panel
16	0.4	mg/cm2	Negative	3/7/2023	11:34:49	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	B	Right	Door	Door
17	0.2	mg/cm2	Negative	3/7/2023	11:35:58	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	B	Right	Door	R Casing
18	0.5	mg/cm2	Negative	3/7/2023	11:36:11	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	B	Right	Door	R Jamb
19	0.5	mg/cm2	Negative	3/7/2023	11:37:26	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	B	Right	Door	Door
20	0.3	mg/cm2	Negative	3/7/2023	11:37:39	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	B	Right	Door	R Casing
21	0.3	mg/cm2	Negative	3/7/2023	11:37:53	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	B	Right	Door	R Jamb
22	0.2	mg/cm2	Negative	3/7/2023	11:38:40	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	C	Left	Door	Door
23	0.2	mg/cm2	Negative	3/7/2023	11:40:14	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	C	Left	Door	Door
24	0.3	mg/cm2	Negative	3/7/2023	11:40:27	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	C	Left	Door	R Casing
25	0.3	mg/cm2	Negative	3/7/2023	11:40:38	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	C	Left	Door	R Jamb
26	0.3	mg/cm2	Negative	3/7/2023	11:41:13	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	D	Left	Door	Door
27	0.4	mg/cm2	Negative	3/7/2023	11:41:31	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	D	Left	Door	L casing
28	0.4	mg/cm2	Negative	3/7/2023	11:41:43	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	D	Left	Door	L Jamb
29	0.2	mg/cm2	Negative	3/7/2023	11:43:06	Lead Paint	202301331	Interior	1-a	Plaster	Offwhite	Intact	A	Center	Room	Wall
30	0.3	mg/cm2	Negative	3/7/2023	11:43:31	Lead Paint	202301331	Interior	1-a	Drywall	Offwhite	Intact	B	Center	Room	Wall
31	0.4	mg/cm2	Negative	3/7/2023	11:43:43	Lead Paint	202301331	Interior	1-a	Plaster	Offwhite	Intact	B	Center	Room	Wall
32	0.2	mg/cm2	Negative	3/7/2023	11:44:02	Lead Paint	202301331	Interior	1-a	Plaster	Offwhite	Intact	C	Center	Room	Wall
33	0.2	mg/cm2	Negative	3/7/2023	11:44:16	Lead Paint	202301331	Interior	1-a	Plaster	Offwhite	Intact	D	Center	Room	Wall
34	0.6	mg/cm2	Negative	3/7/2023	11:45:44	Lead Paint	202301331	Interior	1-a	Plaster	Offwhite	Intact	B	Center	Room	Baseboard
35	0.2	mg/cm2	Negative	3/7/2023	11:46:21	Lead Paint	202301331	Interior	1-a	Wood	Offwhite	Intact	D	Center	Room	Shelf
36	0.2	mg/cm2	Negative	3/7/2023	11:46:40	Lead Paint	202301331	Interior	1-a	Wood	Offwhite	Intact	D	Center	Room	Shelf Support
37	0.2	mg/cm2	Negative	3/7/2023	11:47:26	Lead Paint	202301331	Interior	1-a	Wood	Offwhite	Intact	C	Center	Room	chalkboard frame
38	0.6	mg/cm2	Negative	3/7/2023	11:48:14	Lead Paint	202301331	Interior	1-a	stone	Offwhite	Intact	C	Center	Room	chalkboard
39	0.1	mg/cm2	Negative	3/7/2023	11:48:53	Lead Paint	202301331	Interior	1-a	Wood	Stained	Intact	D	Center	Door	Door
40	0.1	mg/cm2	Negative	3/7/2023	11:49:09	Lead Paint	202301331	Interior	1-a	Wood	Stained	Intact	D	Center	Door	R Casing
41	0.2	mg/cm2	Negative	3/7/2023	11:49:22	Lead Paint	202301331	Interior	1-a	Wood	Stained	Intact	D	Center	Door	R Jamb
42	0.3	mg/cm2	Negative	3/7/2023	11:49:53	Lead Paint	202301331	Interior	1-a	Wood	White	Intact	A	Center	Closet	Door
43	0.3	mg/cm2	Negative	3/7/2023	11:50:29	Lead Paint	202301331	Interior	1-a	Wood	Stained	Intact	A	Center	Closet	Shelf

44	0.3 mg/cm2	Negative	3/7/2023	11:50:46	Lead Paint	202301331	Interior	1-a	Wood	Stained	Intact	A	Center	Closet	Shelf Support
45	0.1 mg/cm2	Negative	3/7/2023	11:54:22	Lead Paint	202301331	Interior	1-r	Vinyl	Tan	Intact	A	Center	Room	Floor
46	0.2 mg/cm2	Negative	3/7/2023	11:55:27	Lead Paint	202301331	Interior	1-b	Plaster	White	Intact	A	Center	Room	Wall
47	0.3 mg/cm2	Negative	3/7/2023	11:55:49	Lead Paint	202301331	Interior	1-b	Drywall	White	Intact	A	Center	Room	Wall
48	0.2 mg/cm2	Negative	3/7/2023	11:56:15	Lead Paint	202301331	Interior	1-b	Plaster	White	Intact	C	Center	Room	Wall
49	0.3 mg/cm2	Negative	3/7/2023	11:56:29	Lead Paint	202301331	Interior	1-b	Plaster	White	Intact	B	Center	Room	Wall
50	0.3 mg/cm2	Negative	3/7/2023	11:56:49	Lead Paint	202301331	Interior	1-b	Plaster	White	Intact	D	Center	Room	Wall
51	0.2 mg/cm2	Negative	3/7/2023	11:57:47	Lead Paint	202301331	Interior	1-b	Plaster	White	Intact	B	Center	Room	Baseboard
52	1 mg/cm2	Positive	3/7/2023	11:58:28	Lead Paint	202301331	Interior	1-b	Vinyl	Brown	Intact	B	Center	Room	Floor
53	0.1 mg/cm2	Negative	3/7/2023	11:59:30	Lead Paint	202301331	Interior	1-b	Wood	White	Intact	D	Center	Room	Cabinet
54	0.1 mg/cm2	Negative	3/7/2023	11:59:44	Lead Paint	202301331	Interior	1-b	Wood	White	Intact	D	Center	Room	Cabinet door
55	0.2 mg/cm2	Negative	3/7/2023	12:00:33	Lead Paint	202301331	Interior	1-b	stone	Brown	Intact	B	Center	Room	chalkboard
56	0.3 mg/cm2	Negative	3/7/2023	12:02:00	Lead Paint	202301331	Interior	1-b	Wood	White	Intact	B	Center	Room	frame
57	0.3 mg/cm2	Negative	3/7/2023	12:02:43	Lead Paint	202301331	Interior	1-b	Wood	White	Intact	B	Center	Room	bulletin board
58	0 mg/cm2	Negative	3/7/2023	12:03:19	Lead Paint	202301331	Interior	1-b	Wood	Stained	Intact	B	Center	Door	Door
59	0.2 mg/cm2	Negative	3/7/2023	12:03:38	Lead Paint	202301331	Interior	1-b	Wood	Stained	Intact	B	Center	Door	L casing
60	0.3 mg/cm2	Negative	3/7/2023	12:03:52	Lead Paint	202301331	Interior	1-b	Wood	Stained	Intact	B	Center	Door	L Jamb
61	0 mg/cm2	Negative	3/7/2023	12:04:24	Lead Paint	202301331	Interior	1-b	Wood	Gray	Intact	C	Center	Door	Door
62	0.3 mg/cm2	Negative	3/7/2023	12:04:51	Lead Paint	202301331	Interior	1-b	Wood	Offwhite	Intact	C	Center	Door	L casing
63	0.2 mg/cm2	Negative	3/7/2023	12:05:14	Lead Paint	202301331	Interior	1-b	Wood	Gray	Intact	C	Center	Door	L Jamb
64	1.4 mg/cm2	Positive	3/7/2023	12:05:44	Lead Paint	202301331	Interior	1-b	Wood	Gray	Intact	C	Center	Door	footer
65	0.4 mg/cm2	Negative	3/7/2023	12:06:42	Lead Paint	202301331	Interior	1-b	Plaster	White	Intact	B	Center	Room	Ceiling
66	0.5 mg/cm2	Negative	3/7/2023	12:09:25	Lead Paint	202301331	Interior	1-a	Plaster	White	Intact	B	Center	Room	Ceiling
67	0.4 mg/cm2	Negative	3/7/2023	12:10:10	Lead Paint	202301331	Interior	1-a	Metal	White	Intact	B	Center	Room	conduit
68	0.2 mg/cm2	Negative	3/7/2023	12:11:06	Lead Paint	202301331	Interior	1-b	Metal	White	Intact	C	Center	Room	panel
69	0.5 mg/cm2	Negative	3/7/2023	12:11:32	Lead Paint	202301331	Interior	1-b	Wood	White	Intact	C	Center	Room	Baseboard
70	0.6 mg/cm2	Negative	3/7/2023	12:12:59	Lead Paint	202301331	Interior	1-c	Plaster	White	Intact	A	Center	Room	Wall
71	0.9 mg/cm2	Negative	3/7/2023	12:13:28	Lead Paint	202301331	Interior	1-c	Plaster	White	Intact	B	Center	Room	Wall
72	0.6 mg/cm2	Negative	3/7/2023	12:14:00	Lead Paint	202301331	Interior	1-c	Plaster	White	Intact	C	Center	Room	Wall
73	0.1 mg/cm2	Negative	3/7/2023	12:14:14	Lead Paint	202301331	Interior	1-c	Plaster	White	Intact	D	Center	Room	Wall
74	3.2 mg/cm2	Positive	3/7/2023	12:14:51	Lead Paint	202301331	Interior	1-c	Plaster	White	Intact	D	Center	Room	Baseboard
75	4.7 mg/cm2	Positive	3/7/2023	12:15:25	Lead Paint	202301331	Interior	1-c	Wood	White	Intact	B	Center	Room	Baseboard
76	2.6 mg/cm2	Positive	3/7/2023	12:16:20	Lead Paint	202301331	Interior	1-c	Wood	White	Intact	B	Center	Room	frame
77	0.4 mg/cm2	Negative	3/7/2023	12:16:33	Lead Paint	202301331	Interior	1-c	Wood	White	Intact	B	Center	Room	bulletin board
78	0.2 mg/cm2	Negative	3/7/2023	12:16:53	Lead Paint	202301331	Interior	1-c	Wood	White	Intact	B	Center	Room	Shelf
79	0.2 mg/cm2	Negative	3/7/2023	12:17:06	Lead Paint	202301331	Interior	1-c	Wood	White	Intact	B	Center	Room	Shelf Support
80	0.6 mg/cm2	Negative	3/7/2023	12:17:45	Lead Paint	202301331	Interior	1-c	stone	Black	Intact	B	Center	Room	chalkboard
81	0.1 mg/cm2	Negative	3/7/2023	12:18:16	Lead Paint	202301331	Interior	1-c	Wood	Red	Intact	B	Left	Room	Cabinet
82	0.2 mg/cm2	Negative	3/7/2023	12:18:45	Lead Paint	202301331	Interior	1-c	Metal	Blue	Intact	B	Left	Room	Cabinet door
83	3.9 mg/cm2	Positive	3/7/2023	12:19:33	Lead Paint	202301331	Interior	1-c	Wood	Gray	Intact	B	Left	Door	Door
84	4.6 mg/cm2	Positive	3/7/2023	12:19:54	Lead Paint	202301331	Interior	1-c	Wood	White	Intact	B	Left	Door	L casing
85	4 mg/cm2	Positive	3/7/2023	12:20:07	Lead Paint	202301331	Interior	1-c	Wood	White	Intact	B	Left	Door	L Jamb
86	3.2 mg/cm2	Positive	3/7/2023	12:20:41	Lead Paint	202301331	Interior	1-c	Wood	White	Intact	C	Center	Closet	Door
87	0.2 mg/cm2	Negative	3/7/2023	12:21:13	Lead Paint	202301331	Interior	1-c	Wood	Stained	Intact	C	Center	Closet	Shelf
88	0.2 mg/cm2	Negative	3/7/2023	12:21:27	Lead Paint	202301331	Interior	1-c	Wood	Stained	Intact	C	Center	Closet	Shelf Support
89	0.1 mg/cm2	Negative	3/7/2023	12:22:14	Lead Paint	202301331	Interior	1-c	Wood	Stained	Intact	C	Left	Door	Door
90	0.1 mg/cm2	Negative	3/7/2023	12:22:28	Lead Paint	202301331	Interior	1-c	Wood	Stained	Intact	C	Left	Door	R Casing
91	0.3 mg/cm2	Negative	3/7/2023	12:22:39	Lead Paint	202301331	Interior	1-c	Wood	Stained	Intact	C	Left	Door	R Jamb
92	0.2 mg/cm2	Negative	3/7/2023	12:23:14	Lead Paint	202301331	Interior	1-c	Metal	Gray	Intact	D	Center	Door	Door
93	0.3 mg/cm2	Negative	3/7/2023	12:23:39	Lead Paint	202301331	Interior	1-c	Metal	White	Intact	D	Center	Door	L casing

94	0.3 mg/cm2	Negative	3/7/2023	12:23:58	Lead Paint	202301331	Interior	1-c	Metal	Gray	Intact	D	Center	Door	L Jamb
95	0.3 mg/cm2	Negative	3/7/2023	12:27:45	Lead Paint	202301331	Interior	1-c	Plaster	White	Intact	D	Center	Room	Ceiling
96	0.2 mg/cm2	Negative	3/7/2023	12:29:37	Lead Paint	202301331	Interior	1-c	Metal	White	Intact	D	Center	Room	vent
97	0.7 mg/cm2	Negative	3/7/2023	12:31:35	Lead Paint	202301331	Interior	1-d	Plaster	White	Intact	A	Center	Room	Wall
98	0.2 mg/cm2	Negative	3/7/2023	12:31:52	Lead Paint	202301331	Interior	1-d	Plaster	White	Intact	B	Center	Room	Wall
99	0.6 mg/cm2	Negative	3/7/2023	12:32:04	Lead Paint	202301331	Interior	1-d	Plaster	White	Intact	C	Center	Room	Wall
100	0.1 mg/cm2	Negative	3/7/2023	12:32:33	Lead Paint	202301331	Interior	1-d	Drywall	White	Intact	D	Center	Room	Wall
101	0.6 mg/cm2	Negative	3/7/2023	12:32:48	Lead Paint	202301331	Interior	1-d	Plaster	White	Intact	D	Center	Room	Wall
102	2.9 mg/cm2	Positive	3/7/2023	12:33:30	Lead Paint	202301331	Interior	1-d	Plaster	White	Intact	B	Center	Room	Baseboard
103	0.3 mg/cm2	Negative	3/7/2023	12:33:50	Lead Paint	202301331	Interior	1-d	Wood	White	Intact	C	Center	Room	Baseboard
104	0.5 mg/cm2	Negative	3/7/2023	12:34:15	Lead Paint	202301331	Interior	1-d	Vinyl	Offwhite	Intact	C	Center	Room	Floor
105	0.5 mg/cm2	Negative	3/7/2023	12:34:54	Lead Paint	202301331	Interior	1-d	Wood	Offwhite	Intact	A	Center	Room	Cabinet
106	0.8 mg/cm2	Negative	3/7/2023	12:35:06	Lead Paint	202301331	Interior	1-d	Wood	Offwhite	Intact	A	Center	Room	Cabinet door
107	0.7 mg/cm2	Negative	3/7/2023	12:35:31	Lead Paint	202301331	Interior	1-d	Wood	Offwhite	Intact	B	Center	Room	frame
108	0.4 mg/cm2	Negative	3/7/2023	12:35:47	Lead Paint	202301331	Interior	1-d	Wood	Offwhite	Intact	B	Center	Room	bulletin board
109	0.1 mg/cm2	Negative	3/7/2023	12:36:52	Lead Paint	202301331	Interior	1-d	Wood	Stained	Intact	A	Center	Door	Door
110	0.1 mg/cm2	Negative	3/7/2023	12:37:06	Lead Paint	202301331	Interior	1-d	Wood	Stained	Intact	A	Center	Door	L casing
111	0.3 mg/cm2	Negative	3/7/2023	12:37:17	Lead Paint	202301331	Interior	1-d	Wood	Stained	Intact	A	Center	Door	L Jamb
112	0.5 mg/cm2	Negative	3/7/2023	12:37:48	Lead Paint	202301331	Interior	1-d	Wood	Gray	Intact	B	Center	Door	Door
113	0.4 mg/cm2	Negative	3/7/2023	12:38:07	Lead Paint	202301331	Interior	1-d	Wood	White	Intact	B	Center	Door	R Casing
114	0.6 mg/cm2	Negative	3/7/2023	12:38:21	Lead Paint	202301331	Interior	1-d	Wood	White	Intact	B	Center	Door	R Jamb
115	0.5 mg/cm2	Negative	3/7/2023	12:41:41	Lead Paint	202301331	Interior	1-d	Plaster	White	Intact	C	Center	Room	Ceiling
116	0.2 mg/cm2	Negative	3/7/2023	12:42:04	Lead Paint	202301331	Interior	1-d	Metal	White	Intact	C	Center	Room	vent
117	0.2 mg/cm2	Negative	3/7/2023	12:44:48	Lead Paint	202301331	Interior	1-e	Plaster	White	Intact	A	Center	Room	Wall
118	0.3 mg/cm2	Negative	3/7/2023	12:45:08	Lead Paint	202301331	Interior	1-e	Drywall	White	Intact	A	Center	Room	Wall
119	0.3 mg/cm2	Negative	3/7/2023	12:46:03	Lead Paint	202301331	Interior	1-e	Plaster	Offwhite	Intact	C	Center	Room	Wall
120	0.1 mg/cm2	Negative	3/7/2023	12:46:29	Lead Paint	202301331	Interior	1-e	Plaster	Offwhite	Intact	D	Center	Room	Wall
121	0.4 mg/cm2	Negative	3/7/2023	12:47:19	Lead Paint	202301331	Interior	1-e	Concrete	Stained	Intact	D	Center	Room	Floor
122	0.1 mg/cm2	Negative	3/7/2023	12:48:00	Lead Paint	202301331	Interior	1-e	Wood	White	Intact	B	Center	Room	Shelf
123	0.1 mg/cm2	Negative	3/7/2023	12:48:13	Lead Paint	202301331	Interior	1-e	Wood	White	Intact	B	Center	Room	Shelf Support
124	0.3 mg/cm2	Negative	3/7/2023	12:48:52	Lead Paint	202301331	Interior	1-e	Wood	Offwhite	Intact	D	Center	Room	Cabinet
125	0.3 mg/cm2	Negative	3/7/2023	12:49:05	Lead Paint	202301331	Interior	1-e	Wood	Offwhite	Intact	D	Center	Room	Cabinet door
126	0.2 mg/cm2	Negative	3/7/2023	12:49:53	Lead Paint	202301331	Interior	1-e	Metal	Tan	Intact	A	Center	Door	Door
127	0.2 mg/cm2	Negative	3/7/2023	12:50:12	Lead Paint	202301331	Interior	1-e	Metal	Gray	Intact	A	Center	Door	L casing
128	0.2 mg/cm2	Negative	3/7/2023	12:50:24	Lead Paint	202301331	Interior	1-e	Metal	Gray	Intact	A	Center	Door	L Jamb
129	0.2 mg/cm2	Negative	3/7/2023	12:50:58	Lead Paint	202301331	Interior	1-e	Plaster	White	Intact	A	Center	Room	Ceiling
130	0.2 mg/cm2	Negative	3/7/2023	12:51:50	Lead Paint	202301331	Interior	1-e	Wood	Gray	Intact	B	Center	Stairs	Riser
131	0.1 mg/cm2	Negative	3/7/2023	12:52:02	Lead Paint	202301331	Interior	1-e	Wood	Gray	Intact	B	Center	Stairs	Tread
132	0.2 mg/cm2	Negative	3/7/2023	12:52:25	Lead Paint	202301331	Interior	1-e	Wood	Gray	Intact	B	Center	Stairs	post
133	0.2 mg/cm2	Negative	3/7/2023	12:52:43	Lead Paint	202301331	Interior	1-e	Wood	Stained	Intact	B	Center	Stairs	post
134	3.9 mg/cm2	Positive	3/7/2023	12:54:57	Lead Paint	202301331	Interior	1-f	Plaster	White	Intact	A	Center	Room	Wall
135	1.9 mg/cm2	Positive	3/7/2023	12:55:12	Lead Paint	202301331	Interior	1-f	Plaster	White	Intact	B	Center	Room	Wall
136	6.6 mg/cm2	Positive	3/7/2023	12:55:29	Lead Paint	202301331	Interior	1-f	Plaster	White	Intact	C	Center	Room	Wall
137	4.2 mg/cm2	Positive	3/7/2023	12:55:47	Lead Paint	202301331	Interior	1-f	Plaster	White	Intact	D	Center	Room	Wall
138	3.6 mg/cm2	Positive	3/7/2023	12:56:11	Lead Paint	202301331	Interior	1-f	Plaster	Gray	Intact	D	Center	Room	Baseboard
139	0.4 mg/cm2	Negative	3/7/2023	12:56:32	Lead Paint	202301331	Interior	1-f	Vinyl	Offwhite	Intact	D	Center	Room	Floor
140	1 mg/cm2	Positive	3/7/2023	12:57:22	Lead Paint	202301331	Interior	1-f	Wood	Offwhite	Intact	A	Center	Room	Cabinet
141	0.2 mg/cm2	Negative	3/7/2023	12:57:47	Lead Paint	202301331	Interior	1-f	Wood	Offwhite	Intact	A	Center	Room	Cabinet door
142	3.2 mg/cm2	Positive	3/7/2023	12:59:20	Lead Paint	202301331	Interior	1-f	Wood	Offwhite	Intact	B	Center	Room	desk
143	0.5 mg/cm2	Negative	3/7/2023	12:59:45	Lead Paint	202301331	Interior	1-f	Metal	Gray	Intact	B	Center	Room	desk

144	0.4 mg/cm2	Negative	3/7/2023	13:00:12	Lead Paint	202301331	Interior	1-f	Wood	Gray	Intact	B	Center	Room	frame
145	1 mg/cm2	Positive	3/7/2023	13:00:24	Lead Paint	202301331	Interior	1-f	Wood	Gray	Intact	B	Center	Room	bulletin board
146	8.7 mg/cm2	Positive	3/7/2023	13:00:52	Lead Paint	202301331	Interior	1-f	Wood	Offwhite	Intact	B	Center	Room	panel
147	1.4 mg/cm2	Positive	3/7/2023	13:01:17	Lead Paint	202301331	Interior	1-f	Wood	Offwhite	Intact	B	Center	Room	counter
148	4.3 mg/cm2	Positive	3/7/2023	13:01:56	Lead Paint	202301331	Interior	1-f	Plaster	Green	Intact	B	Center	Room	counter
149	0.6 mg/cm2	Negative	3/7/2023	13:02:15	Lead Paint	202301331	Interior	1-f	Metal	Green	Intact	B	Center	Room	conduit
150	0.6 mg/cm2	Negative	3/7/2023	13:02:29	Lead Paint	202301331	Interior	1-f	Metal	Offwhite	Intact	B	Center	Room	conduit
151	0.3 mg/cm2	Negative	3/7/2023	13:03:25	Lead Paint	202301331	Interior	1-f	Wood	Offwhite	Intact	B	Center	Room	Cabinet
152	0.3 mg/cm2	Negative	3/7/2023	13:04:04	Lead Paint	202301331	Interior	1-f	Plaster	Offwhite	Intact	B	Center	Room	Ceiling
153	0.3 mg/cm2	Negative	3/7/2023	13:04:46	Lead Paint	202301331	Interior	1-f	Wood	White	Intact	A	Center	Door	R Casing
154	0.3 mg/cm2	Negative	3/7/2023	13:05:07	Lead Paint	202301331	Interior	1-f	Wood	Gray	Intact	A	Center	Door	R Jamb
155	0.1 mg/cm2	Negative	3/7/2023	13:06:42	Lead Paint	202301331	Interior	1-g	Concrete	White	Intact	A	Center	Room	Wall
156	0.3 mg/cm2	Negative	3/7/2023	13:07:02	Lead Paint	202301331	Interior	1-g	Concrete	White	Intact	B	Center	Room	Wall
157	0 mg/cm2	Negative	3/7/2023	13:07:35	Lead Paint	202301331	Interior	1-g	Concrete	White	Intact	B	Center	Room	Shelf
158	0.1 mg/cm2	Negative	3/7/2023	13:07:47	Lead Paint	202301331	Interior	1-g	Concrete	White	Intact	B	Center	Room	Shelf Support
159	0.4 mg/cm2	Negative	3/7/2023	13:08:38	Lead Paint	202301331	Interior	1-g	Wood	Brown	Intact	B	Center	Room	Baseboard
160	0 mg/cm2	Negative	3/7/2023	13:09:17	Lead Paint	202301331	Interior	1-g	Wood	White	Intact	D	Center	Door	Door
161	0.2 mg/cm2	Negative	3/7/2023	13:09:36	Lead Paint	202301331	Interior	1-g	Wood	White	Intact	D	Center	Door	R Casing
162	0.2 mg/cm2	Negative	3/7/2023	13:09:51	Lead Paint	202301331	Interior	1-g	Wood	White	Intact	D	Center	Door	R Jamb
163	0.3 mg/cm2	Negative	3/7/2023	13:11:08	Lead Paint	202301331	Interior	1-h	Wood	White	Intact	A	Center	Room	Wall
164	0.3 mg/cm2	Negative	3/7/2023	13:11:36	Lead Paint	202301331	Interior	1-h	Wood	White	Intact	B	Center	Room	Wall
165	0.2 mg/cm2	Negative	3/7/2023	13:12:02	Lead Paint	202301331	Interior	1-h	Concrete	White	Intact	C	Center	Room	Wall
166	0.3 mg/cm2	Negative	3/7/2023	13:12:17	Lead Paint	202301331	Interior	1-h	Concrete	White	Intact	D	Center	Room	Wall
167	1.6 mg/cm2	Positive	3/7/2023	13:12:43	Lead Paint	202301331	Interior	1-h	Wood	White	Intact	A	Center	Room	Cabinet
168	1.1 mg/cm2	Positive	3/7/2023	13:12:55	Lead Paint	202301331	Interior	1-h	Wood	White	Intact	A	Center	Room	Cabinet door
169	0.9 mg/cm2	Negative	3/7/2023	13:13:51	Lead Paint	202301331	Interior	1-h	Metal	White	Intact	C	Center	Window	Part Bead
170	1.1 mg/cm2	Positive	3/7/2023	13:14:52	Lead Paint	202301331	Interior	1-h	Wood	White	Intact	B	Center	Door	Door
171	0.7 mg/cm2	Negative	3/7/2023	13:15:12	Lead Paint	202301331	Interior	1-h	Wood	White	Intact	B	Center	Door	L casing
172	0.9 mg/cm2	Negative	3/7/2023	13:15:29	Lead Paint	202301331	Interior	1-h	Wood	White	Intact	B	Center	Door	L Jamb
173	1.3 mg/cm2	Positive	3/7/2023	13:15:58	Lead Paint	202301331	Interior	1-h	Wood	White	Intact	B	Center	Room	Ceiling
174	0.3 mg/cm2	Negative	3/7/2023	13:16:24	Lead Paint	202301331	Interior	1-h	Metal	White	Intact	B	Center	Room	conduit
175	1.6 mg/cm2	Positive	3/7/2023	13:16:49	Lead Paint	202301331	Interior	1-h	Concrete	Gray	Intact	B	Center	Room	Floor
176	0.4 mg/cm2	Negative	3/7/2023	13:18:13	Lead Paint	202301331	Interior	1-j	Concrete	White	Intact	A	Center	Room	Wall
177	0.4 mg/cm2	Negative	3/7/2023	13:18:30	Lead Paint	202301331	Interior	1-j	Concrete	White	Intact	B	Center	Room	Wall
178	0.4 mg/cm2	Negative	3/7/2023	13:18:54	Lead Paint	202301331	Interior	1-j	Concrete	White	Intact	C	Center	Room	Wall
179	0.7 mg/cm2	Negative	3/7/2023	13:19:26	Lead Paint	202301331	Interior	1-j	Wood	White	Intact	D	Center	Room	Wall
180	0.4 mg/cm2	Negative	3/7/2023	13:20:02	Lead Paint	202301331	Interior	1-j	Concrete	White	Intact	C	Center	Room	Ceiling
181	0.5 mg/cm2	Negative	3/7/2023	13:20:23	Lead Paint	202301331	Interior	1-j	Concrete	Gray	Intact	C	Center	Room	Floor
182	0.2 mg/cm2	Negative	3/7/2023	13:20:58	Lead Paint	202301331	Interior	1-j	Wood	Brown	Intact	A	Right	Door	Door
183	0.1 mg/cm2	Negative	3/7/2023	13:21:19	Lead Paint	202301331	Interior	1-j	Wood	White	Intact	A	Right	Door	L casing
184	0.2 mg/cm2	Negative	3/7/2023	13:21:32	Lead Paint	202301331	Interior	1-j	Wood	White	Intact	A	Right	Door	L Jamb
185	1.5 mg/cm2	Positive	3/7/2023	13:22:15	Lead Paint	202301331	Interior	1-j	Wood	White	Intact	C	Center	Door	Door
186	1.4 mg/cm2	Positive	3/7/2023	13:22:30	Lead Paint	202301331	Interior	1-j	Wood	White	Intact	C	Center	Door	L casing
187	0.2 mg/cm2	Negative	3/7/2023	13:23:03	Lead Paint	202301331	Interior	1-j	Wood	Gray	Intact	C	Center	Door	bar
188	0.3 mg/cm2	Negative	3/7/2023	13:23:37	Lead Paint	202301331	Interior	1-j	Wood	Gray	Intact	C	Center	Room	workbench
189	1.2 mg/cm2	Positive	3/7/2023	13:23:52	Lead Paint	202301331	Interior	1-j	Wood	White	Intact	C	Center	Room	workbench
190	0.3 mg/cm2	Negative	3/7/2023	13:24:40	Lead Paint	202301331	Interior	1-j	Wood	White	Intact	D	Center	Door	Door
191	0.3 mg/cm2	Negative	3/7/2023	13:25:00	Lead Paint	202301331	Interior	1-j	Wood	White	Intact	D	Center	Door	L casing
192	0.3 mg/cm2	Negative	3/7/2023	13:25:14	Lead Paint	202301331	Interior	1-j	Wood	White	Intact	D	Center	Door	L Jamb
193	0.2 mg/cm2	Negative	3/7/2023	13:25:40	Lead Paint	202301331	Interior	1-j	Wood	Gray	Intact	D	Center	Room	Floor

194	0.3 mg/cm2	Negative	3/7/2023	13:25:56	Lead Paint	202301331	Interior	1-j	Wood	Gray	Intact	C	Center	Room	Floor
195	0.4 mg/cm2	Negative	3/7/2023	13:27:00	Lead Paint	202301331	Interior	1-i	Concrete	White	Intact	A	Center	Room	Wall
196	0.3 mg/cm2	Negative	3/7/2023	13:27:16	Lead Paint	202301331	Interior	1-i	Drywall	White	Intact	B	Center	Room	Wall
197	0.3 mg/cm2	Negative	3/7/2023	13:27:32	Lead Paint	202301331	Interior	1-i	Drywall	White	Intact	C	Center	Room	Wall
198	0.3 mg/cm2	Negative	3/7/2023	13:27:46	Lead Paint	202301331	Interior	1-i	Drywall	White	Intact	D	Center	Room	Wall
199	0.1 mg/cm2	Negative	3/7/2023	13:28:03	Lead Paint	202301331	Interior	1-i	Drywall	White	Intact	D	Center	Room	Ceiling
200	0.2 mg/cm2	Negative	3/7/2023	13:28:27	Lead Paint	202301331	Interior	1-i	Vinyl	Offwhite	Intact	D	Center	Room	Floor
201	0.1 mg/cm2	Negative	3/7/2023	13:29:12	Lead Paint	202301331	Interior	1-i	Wood	Stained	Intact	D	Center	Room	Cabinet
202	0.3 mg/cm2	Negative	3/7/2023	13:29:25	Lead Paint	202301331	Interior	1-i	Wood	Stained	Intact	D	Center	Room	Cabinet door
203	0.1 mg/cm2	Negative	3/7/2023	13:29:56	Lead Paint	202301331	Interior	1-i	Wood	White	Intact	B	Center	Door	R Casing
204	0.2 mg/cm2	Negative	3/7/2023	13:30:08	Lead Paint	202301331	Interior	1-i	Wood	White	Intact	B	Center	Door	R Jamb
205	0.2 mg/cm2	Negative	3/7/2023	13:31:24	Lead Paint	202301331	Interior	1-k	Wood	White	Intact	B	Center	Room	workbench
206	0.1 mg/cm2	Negative	3/7/2023	13:31:48	Lead Paint	202301331	Interior	1-k	Wood	Stained	Intact	B	Center	Room	workbench
207	0.2 mg/cm2	Negative	3/7/2023	13:32:32	Lead Paint	202301331	Interior	1-k	Concrete	Blue	Intact	A	Center	Room	post
208	0.3 mg/cm2	Negative	3/7/2023	13:33:03	Lead Paint	202301331	Interior	1-k	Wood	Tan	Intact	A	Center	Room	Shelf
209	0.4 mg/cm2	Negative	3/7/2023	13:33:38	Lead Paint	202301331	Interior	1-k	Concrete	Gray	Intact	A	Center	Room	Floor
210	0.3 mg/cm2	Negative	3/7/2023	13:40:42	Lead Paint	202301331	Interior	1-m	Concrete	White	Intact	A	Center	Room	Wall
211	0.3 mg/cm2	Negative	3/7/2023	13:40:58	Lead Paint	202301331	Interior	1-m	Drywall	White	Intact	A	Center	Room	Wall
212	0.2 mg/cm2	Negative	3/7/2023	13:41:17	Lead Paint	202301331	Interior	1-m	Drywall	Brown	Intact	B	Center	Room	Wall
213	0.2 mg/cm2	Negative	3/7/2023	13:41:51	Lead Paint	202301331	Interior	1-m	Plaster	Brown	Intact	B	Center	Room	Wall
214	0.3 mg/cm2	Negative	3/7/2023	13:42:19	Lead Paint	202301331	Interior	1-m	Plaster	White	Intact	D	Center	Room	Wall
215	0.2 mg/cm2	Negative	3/7/2023	13:43:09	Lead Paint	202301331	Interior	1-m	Plaster	White	Intact	B	Center	Room	Baseboard
216	0.3 mg/cm2	Negative	3/7/2023	13:43:39	Lead Paint	202301331	Interior	1-m	Wood	White	Intact	A	Center	Door	Door
217	0 mg/cm2	Negative	3/7/2023	13:44:02	Lead Paint	202301331	Interior	1-m	Wood	White	Intact	A	Center	Door	R Casing
218	0.1 mg/cm2	Negative	3/7/2023	13:44:14	Lead Paint	202301331	Interior	1-m	Wood	White	Intact	A	Center	Door	R Jamb
219	0.3 mg/cm2	Negative	3/7/2023	13:45:50	Lead Paint	202301331	Interior	1-l	Plaster	White	Intact	A	Center	Room	Wall
220	0.3 mg/cm2	Negative	3/7/2023	13:47:32	Lead Paint	202301331	Interior	1-l	Plaster	White	Intact	B	Center	Room	Wall
221	0.3 mg/cm2	Negative	3/7/2023	13:47:54	Lead Paint	202301331	Interior	1-l	Drywall	White	Intact	B	Center	Room	Wall
222	0.2 mg/cm2	Negative	3/7/2023	13:48:26	Lead Paint	202301331	Interior	1-l	Drywall	White	Intact	C	Center	Room	Wall
223	1.4 mg/cm2	Positive	3/7/2023	13:49:01	Lead Paint	202301331	Interior	1-l	Plaster	White	Intact	D	Center	Room	Wall
224	0.7 mg/cm2	Negative	3/7/2023	13:49:49	Lead Paint	202301331	Interior	1-l	Plaster	Offwhite	Intact	D	Center	Room	Ceiling
225	0.3 mg/cm2	Negative	3/7/2023	13:50:10	Lead Paint	202301331	Interior	1-l	Plaster	Offwhite	Intact	D	Center	Room	Baseboard
226	0.1 mg/cm2	Negative	3/7/2023	13:50:31	Lead Paint	202301331	Interior	1-l	Vinyl	Offwhite	Intact	D	Center	Room	Floor
227	0.4 mg/cm2	Negative	3/7/2023	13:51:49	Lead Paint	202301331	Interior	1-l	Metal	Offwhite	Intact	D	Center	Window	L Casing
228	0.4 mg/cm2	Negative	3/7/2023	13:52:05	Lead Paint	202301331	Interior	1-l	Metal	Offwhite	Intact	D	Center	Window	Sash
229	0.1 mg/cm2	Negative	3/7/2023	13:52:49	Lead Paint	202301331	Interior	1-l	Wood	Gray	Intact	A	Center	Door	Door
230	0.2 mg/cm2	Negative	3/7/2023	13:53:10	Lead Paint	202301331	Interior	1-l	Metal	Gray	Intact	A	Center	Door	L casing
231	0.3 mg/cm2	Negative	3/7/2023	13:53:28	Lead Paint	202301331	Interior	1-l	Metal	Gray	Intact	A	Center	Door	L Jamb
232	0.3 mg/cm2	Negative	3/7/2023	13:54:46	Lead Paint	202301331	Interior	1-l	Wood	White	Intact	B	Left	Closet	Door
233	0.2 mg/cm2	Negative	3/7/2023	13:55:06	Lead Paint	202301331	Interior	1-l	Wood	White	Intact	B	Left	Closet	Shelf
234	0.3 mg/cm2	Negative	3/7/2023	13:55:18	Lead Paint	202301331	Interior	1-l	Wood	White	Intact	B	Left	Closet	Shelf Support
235	0.1 mg/cm2	Negative	3/7/2023	13:55:55	Lead Paint	202301331	Interior	1-l	Wood	Gray	Intact	B	Left	Door	Door
236	0.4 mg/cm2	Negative	3/7/2023	13:56:13	Lead Paint	202301331	Interior	1-l	Wood	White	Intact	B	Left	Door	R Casing
237	0.4 mg/cm2	Negative	3/7/2023	13:56:49	Lead Paint	202301331	Interior	1-l	Wood	White	Intact	B	Left	Door	R Jamb
238	0.4 mg/cm2	Negative	3/7/2023	13:57:14	Lead Paint	202301331	Interior	1-l	Metal	White	Intact	B	Center	Room	conduit
239	0.2 mg/cm2	Negative	3/7/2023	13:58:07	Lead Paint	202301331	Interior	1-l	Metal	Gray	Intact	B	Right	Door	Door
240	0.5 mg/cm2	Negative	3/7/2023	13:58:27	Lead Paint	202301331	Interior	1-l	Metal	White	Intact	B	Right	Door	L casing
241	0.1 mg/cm2	Negative	3/7/2023	13:58:39	Lead Paint	202301331	Interior	1-l	Metal	White	Intact	B	Right	Door	L Jamb
242	0.1 mg/cm2	Negative	3/7/2023	14:00:20	Lead Paint	202301331	Interior	1-n	Plaster	White	Intact	A	Center	Room	Wall
243	0.3 mg/cm2	Negative	3/7/2023	14:00:45	Lead Paint	202301331	Interior	1-n	Drywall	White	Intact	B	Center	Room	Wall

244	0.5 mg/cm2	Negative	3/7/2023	14:01:06	Lead Paint	202301331	Interior	1-n	Plaster	White	Intact	C	Center	Room	Wall
245	0.3 mg/cm2	Negative	3/7/2023	14:01:29	Lead Paint	202301331	Interior	1-n	Plaster	Yellow	Intact	D	Center	Room	Wall
246	0.5 mg/cm2	Negative	3/7/2023	14:02:05	Lead Paint	202301331	Interior	1-n	Plaster	White	Intact	D	Center	Room	Ceiling
247	0.3 mg/cm2	Negative	3/7/2023	14:02:45	Lead Paint	202301331	Interior	1-n	Vinyl	Tan	Intact	D	Center	Room	Floor
248	11 mg/cm2	Positive	3/7/2023	14:03:13	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	B	Center	Room	Cabinet
249	7.8 mg/cm2	Positive	3/7/2023	14:03:27	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	B	Center	Room	Cabinet door
250	0.2 mg/cm2	Negative	3/7/2023	14:04:04	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	D	Center	Room	Chair Rail
251	5.4 mg/cm2	Positive	3/7/2023	14:04:31	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	D	Center	Room	Baseboard
252	7.7 mg/cm2	Positive	3/7/2023	14:05:34	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	C	Center	Window	L Casing
253	7 mg/cm2	Positive	3/7/2023	14:05:48	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	C	Center	Window	Sill
254	6.1 mg/cm2	Positive	3/7/2023	14:06:09	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	C	Center	Window	Sash
255	7.4 mg/cm2	Positive	3/7/2023	14:06:46	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	B	Left	Door	Door
256	7.3 mg/cm2	Positive	3/7/2023	14:06:59	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	B	Left	Door	L casing
257	9.4 mg/cm2	Positive	3/7/2023	14:07:12	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	B	Left	Door	L Jamb
258	7.1 mg/cm2	Positive	3/7/2023	14:07:59	Lead Paint	202301331	Interior	1-n	Wood	Gray	Intact	B	Right	Closet	Door
259	0.1 mg/cm2	Negative	3/7/2023	14:08:29	Lead Paint	202301331	Interior	1-n	Wood	Stained	Intact	B	Right	Closet	Shelf
260	0.1 mg/cm2	Negative	3/7/2023	14:08:41	Lead Paint	202301331	Interior	1-n	Wood	Stained	Intact	B	Right	Closet	Shelf Support
261	7.5 mg/cm2	Positive	3/7/2023	14:09:18	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	C	Center	Door	R Casing
262	8.7 mg/cm2	Positive	3/7/2023	14:09:30	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	C	Center	Door	R Jamb
263	8.1 mg/cm2	Positive	3/7/2023	14:09:56	Lead Paint	202301331	Interior	1-n	Wood	Gray	Intact	C	Center	Door	Door
264	8.9 mg/cm2	Positive	3/7/2023	14:10:15	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	C	Center	Door	R Casing
265	9 mg/cm2	Positive	3/7/2023	14:10:27	Lead Paint	202301331	Interior	1-n	Wood	White	Intact	C	Center	Door	R Jamb
266	7.4 mg/cm2	Positive	3/7/2023	14:11:46	Lead Paint	202301331	Interior	1-o	Plaster	Various	Intact	A	Center	Room	Wall
267	0.7 mg/cm2	Negative	3/7/2023	14:12:05	Lead Paint	202301331	Interior	1-o	Plaster	White	Intact	B	Center	Room	Wall
268	0.3 mg/cm2	Negative	3/7/2023	14:12:32	Lead Paint	202301331	Interior	1-o	Plaster	Various	Intact	C	Center	Room	Wall
269	0.3 mg/cm2	Negative	3/7/2023	14:12:58	Lead Paint	202301331	Interior	1-o	Plaster	Various	Intact	D	Center	Room	Wall
270	1.7 mg/cm2	Positive	3/7/2023	14:13:47	Lead Paint	202301331	Interior	1-o	Concrete	Gray	Intact	D	Center	Room	Floor
271	11.6 mg/cm2	Positive	3/7/2023	14:14:16	Lead Paint	202301331	Interior	1-o	Wood	Gray	Intact	C	Center	Room	Wall
272	3.6 mg/cm2	Positive	3/7/2023	14:14:46	Lead Paint	202301331	Interior	1-o	Wood	Various	Intact	D	Center	Door	Door
273	6.6 mg/cm2	Positive	3/7/2023	14:15:07	Lead Paint	202301331	Interior	1-o	Wood	Gray	Intact	D	Center	Door	R Casing
274	7.1 mg/cm2	Positive	3/7/2023	14:15:19	Lead Paint	202301331	Interior	1-o	Wood	Gray	Intact	D	Center	Door	R Jamb
275	6.7 mg/cm2	Positive	3/7/2023	14:15:36	Lead Paint	202301331	Interior	1-o	Wood	Gray	Intact	C	Center	Door	Door
276	8.7 mg/cm2	Positive	3/7/2023	14:15:47	Lead Paint	202301331	Interior	1-o	Wood	Gray	Intact	C	Center	Door	L casing
277	6.5 mg/cm2	Positive	3/7/2023	14:15:59	Lead Paint	202301331	Interior	1-o	Wood	Gray	Intact	C	Center	Door	L Jamb
278	0.2 mg/cm2	Negative	3/7/2023	14:17:39	Lead Paint	202301331	Interior	1-p	Drywall	White	Intact	A	Center	Room	Wall
279	0.2 mg/cm2	Negative	3/7/2023	14:17:58	Lead Paint	202301331	Interior	1-p	Plaster	White	Intact	B	Center	Room	Wall
280	0.1 mg/cm2	Negative	3/7/2023	14:18:11	Lead Paint	202301331	Interior	1-p	Plaster	White	Intact	C	Center	Room	Wall
281	0.5 mg/cm2	Negative	3/7/2023	14:18:32	Lead Paint	202301331	Interior	1-p	Plaster	White	Intact	D	Center	Room	Wall
282	0.1 mg/cm2	Negative	3/7/2023	14:18:57	Lead Paint	202301331	Interior	1-p	Drywall	White	Intact	D	Center	Room	Ceiling
283	0.2 mg/cm2	Negative	3/7/2023	14:19:22	Lead Paint	202301331	Interior	1-p	Wood	Tan	Intact	A	Center	Room	Baseboard
284	0.1 mg/cm2	Negative	3/7/2023	14:20:14	Lead Paint	202301331	Interior	1-p	Wood	White	Intact	A	Left	Room	Shelf
285	0.1 mg/cm2	Negative	3/7/2023	14:20:50	Lead Paint	202301331	Interior	1-p	Wood	Gray	Intact	A	Center	Door	Door
286	0.2 mg/cm2	Negative	3/7/2023	14:21:07	Lead Paint	202301331	Interior	1-p	Wood	Gray	Intact	A	Center	Door	L casing
287	0.2 mg/cm2	Negative	3/7/2023	14:21:20	Lead Paint	202301331	Interior	1-p	Wood	Gray	Intact	A	Center	Door	L Jamb
288	0.2 mg/cm2	Negative	3/7/2023	14:21:46	Lead Paint	202301331	Interior	1-p	Wood	Gray	Intact	C	Center	Door	Door
289	0.2 mg/cm2	Negative	3/7/2023	14:22:00	Lead Paint	202301331	Interior	1-p	Wood	Gray	Intact	C	Center	Door	R Casing
290	0.1 mg/cm2	Negative	3/7/2023	14:22:12	Lead Paint	202301331	Interior	1-p	Wood	Gray	Intact	C	Center	Door	R Jamb
291	0.1 mg/cm2	Negative	3/7/2023	14:24:12	Lead Paint	202301331	Interior	1-q	Plaster	White	Intact	A	Center	Room	Wall
292	0.3 mg/cm2	Negative	3/7/2023	14:24:31	Lead Paint	202301331	Interior	1-q	Plaster	White	Intact	B	Center	Room	Wall
293	0.2 mg/cm2	Negative	3/7/2023	14:24:59	Lead Paint	202301331	Interior	1-q	Wood	White	Intact	C	Center	Room	Wall

294	0.4 mg/cm2	Negative	3/7/2023	14:25:36	Lead Paint	202301331	Interior	1-q	Wood	White	Intact	C	Center	Room	bulletin board
295	0.6 mg/cm2	Negative	3/7/2023	14:26:28	Lead Paint	202301331	Interior	1-q	Plaster	White	Intact	D	Center	Room	Wall
296	0.4 mg/cm2	Negative	3/7/2023	14:26:53	Lead Paint	202301331	Interior	1-q	Plaster	White	Intact	D	Center	Room	Ceiling
297	0.3 mg/cm2	Negative	3/7/2023	14:27:37	Lead Paint	202301331	Interior	1-q	Wood	White	Intact	C	Center	Window	Part Bead
298	0.2 mg/cm2	Negative	3/7/2023	14:28:23	Lead Paint	202301331	Interior	1-q	Wood	Gray	Intact	C	Center	Closet	Door Casing
299	0.4 mg/cm2	Negative	3/7/2023	14:28:42	Lead Paint	202301331	Interior	1-q	Plaster	White	Intact	C	Center	Closet	Wall
300	4.8 mg/cm2	Positive	3/7/2023	14:29:16	Lead Paint	202301331	Interior	1-q	Wood	Gray	Intact	D	Center	Closet	Door
301	0.3 mg/cm2	Negative	3/7/2023	14:29:50	Lead Paint	202301331	Interior	1-q	Wood	Gray	Intact	A	Center	Closet	Door Casing
302	0.1 mg/cm2	Negative	3/7/2023	14:30:10	Lead Paint	202301331	Interior	1-q	Wood	Stained	Intact	A	Center	Closet	Shelf
303	0.2 mg/cm2	Negative	3/7/2023	14:30:24	Lead Paint	202301331	Interior	1-q	Wood	Stained	Intact	A	Center	Closet	Shelf Support
304	0.2 mg/cm2	Negative	3/7/2023	14:31:12	Lead Paint	202301331	Interior	1-q	Wood	Gray	Intact	B	Center	Door	Door
305	0.2 mg/cm2	Negative	3/7/2023	14:31:26	Lead Paint	202301331	Interior	1-q	Wood	Gray	Intact	B	Center	Door	L casing
306	0.2 mg/cm2	Negative	3/7/2023	14:31:39	Lead Paint	202301331	Interior	1-q	Wood	Gray	Intact	B	Center	Door	L Jamb
307	0.2 mg/cm2	Negative	3/7/2023	14:32:00	Lead Paint	202301331	Interior	1-q	Wood	Gray	Intact	C	Center	Door	Door
308	0.1 mg/cm2	Negative	3/7/2023	14:32:12	Lead Paint	202301331	Interior	1-q	Wood	Gray	Intact	C	Center	Door	R Casing
309	0.2 mg/cm2	Negative	3/7/2023	14:32:25	Lead Paint	202301331	Interior	1-q	Wood	Gray	Intact	C	Center	Door	R Jamb
310	4.7 mg/cm2	Positive	3/7/2023	14:33:57	Lead Paint	202301331	Interior	1-r	Wood	Gray	Intact	C	Center	Stairs	Riser
311	1.1 mg/cm2	Positive	3/7/2023	14:34:09	Lead Paint	202301331	Interior	1-r	Wood	Gray	Intact	C	Center	Stairs	Tread
312	0.4 mg/cm2	Negative	3/7/2023	14:35:08	Lead Paint	202301331	Interior	1-r	Wood	Gray	Intact	D	Center	Door	Door
313	0.3 mg/cm2	Negative	3/7/2023	14:35:28	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	D	Center	Door	R Casing
314	0.3 mg/cm2	Negative	3/7/2023	14:35:41	Lead Paint	202301331	Interior	1-r	Metal	Gray	Intact	D	Center	Door	R Jamb
315	0.9 mg/cm2	Negative	3/7/2023	15:24:23	Lead Paint	202301331	Calibration								
316	0.8 mg/cm2	Negative	3/7/2023	15:24:40	Lead Paint	202301331	Calibration								
317	0.9 mg/cm2	Negative	3/7/2023	15:24:56	Lead Paint	202301331	Calibration								
318	0 mg/cm2	Negative	3/7/2023	15:25:13	Lead Paint	202301331	Calibration								
319	0 mg/cm2	Negative	3/7/2023	15:25:20	Lead Paint	202301331	Calibration								
320	0.1 mg/cm2	Negative	3/7/2023	15:25:27	Lead Paint	202301331	Calibration								
321	0.4 mg/cm2	Negative	3/7/2023	15:29:19	Lead Paint	202301331	Interior	2-a	Plaster	White	Intact	A	Center	Room	Wall
322	0.6 mg/cm2	Negative	3/7/2023	15:29:33	Lead Paint	202301331	Interior	2-a	Plaster	White	Intact	B	Center	Room	Wall
323	0.2 mg/cm2	Negative	3/7/2023	15:29:51	Lead Paint	202301331	Interior	2-a	Plaster	White	Intact	C	Center	Room	Wall
324	0.6 mg/cm2	Negative	3/7/2023	15:30:09	Lead Paint	202301331	Interior	2-a	Plaster	White	Intact	D	Center	Room	Wall
325	0.5 mg/cm2	Negative	3/7/2023	15:31:05	Lead Paint	202301331	Interior	2-a	Wood	White	Intact	A	Center	Room	Wall
326	0.6 mg/cm2	Negative	3/7/2023	15:31:36	Lead Paint	202301331	Interior	2-a	Wood	White	Intact	A	Center	Room	bulletin board
327	0.3 mg/cm2	Negative	3/7/2023	15:32:05	Lead Paint	202301331	Interior	2-a	Wood	White	Intact	A	Center	Room	Shelf
328	0.4 mg/cm2	Negative	3/7/2023	15:32:17	Lead Paint	202301331	Interior	2-a	Wood	White	Intact	A	Center	Room	Shelf Support
329	0.3 mg/cm2	Negative	3/7/2023	15:32:37	Lead Paint	202301331	Interior	2-a	Wood	White	Intact	C	Center	Room	Wall
330	0.3 mg/cm2	Negative	3/7/2023	15:33:22	Lead Paint	202301331	Interior	2-a	Wood	White	Intact	C	Center	Room	Ceiling
331	0.4 mg/cm2	Negative	3/7/2023	15:33:47	Lead Paint	202301331	Interior	2-a	Plaster	White	Intact	B	Center	Room	Baseboard
332	0.2 mg/cm2	Negative	3/7/2023	15:34:06	Lead Paint	202301331	Interior	2-a	Wood	Stained	Intact	B	Center	Room	Floor
333	0.6 mg/cm2	Negative	3/7/2023	15:34:38	Lead Paint	202301331	Interior	2-a	Wood	White	Intact	B	Center	Room	frame
334	0.3 mg/cm2	Negative	3/7/2023	15:34:52	Lead Paint	202301331	Interior	2-a	Wood	White	Intact	B	Center	Room	Shelf
335	0.3 mg/cm2	Negative	3/7/2023	15:35:32	Lead Paint	202301331	Interior	2-a	stone	Black	Intact	B	Center	Room	blackboard
336	0.1 mg/cm2	Negative	3/7/2023	15:36:37	Lead Paint	202301331	Interior	2-a	Wood	White	Intact	B	Center	Window	L Casing
337	0.2 mg/cm2	Negative	3/7/2023	15:37:02	Lead Paint	202301331	Interior	2-a	Wood	White	Intact	B	Center	Closet	Door
338	0.1 mg/cm2	Negative	3/7/2023	15:37:38	Lead Paint	202301331	Interior	2-a	Wood	Stained	Intact	C	Center	Closet	Shelf
339	0.1 mg/cm2	Negative	3/7/2023	15:39:33	Lead Paint	202301331	Interior	2-a	Wood	Stained	Intact	C	Center	Closet	Shelf
340	0.2 mg/cm2	Negative	3/7/2023	15:39:46	Lead Paint	202301331	Interior	2-a	Wood	Stained	Intact	C	Center	Closet	Shelf Support
341	0.3 mg/cm2	Negative	3/7/2023	15:40:12	Lead Paint	202301331	Interior	2-a	Wood	Stained	Intact	C	Center	Room	Cabinet
342	0.5 mg/cm2	Negative	3/7/2023	15:40:48	Lead Paint	202301331	Interior	2-a	Wood	Gray	Intact	D	Center	Door	Door
343	0.4 mg/cm2	Negative	3/7/2023	15:41:12	Lead Paint	202301331	Interior	2-a	Wood	White	Intact	D	Center	Door	L casing

344	0.5 mg/cm2	Negative	3/7/2023	15:41:24	Lead Paint	202301331	Interior	2-a	Wood	White	Intact	D	Center	Door	L Jamb
345	0.2 mg/cm2	Negative	3/7/2023	15:58:19	Lead Paint	202301331	Interior	2-a	Metal	White	Intact	C	Center	Room	vent
346	0.2 mg/cm2	Negative	3/7/2023	15:58:47	Lead Paint	202301331	Interior	2-a	Drywall	White	Intact	C	Center	Room	Ceiling
347	0.2 mg/cm2	Negative	3/7/2023	16:00:21	Lead Paint	202301331	Interior	2-b	Drywall	White	Intact	C	Center	Room	Wall
348	0.2 mg/cm2	Negative	3/7/2023	16:00:37	Lead Paint	202301331	Interior	2-b	Plaster	White	Intact	C	Center	Room	Wall
349	0.5 mg/cm2	Negative	3/7/2023	16:00:55	Lead Paint	202301331	Interior	2-b	Plaster	White	Intact	C	Center	Room	Wall
350	0.6 mg/cm2	Negative	3/7/2023	16:01:14	Lead Paint	202301331	Interior	2-b	Plaster	White	Intact	D	Center	Room	Wall
351	0.5 mg/cm2	Negative	3/7/2023	16:02:05	Lead Paint	202301331	Interior	2-b	Plaster	White	Intact	D	Center	Room	Ceiling
352	0.2 mg/cm2	Negative	3/7/2023	16:02:55	Lead Paint	202301331	Interior	2-b	Metal	White	Intact	C	Center	Room	vent
353	0.6 mg/cm2	Negative	3/7/2023	16:03:23	Lead Paint	202301331	Interior	2-b	Wood	White	Intact	C	Center	Room	Baseboard
354	0.3 mg/cm2	Negative	3/7/2023	16:03:44	Lead Paint	202301331	Interior	2-b	Wood	Stained	Intact	C	Center	Room	Floor
355	0.5 mg/cm2	Negative	3/7/2023	16:04:28	Lead Paint	202301331	Interior	2-b	Wood	White	Intact	B	Center	Room	frame
356	0.4 mg/cm2	Negative	3/7/2023	16:05:14	Lead Paint	202301331	Interior	2-b	stone	Black	Intact	B	Center	Room	chalkboard
357	0.4 mg/cm2	Negative	3/7/2023	16:06:04	Lead Paint	202301331	Interior	2-b	Wood	Gray	Intact	D	Center	Door	Door
358	0.4 mg/cm2	Negative	3/7/2023	16:06:22	Lead Paint	202301331	Interior	2-b	Wood	White	Intact	D	Center	Door	R Casing
359	0.2 mg/cm2	Negative	3/7/2023	16:06:34	Lead Paint	202301331	Interior	2-b	Wood	White	Intact	D	Center	Door	R Jamb
360	0.3 mg/cm2	Negative	3/7/2023	16:07:03	Lead Paint	202301331	Interior	2-b	Wood	White	Intact	A	Center	Closet	Door
361	0.2 mg/cm2	Negative	3/7/2023	16:07:25	Lead Paint	202301331	Interior	2-b	Wood	White	Intact	A	Center	Closet	Shelf
362	0.3 mg/cm2	Negative	3/7/2023	16:07:37	Lead Paint	202301331	Interior	2-b	Wood	White	Intact	A	Center	Closet	Shelf Support
363	5.1 mg/cm2	Positive	3/7/2023	16:08:44	Lead Paint	202301331	Interior	2-c	Plaster	White	Intact	A	Center	Room	Wall
364	1.3 mg/cm2	Positive	3/7/2023	16:09:02	Lead Paint	202301331	Interior	2-c	Plaster	White	Intact	B	Center	Room	Wall
365	3.2 mg/cm2	Positive	3/7/2023	16:09:18	Lead Paint	202301331	Interior	2-c	Plaster	White	Intact	C	Center	Room	Wall
366	0.3 mg/cm2	Negative	3/7/2023	16:09:33	Lead Paint	202301331	Interior	2-c	Plaster	White	Intact	D	Center	Room	Wall
367	0.9 mg/cm2	Negative	3/7/2023	16:09:58	Lead Paint	202301331	Interior	2-c	Plaster	White	Intact	D	Center	Room	Ceiling
368	0.6 mg/cm2	Negative	3/7/2023	16:11:01	Lead Paint	202301331	Interior	2-c	Plaster	Gray	Intact	D	Center	Railing	Railing
369	3.1 mg/cm2	Positive	3/7/2023	16:11:26	Lead Paint	202301331	Interior	2-c	Plaster	Gray	Intact	B	Center	Room	Baseboard
370	0.2 mg/cm2	Negative	3/7/2023	16:12:17	Lead Paint	202301331	Interior	2-c	Metal	Gray	Intact	C	Center	Door	Door
371	0.5 mg/cm2	Negative	3/7/2023	16:12:43	Lead Paint	202301331	Interior	2-c	Metal	Gray	Intact	C	Center	Door	L casing
372	0.5 mg/cm2	Negative	3/7/2023	16:12:57	Lead Paint	202301331	Interior	2-c	Metal	Gray	Intact	C	Center	Door	L Jamb
373	1.1 mg/cm2	Positive	3/7/2023	16:13:47	Lead Paint	202301331	Interior	2-c	Wood	Gray	Intact	D	Center	Door	Door
374	0.7 mg/cm2	Negative	3/7/2023	16:14:07	Lead Paint	202301331	Interior	2-c	Wood	Gray	Intact	D	Center	Door	R Casing
375	0.6 mg/cm2	Negative	3/7/2023	16:14:25	Lead Paint	202301331	Interior	2-c	Wood	Gray	Intact	D	Center	Door	R Jamb
376	0.2 mg/cm2	Negative	3/7/2023	16:15:05	Lead Paint	202301331	Interior	2-c	Metal	White	Intact	D	Center	Railing	Railing
377	7.4 mg/cm2	Positive	3/7/2023	16:15:41	Lead Paint	202301331	Interior	2-c	Concrete	Gray	Intact	D	Center	Stairs	Riser
378	0.7 mg/cm2	Negative	3/7/2023	16:15:58	Lead Paint	202301331	Interior	2-c	Concrete	Gray	Intact	D	Center	Stairs	Tread
379	10.3 mg/cm2	Positive	3/7/2023	16:17:42	Lead Paint	202301331	Interior	2-d	Plaster	Offwhite	Intact	A	Center	Room	Wall
380	0.2 mg/cm2	Negative	3/7/2023	16:17:54	Lead Paint	202301331	Interior	2-d	Plaster	Offwhite	Intact	B	Center	Room	Wall
381	7.9 mg/cm2	Positive	3/7/2023	16:18:21	Lead Paint	202301331	Interior	2-d	Plaster	Offwhite	Intact	C	Center	Room	Wall
382	0.2 mg/cm2	Negative	3/7/2023	16:18:39	Lead Paint	202301331	Interior	2-d	Plaster	Offwhite	Intact	D	Center	Room	Wall
383	11.3 mg/cm2	Positive	3/7/2023	16:18:58	Lead Paint	202301331	Interior	2-d	Plaster	Offwhite	Intact	D	Center	Room	Ceiling
384	1.7 mg/cm2	Positive	3/7/2023	16:20:07	Lead Paint	202301331	Interior	2-d	Tile	Offwhite	Intact	A	Center	Room	Baseboard
385	0.1 mg/cm2	Negative	3/7/2023	16:20:27	Lead Paint	202301331	Interior	2-d	Ceramic	Offwhite	Intact	A	Center	Room	Floor
386	1.7 mg/cm2	Positive	3/7/2023	16:20:46	Lead Paint	202301331	Interior	2-d	Concrete	Gray	Intact	A	Center	Room	Floor
387	0.9 mg/cm2	Negative	3/7/2023	16:21:39	Lead Paint	202301331	Interior	2-d	Wood	White	Intact	D	Center	Room	stall
388	0.1 mg/cm2	Negative	3/7/2023	16:22:18	Lead Paint	202301331	Interior	2-d	Wood	White	Intact	D	Center	Door	Door
389	15.7 mg/cm2	Positive	3/7/2023	16:22:40	Lead Paint	202301331	Interior	2-d	Wood	White	Intact	D	Center	Room	Chair Rail
390	17.5 mg/cm2	Positive	3/7/2023	16:22:59	Lead Paint	202301331	Interior	2-d	Wood	White	Intact	D	Center	Room	stall
391	0.2 mg/cm2	Negative	3/7/2023	16:23:27	Lead Paint	202301331	Interior	2-d	Wood	White	Intact	D	Center	Room	Cabinet
392	1.1 mg/cm2	Positive	3/7/2023	16:24:04	Lead Paint	202301331	Interior	2-d	Wood	Gray	Intact	B	Right	Door	Door
393	14.9 mg/cm2	Positive	3/7/2023	16:24:25	Lead Paint	202301331	Interior	2-d	Wood	Gray	Intact	B	Right	Door	R Casing

394	6.2 mg/cm2	Positive	3/7/2023	16:24:38	Lead Paint	202301331	Interior	2-d	Wood	Gray	Intact	B	Right	Door	R Jamb
395	0.3 mg/cm2	Negative	3/7/2023	16:26:25	Lead Paint	202301331	Interior	2-e	Plaster	White	Intact	A	Left	Room	Wall
396	0.2 mg/cm2	Negative	3/7/2023	16:26:44	Lead Paint	202301331	Interior	2-e	Drywall	White	Intact	A	Left	Room	Wall
397	0.1 mg/cm2	Negative	3/7/2023	16:26:59	Lead Paint	202301331	Interior	2-e	Drywall	White	Intact	B	Left	Room	Wall
398	0.3 mg/cm2	Negative	3/7/2023	16:27:31	Lead Paint	202301331	Interior	2-e	Drywall	White	Intact	C	Center	Room	Wall
399	0.3 mg/cm2	Negative	3/7/2023	16:27:49	Lead Paint	202301331	Interior	2-e	Drywall	White	Intact	D	Center	Room	Wall
400	0.3 mg/cm2	Negative	3/7/2023	16:28:15	Lead Paint	202301331	Interior	2-e	Drywall	Gray	Intact	D	Center	Room	Wall
401	0.3 mg/cm2	Negative	3/7/2023	16:28:57	Lead Paint	202301331	Interior	2-e	Plaster	White	Intact	C	Center	Room	Wall
402	0.1 mg/cm2	Negative	3/7/2023	16:29:28	Lead Paint	202301331	Interior	2-e	Wood	White	Intact	D	Center	Room	Baseboard
403	1.9 mg/cm2	Positive	3/7/2023	16:29:47	Lead Paint	202301331	Interior	2-e	Concrete	Gray	Intact	D	Center	Room	Baseboard
404	0.2 mg/cm2	Negative	3/7/2023	16:30:26	Lead Paint	202301331	Interior	2-e	Wood	White	Intact	A	Center	Room	Cabinet
405	0.2 mg/cm2	Negative	3/7/2023	16:30:40	Lead Paint	202301331	Interior	2-e	Wood	White	Intact	A	Center	Room	Cabinet door
406	0.1 mg/cm2	Negative	3/7/2023	16:31:28	Lead Paint	202301331	Interior	2-e	Wood	White	Intact	D	Center	Closet	Door
407	0.2 mg/cm2	Negative	3/7/2023	16:31:48	Lead Paint	202301331	Interior	2-e	Wood	White	Intact	D	Center	Closet	Door Casing
408	0.2 mg/cm2	Negative	3/7/2023	16:32:02	Lead Paint	202301331	Interior	2-e	Wood	White	Intact	D	Center	Closet	Door Jamb
409	0.3 mg/cm2	Negative	3/7/2023	16:32:41	Lead Paint	202301331	Interior	2-e	Wood	Gray	Intact	A	Center	Door	Door
410	0.4 mg/cm2	Negative	3/7/2023	16:32:58	Lead Paint	202301331	Interior	2-e	Wood	Gray	Intact	A	Center	Door	R Casing
411	0.4 mg/cm2	Negative	3/7/2023	16:33:10	Lead Paint	202301331	Interior	2-e	Wood	Gray	Intact	A	Center	Door	R Jamb
412	0.1 mg/cm2	Negative	3/7/2023	16:33:41	Lead Paint	202301331	Interior	2-e	Wood	White	Intact	B	Center	Door	R Casing
413	0.1 mg/cm2	Negative	3/7/2023	16:33:53	Lead Paint	202301331	Interior	2-e	Wood	White	Intact	B	Center	Door	R Jamb
414	0.1 mg/cm2	Negative	3/7/2023	16:34:17	Lead Paint	202301331	Interior	2-e	Wood	White	Intact	B	Center	Room	stall
415	0.4 mg/cm2	Negative	3/7/2023	16:34:59	Lead Paint	202301331	Interior	2-e	Wood	White	Intact	A	Right	Closet	Door
416	0.1 mg/cm2	Negative	3/7/2023	16:35:26	Lead Paint	202301331	Interior	2-e	Wood	Stained	Intact	A	Right	Closet	Shelf
417	0 mg/cm2	Negative	3/7/2023	16:35:40	Lead Paint	202301331	Interior	2-e	Wood	Stained	Intact	A	Right	Closet	Shelf Support
418	0.1 mg/cm2	Negative	3/7/2023	16:36:25	Lead Paint	202301331	Interior	2-e	Wood	Gray	Intact	A	Center	Room	stall
419	0.1 mg/cm2	Negative	3/7/2023	16:36:40	Lead Paint	202301331	Interior	2-e	Wood	Wallpaper	Intact	A	Center	Room	stall
420	0.3 mg/cm2	Negative	3/7/2023	16:37:30	Lead Paint	202301331	Interior	2-e	Wood	White	Intact	D	Center	Room	frame
421	0.6 mg/cm2	Negative	3/7/2023	16:37:48	Lead Paint	202301331	Interior	2-e	stone	Black	Intact	D	Center	Room	chalkboard
422	10.3 mg/cm2	Positive	3/7/2023	16:40:15	Lead Paint	202301331	Interior	2-f	Plaster	Various	Intact	A	Center	Room	Wall
423	10.2 mg/cm2	Positive	3/7/2023	16:40:33	Lead Paint	202301331	Interior	2-f	Plaster	Various	Intact	B	Center	Room	Wall
424	0.2 mg/cm2	Negative	3/7/2023	16:40:53	Lead Paint	202301331	Interior	2-f	Drywall	Various	Intact	B	Center	Room	Wall
425	11.2 mg/cm2	Positive	3/7/2023	16:41:17	Lead Paint	202301331	Interior	2-f	Plaster	Various	Intact	C	Center	Room	Wall
426	9.5 mg/cm2	Positive	3/7/2023	16:41:37	Lead Paint	202301331	Interior	2-f	Plaster	Various	Intact	D	Center	Room	Wall
427	0.2 mg/cm2	Negative	3/7/2023	16:42:10	Lead Paint	202301331	Interior	2-f	Metal	White	Intact	D	Center	Room	conduit
428	15.4 mg/cm2	Positive	3/7/2023	16:42:36	Lead Paint	202301331	Interior	2-f	Wood	White	Intact	B	Center	Room	Chair Rail
429	12.2 mg/cm2	Positive	3/7/2023	16:43:00	Lead Paint	202301331	Interior	2-f	Wood	White	Intact	B	Center	Room	stall
430	9.9 mg/cm2	Positive	3/7/2023	16:43:25	Lead Paint	202301331	Interior	2-f	Plaster	White	Intact	B	Center	Room	Ceiling
431	0.1 mg/cm2	Negative	3/7/2023	16:44:18	Lead Paint	202301331	Interior	2-f	Wood	Green	Intact	B	Center	Room	Cabinet
432	10.3 mg/cm2	Positive	3/7/2023	16:45:00	Lead Paint	202301331	Interior	2-f	Wood	Gray	Intact	A	Center	Door	Door
433	12.6 mg/cm2	Positive	3/7/2023	16:45:20	Lead Paint	202301331	Interior	2-f	Wood	White	Intact	A	Center	Door	R Casing
434	0.2 mg/cm2	Negative	3/7/2023	16:45:34	Lead Paint	202301331	Interior	2-f	Wood	White	Intact	A	Center	Door	R Jamb
435	0.3 mg/cm2	Negative	3/7/2023	16:46:17	Lead Paint	202301331	Interior	2-f	Drywall	White	Intact	A	Center	Room	Wall
436	0.3 mg/cm2	Negative	3/7/2023	16:46:39	Lead Paint	202301331	Interior	2-f	Drywall	White	Intact	B	Center	Room	Wall
437	13.8 mg/cm2	Positive	3/7/2023	16:47:21	Lead Paint	202301331	Interior	2-f	Wood	White	Intact	B	Center	Room	stall
438	0.2 mg/cm2	Negative	3/7/2023	16:47:33	Lead Paint	202301331	Interior	2-f	Wood	White	Intact	B	Center	Room	stall
439	11.8 mg/cm2	Positive	3/7/2023	16:47:44	Lead Paint	202301331	Interior	2-f	Wood	White	Intact	B	Center	Room	stall
440	0.8 mg/cm2	Negative	3/7/2023	16:48:23	Lead Paint	202301331	Interior	2-f	Wood	Gray	Intact	D	Center	Door	Door
441	12 mg/cm2	Positive	3/7/2023	16:48:45	Lead Paint	202301331	Interior	2-f	Wood	Gray	Intact	D	Center	Door	R Casing
442	7.9 mg/cm2	Positive	3/7/2023	16:48:57	Lead Paint	202301331	Interior	2-f	Wood	Gray	Intact	D	Center	Door	R Jamb
443	0.3 mg/cm2	Negative	3/7/2023	16:49:27	Lead Paint	202301331	Interior	2-f	Ceramic	Offwhite	Intact	D	Center	Room	Floor

Company Viken Detection
 Model Pb200i
 Instrument Type XRF Lead Paint Analyzer
 Serial Number 2627
 App Version Pb200i-4.1-11

Reading #	Concentration	Units	Result	Date	Time	Job name	Interior/exterior	Room	Substrate	Color	Condition	Wall	Location	Member	Component
1		0.9 mg/cm2	Negative	3/8/2023	11:11:26		Calibration								
2		0.8 mg/cm2	Negative	3/8/2023	11:11:40		Calibration								
3		0.9 mg/cm2	Negative	3/8/2023	11:11:55		Calibration								
4		0.1 mg/cm2	Negative	3/8/2023	11:12:11		Calibration								
5		0.1 mg/cm2	Negative	3/8/2023	11:12:17		Calibration								
6		0.1 mg/cm2	Negative	3/8/2023	11:12:24		Calibration								
7		1.1 mg/cm2	Positive	3/8/2023	11:16:47	202301331	Interior	2-h	Plaster	White	Intact	A	Center	Room	Wall
8		0.8 mg/cm2	NULL	3/8/2023	11:17:10	202301331	Interior	2-h	Plaster	White	Intact	B	Center	Room	Wall
9		0.8 mg/cm2	Negative	3/8/2023	11:20:03	202301331	Interior	2-h	Plaster	White	Intact	B	Center	Room	Wall
10		0.3 mg/cm2	Negative	3/8/2023	11:20:42	202301331	Interior	2-h	Drywall	White	Intact	B	Right	Room	Wall
11		0.2 mg/cm2	Negative	3/8/2023	11:20:57	202301331	Interior	2-h	Drywall	White	Intact	C	Left	Room	Wall
12		0.6 mg/cm2	Negative	3/8/2023	11:21:17	202301331	Interior	2-h	Plaster	White	Intact	C	Center	Room	Wall
13		0.5 mg/cm2	Negative	3/8/2023	11:21:39	202301331	Interior	2-h	Plaster	White	Intact	D	Center	Room	Wall
14		0.6 mg/cm2	Negative	3/8/2023	11:22:11	202301331	Interior	2-h	Wood	White	Intact	D	Center	Room	Baseboard
15		0.3 mg/cm2	Negative	3/8/2023	11:23:22	202301331	Interior	2-h	Metal	Offwhite	Intact	D	Center	Window	Part Bead
16		0.1 mg/cm2	Negative	3/8/2023	11:24:10	202301331	Interior	2-h	Wood	Offwhite	Intact	A	Center	Room	frame
17		0.6 mg/cm2	Negative	3/8/2023	11:24:52	202301331	Interior	2-h	stone	Black	Intact	A	Center	Room	blackboard
18		0.1 mg/cm2	Negative	3/8/2023	11:25:12	202301331	Interior	2-h	stone	Green	Intact	A	Center	Room	blackboard
19		0.3 mg/cm2	Negative	3/8/2023	11:25:33	202301331	Interior	2-h	Wood	Gray	Intact	A	Center	Room	blackboard
20		0.4 mg/cm2	Negative	3/8/2023	11:25:59	202301331	Interior	2-h	Metal	Offwhite	Intact	A	Center	Room	vent
21		0.2 mg/cm2	Negative	3/8/2023	11:26:38	202301331	Interior	2-h	Wood	Offwhite	Intact	C	Center	Room	Shelf
22		0.1 mg/cm2	Negative	3/8/2023	11:26:52	202301331	Interior	2-h	Wood	Offwhite	Intact	C	Center	Room	Shelf Support
23		0.5 mg/cm2	Negative	3/8/2023	11:27:32	202301331	Interior	2-h	Wood	Offwhite	Intact	C	Center	Closet	Door
24		0.1 mg/cm2	Negative	3/8/2023	11:27:52	202301331	Interior	2-h	Wood	Stained	Intact	C	Center	Closet	Shelf
25		0.2 mg/cm2	Negative	3/8/2023	11:28:09	202301331	Interior	2-h	Wood	Stained	Intact	C	Center	Closet	Shelf Support
26		0.3 mg/cm2	Negative	3/8/2023	11:28:44	202301331	Interior	2-h	Wood	Gray	Intact	B	Center	Door	Door
27		0.4 mg/cm2	Negative	3/8/2023	11:29:05	202301331	Interior	2-h	Wood	White	Intact	B	Center	Door	L casing
28		0.2 mg/cm2	Negative	3/8/2023	11:29:17	202301331	Interior	2-h	Wood	White	Intact	B	Center	Door	L Jamb
29		0.2 mg/cm2	Negative	3/8/2023	11:30:36	202301331	Interior	2-h	Plaster	White	Intact	A	Center	Room	Ceiling
30		0.2 mg/cm2	Negative	3/8/2023	11:31:10	202301331	Interior	2-h	Metal	White	Intact	A	Center	Room	vent
31		0.3 mg/cm2	Negative	3/8/2023	12:04:55	202301331	Interior	2-i	Plaster	White	Intact	A	Center	Room	Wall
32		0.2 mg/cm2	Negative	3/8/2023	12:05:25	202301331	Interior	2-i	Plaster	White	Intact	A	Center	Room	Wall
33		0.1 mg/cm2	Negative	3/8/2023	12:05:49	202301331	Interior	2-i	Plaster	White	Intact	B	Center	Room	Wall
34		0.3 mg/cm2	Negative	3/8/2023	12:06:14	202301331	Interior	2-i	Drywall	White	Intact	C	Center	Room	Wall
35		0.4 mg/cm2	Negative	3/8/2023	12:06:34	202301331	Interior	2-i	Plaster	White	Intact	D	Center	Room	Wall
36		0.2 mg/cm2	Negative	3/8/2023	12:07:21	202301331	Interior	2-i	Plaster	White	Intact	D	Center	Room	Ceiling
37		0.2 mg/cm2	Negative	3/8/2023	12:07:56	202301331	Interior	2-i	Metal	White	Intact	C	Center	Room	vent
38		0.2 mg/cm2	Negative	3/8/2023	12:08:43	202301331	Interior	2-i	Wood	White	Intact	A	Center	Room	bulletin board
39		0.5 mg/cm2	Negative	3/8/2023	12:09:15	202301331	Interior	2-i	Wood	White	Intact	D	Center	Room	Baseboard
40		0.2 mg/cm2	Negative	3/8/2023	12:09:35	202301331	Interior	2-i	Wood	Stained	Intact	D	Center	Room	Floor
41		0.5 mg/cm2	Negative	3/8/2023	12:10:07	202301331	Interior	2-i	Metal	White	Intact	D	Center	Room	conduit
42		0.2 mg/cm2	Negative	3/8/2023	12:10:31	202301331	Interior	2-i	Wood	White	Intact	D	Center	Room	panel
43		0.3 mg/cm2	Negative	3/8/2023	12:11:00	202301331	Interior	2-i	Metal	White	Intact	D	Center	Window	Part Bead
44		0.5 mg/cm2	Negative	3/8/2023	12:11:22	202301331	Interior	2-i	Metal	White	Intact	D	Center	Window	Sash

45	0.4 mg/cm2	Negative	3/8/2023	12:11:43	202301331	Interior	2-i	Metal	White	Intact	D	Center	Window	L Casing
46	0.3 mg/cm2	Negative	3/8/2023	12:12:16	202301331	Interior	2-i	Wood	Various	Intact	D	Center	Closet	Door
47	0.1 mg/cm2	Negative	3/8/2023	12:12:49	202301331	Interior	2-i	Wood	Green	Intact	A	Center	Closet	Shelf
48	0.2 mg/cm2	Negative	3/8/2023	12:13:03	202301331	Interior	2-i	Wood	Green	Intact	A	Center	Closet	Shelf Support
49	0.3 mg/cm2	Negative	3/8/2023	12:13:57	202301331	Interior	2-i	Wood	Gray	Intact	D	Center	Door	Door
50	0.3 mg/cm2	Negative	3/8/2023	12:14:21	202301331	Interior	2-i	Wood	White	Intact	D	Center	Door	R Casing
51	0.4 mg/cm2	Negative	3/8/2023	12:14:34	202301331	Interior	2-i	Wood	White	Intact	D	Center	Door	R Jamb
52	0.4 mg/cm2	Negative	3/8/2023	12:16:19	202301331	Interior	2-j	Plaster	White	Intact	A	Center	Room	Wall
53	1.8 mg/cm2	Positive	3/8/2023	12:16:51	202301331	Interior	2-j	Drywall	White	Intact	B	Center	Room	Wall
54	0.2 mg/cm2	Negative	3/8/2023	12:17:12	202301331	Interior	2-j	Plaster	White	Intact	C	Center	Room	Wall
55	0.3 mg/cm2	Negative	3/8/2023	12:18:03	202301331	Interior	2-j	Drywall	White	Intact	C	Right	Room	Wall
56	0.3 mg/cm2	Negative	3/8/2023	12:18:23	202301331	Interior	2-j	Drywall	White	Intact	D	Left	Room	Wall
57	0.2 mg/cm2	Negative	3/8/2023	12:18:39	202301331	Interior	2-j	Plaster	White	Intact	D	Center	Room	Wall
58	0.2 mg/cm2	Negative	3/8/2023	12:19:27	202301331	Interior	2-j	Plaster	White	Intact	C	Center	Room	Ceiling
59	0.2 mg/cm2	Negative	3/8/2023	12:19:57	202301331	Interior	2-j	Wood	White	Intact	C	Center	Room	Crown Moulding
60	0.9 mg/cm2	Negative	3/8/2023	12:20:33	202301331	Interior	2-j	Wood	White	Intact	C	Center	Room	Baseboard
61	0.1 mg/cm2	Negative	3/8/2023	12:21:08	202301331	Interior	2-j	Wood	White	Intact	C	Center	Room	frame
62	0.3 mg/cm2	Negative	3/8/2023	12:21:55	202301331	Interior	2-j	stone	Black	Intact	C	Center	Room	blackboard
63	0.7 mg/cm2	Negative	3/8/2023	12:23:15	202301331	Interior	2-j	stone	Black	Intact	C	Center	Room	blackboard
64	0.1 mg/cm2	Negative	3/8/2023	12:23:40	202301331	Interior	2-j	Wood	White	Intact	C	Center	Room	bulletin board
65	0.4 mg/cm2	Negative	3/8/2023	12:24:42	202301331	Interior	2-j	Wood	Gray	Intact	C	Center	Door	Door
66	0.5 mg/cm2	Negative	3/8/2023	12:25:01	202301331	Interior	2-j	Wood	White	Intact	C	Center	Door	L casing
67	0.3 mg/cm2	Negative	3/8/2023	12:25:13	202301331	Interior	2-j	Wood	White	Intact	C	Center	Door	L Jamb
68	0.1 mg/cm2	Negative	3/8/2023	12:25:34	202301331	Interior	2-j	Wood	White	Intact	A	Center	Closet	Door
69	0.2 mg/cm2	Negative	3/8/2023	12:25:59	202301331	Interior	2-j	Wood	Stained	Intact	A	Center	Closet	Shelf
70	0.3 mg/cm2	Negative	3/8/2023	12:26:12	202301331	Interior	2-j	Wood	Stained	Intact	A	Center	Closet	Shelf Support
71	0.4 mg/cm2	Negative	3/8/2023	12:26:58	202301331	Interior	2-j	Metal	White	Intact	C	Center	Room	conduit
72	0.5 mg/cm2	Negative	3/8/2023	12:28:17	202301331	Interior	2-k	Plaster	White	Intact	A	Center	Room	Wall
73	0.6 mg/cm2	Negative	3/8/2023	12:28:51	202301331	Interior	2-k	Drywall	White	Intact	B	Center	Room	Wall
74	0.7 mg/cm2	Negative	3/8/2023	12:29:15	202301331	Interior	2-k	Plaster	White	Intact	C	Center	Room	Wall
75	0.7 mg/cm2	Negative	3/8/2023	12:29:43	202301331	Interior	2-k	Plaster	White	Intact	D	Center	Room	Wall
76	0.3 mg/cm2	Negative	3/8/2023	12:30:26	202301331	Interior	2-k	Plaster	White	Intact	C	Center	Room	Ceiling
77	0.4 mg/cm2	Negative	3/8/2023	12:30:53	202301331	Interior	2-k	Wood	White	Intact	C	Center	Room	Baseboard
78	0.6 mg/cm2	Negative	3/8/2023	12:31:23	202301331	Interior	2-k	Wood	White	Intact	C	Center	Room	Crown Moulding
79	0.1 mg/cm2	Negative	3/8/2023	12:32:04	202301331	Interior	2-k	Wood	White	Intact	B	Center	Room	Shelf
80	0.2 mg/cm2	Negative	3/8/2023	12:32:17	202301331	Interior	2-k	Wood	White	Intact	B	Center	Room	Shelf Support
81	0.5 mg/cm2	Negative	3/8/2023	12:32:51	202301331	Interior	2-k	Metal	White	Intact	B	Center	Room	conduit
82	0.3 mg/cm2	Negative	3/8/2023	12:33:53	202301331	Interior	2-k	Wood	Gray	Intact	C	Center	Door	Door
83	0.4 mg/cm2	Negative	3/8/2023	12:34:09	202301331	Interior	2-k	Wood	White	Intact	C	Center	Door	R Casing
84	0.3 mg/cm2	Negative	3/8/2023	12:34:21	202301331	Interior	2-k	Wood	White	Intact	C	Center	Door	R Jamb
85	0.4 mg/cm2	Negative	3/8/2023	12:34:49	202301331	Interior	2-k	Wood	Gray	Intact	C	Center	Door	footer
86	0.5 mg/cm2	Negative	3/8/2023	12:35:27	202301331	Interior	2-k	Metal	White	Intact	C	Left	Room	vent
87	0.4 mg/cm2	Negative	3/8/2023	12:37:00	202301331	Interior	2-i	Plaster	White	Intact	A	Center	Room	Wall
88	0.5 mg/cm2	Negative	3/8/2023	12:37:16	202301331	Interior	2-i	Plaster	White	Intact	B	Center	Room	Wall
89	0.8 mg/cm2	Negative	3/8/2023	12:37:36	202301331	Interior	2-i	Plaster	White	Intact	C	Center	Room	Wall
90	0.9 mg/cm2	Negative	3/8/2023	12:38:09	202301331	Interior	2-i	Plaster	Various	Intact	D	Center	Room	Wall
91	0.2 mg/cm2	Negative	3/8/2023	12:39:06	202301331	Interior	2-i	Plaster	White	Intact	C	Center	Room	Ceiling
92	0.4 mg/cm2	Negative	3/8/2023	12:39:39	202301331	Interior	2-i	Wood	White	Intact	C	Center	Room	Baseboard
93	0.2 mg/cm2	Negative	3/8/2023	12:40:23	202301331	Interior	2-i	Metal	White	Intact	C	Center	Room	panel
94	0.2 mg/cm2	Negative	3/8/2023	12:41:16	202301331	Interior	2-i	Wood	White	Intact	C	Center	Room	Crown Moulding
95	0.5 mg/cm2	Negative	3/8/2023	12:41:56	202301331	Interior	2-i	Metal	White	Intact	C	Center	Room	conduit

96	0.5 mg/cm2	Negative	3/8/2023	12:42:13	202301331	Interior	2-l	Wood	White	Intact	C	Center	Room	frame
97	0.4 mg/cm2	Negative	3/8/2023	12:42:33	202301331	Interior	2-l	stone	Black	Intact	C	Center	Room	blackboard
98	0.2 mg/cm2	Negative	3/8/2023	12:43:04	202301331	Interior	2-l	Drywall	White	Intact	B	Right	Room	Wall
99	0.3 mg/cm2	Negative	3/8/2023	12:43:31	202301331	Interior	2-l	Drywall	White	Intact	C	Left	Room	Wall
100	0.9 mg/cm2	Negative	3/8/2023	12:43:57	202301331	Interior	2-l	Wood	White	Intact	D	Left	Room	Shelf
101	0.3 mg/cm2	Negative	3/8/2023	12:44:18	202301331	Interior	2-l	Wood	White	Intact	D	Left	Room	Shelf Support
102	0.5 mg/cm2	Negative	3/8/2023	12:44:49	202301331	Interior	2-l	Wood	Gray	Intact	C	Center	Door	Door
103	0.5 mg/cm2	Negative	3/8/2023	12:45:08	202301331	Interior	2-l	Wood	Offwhite	Intact	C	Center	Door	L casing
104	0.4 mg/cm2	Negative	3/8/2023	12:45:21	202301331	Interior	2-l	Wood	Offwhite	Intact	C	Center	Door	L Jamb
105	0.4 mg/cm2	Negative	3/8/2023	12:45:52	202301331	Interior	2-l	Wood	Offwhite	Intact	A	Center	Closet	Door
106	0.1 mg/cm2	Negative	3/8/2023	12:46:17	202301331	Interior	2-l	Wood	Stained	Intact	A	Center	Closet	Shelf
107	0.2 mg/cm2	Negative	3/8/2023	12:46:30	202301331	Interior	2-l	Wood	Stained	Intact	A	Center	Closet	Shelf Support
108	3 mg/cm2	Positive	3/8/2023	12:47:50	202301331	Interior	2-m	Plaster	White	Intact	A	Center	Room	Wall
109	2.4 mg/cm2	Positive	3/8/2023	12:48:21	202301331	Interior	2-m	Plaster	White	Intact	B	Center	Room	Wall
110	1.7 mg/cm2	Positive	3/8/2023	12:48:45	202301331	Interior	2-m	Plaster	Various	Intact	C	Center	Room	Wall
111	3.2 mg/cm2	Positive	3/8/2023	12:49:26	202301331	Interior	2-m	Plaster	Various	Intact	D	Center	Room	Wall
112	0.3 mg/cm2	Negative	3/8/2023	12:50:48	202301331	Interior	2-m	Plaster	White	Intact	C	Center	Room	Ceiling
113	2.2 mg/cm2	Positive	3/8/2023	12:51:41	202301331	Interior	2-m	Plaster	Gray	Intact	A	Center	Room	Baseboard
114	0 mg/cm2	Negative	3/8/2023	12:52:47	202301331	Interior	2-m	Wood	White	Intact	D	Right	Room	box
115	0.5 mg/cm2	Negative	3/8/2023	12:53:19	202301331	Interior	2-m	Wood	Gray	Intact	C	Center	Room	frame
116	0.5 mg/cm2	Negative	3/8/2023	12:53:39	202301331	Interior	2-m	Wood	Various	Intact	C	Center	Room	bulletin board
117	0.2 mg/cm2	Negative	3/8/2023	12:54:47	202301331	Interior	2-m	Wood	Gray	Intact	A	Center	Room	Chair Rail
118	0.3 mg/cm2	Negative	3/8/2023	12:55:46	202301331	Interior	2-m	Wood	Gray	Intact	A	Center	Door	Door
119	0.5 mg/cm2	Negative	3/8/2023	12:56:03	202301331	Interior	2-m	Wood	Gray	Intact	A	Center	Door	R Casing
120	0.2 mg/cm2	Negative	3/8/2023	12:56:15	202301331	Interior	2-m	Wood	Gray	Intact	A	Center	Door	R Jamb
121	0.7 mg/cm2	Negative	3/8/2023	12:57:11	202301331	Interior	2-m	Wood	Gray	Intact	C	Right	Door	Door
122	0.3 mg/cm2	Negative	3/8/2023	12:57:44	202301331	Interior	2-m	Wood	White	Intact	C	Right	Door	L casing
123	0.2 mg/cm2	Negative	3/8/2023	12:57:57	202301331	Interior	2-m	Wood	White	Intact	C	Right	Door	L Jamb
124	0.1 mg/cm2	Negative	3/8/2023	12:58:37	202301331	Interior	2-m	Wood	Gray	Intact	D	Center	Door	Door
125	0.5 mg/cm2	Negative	3/8/2023	12:58:49	202301331	Interior	2-m	Wood	Gray	Intact	D	Center	Door	R Casing
126	0.4 mg/cm2	Negative	3/8/2023	12:59:04	202301331	Interior	2-m	Wood	Gray	Intact	D	Center	Door	R Jamb
127	0.4 mg/cm2	Negative	3/8/2023	12:59:28	202301331	Interior	2-m	Metal	White	Intact	D	Center	Room	conduit
128	0.2 mg/cm2	Negative	3/8/2023	13:01:40	202301331	Interior	2-m	Wood	Gray	Intact	D	Right	Door	Door
129	0.5 mg/cm2	Negative	3/8/2023	13:02:27	202301331	Interior	2-m	Drywall	White	Intact	D	Right	Closet	Wall
130	0.4 mg/cm2	Negative	3/8/2023	13:03:02	202301331	Interior	2-m	Wood	White	Intact	D	Right	Closet	board
131	0.6 mg/cm2	Negative	3/8/2023	13:06:47	202301331	Interior	3-a	Plaster	White	Intact	A	Center	Room	Wall
132	0.3 mg/cm2	Negative	3/8/2023	13:07:13	202301331	Interior	3-a	Plaster	White	Intact	B	Center	Room	Wall
133	0.2 mg/cm2	Negative	3/8/2023	13:07:34	202301331	Interior	3-a	Plaster	White	Intact	C	Center	Room	Wall
134	0.9 mg/cm2	Negative	3/8/2023	13:07:55	202301331	Interior	3-a	Plaster	White	Intact	D	Center	Room	Wall
135	0.7 mg/cm2	Negative	3/8/2023	13:12:12	202301331	Interior	3-a	Plaster	White	Intact	D	Center	Room	Ceiling
136	0.1 mg/cm2	Negative	3/8/2023	13:12:50	202301331	Interior	3-a	Metal	White	Intact	D	Center	Room	vent
137	0.3 mg/cm2	Negative	3/8/2023	13:13:36	202301331	Interior	3-a	Wood	White	Intact	A	Center	Room	Shelf
138	0.1 mg/cm2	Negative	3/8/2023	13:13:48	202301331	Interior	3-a	Wood	White	Intact	A	Center	Room	Shelf Support
139	0.4 mg/cm2	Negative	3/8/2023	13:14:12	202301331	Interior	3-a	Wood	White	Intact	D	Center	Room	Baseboard
140	0.5 mg/cm2	Negative	3/8/2023	13:14:26	202301331	Interior	3-a	Wood	White	Intact	D	Center	Room	Crown Moulding
141	0.3 mg/cm2	Negative	3/8/2023	13:14:55	202301331	Interior	3-a	Wood	White	Intact	D	Center	Room	frame
142	0.2 mg/cm2	Negative	3/8/2023	13:15:12	202301331	Interior	3-a	stone	Black	Intact	D	Center	Room	frame
143	0.4 mg/cm2	Negative	3/8/2023	13:16:09	202301331	Interior	3-a	Wood	Yellow	Intact	D	Center	Room	fence
144	0.4 mg/cm2	Negative	3/8/2023	13:16:25	202301331	Interior	3-a	Wood	Yellow	Intact	D	Center	Room	bulletin board
145	0.5 mg/cm2	Negative	3/8/2023	13:17:03	202301331	Interior	3-a	Metal	White	Intact	B	Center	Room	conduit
146	0.5 mg/cm2	Negative	3/8/2023	13:17:38	202301331	Interior	3-a	Wood	White	Intact	B	Center	Room	frame

147	0.4 mg/cm2	Negative	3/8/2023	13:17:53	202301331	Interior	3-a	Wood	White	Intact	B	Center	Room	bulletin board
148	0.4 mg/cm2	Negative	3/8/2023	13:18:21	202301331	Interior	3-a	Metal	White	Intact	C	Center	Room	vent
149	0.2 mg/cm2	Negative	3/8/2023	13:19:59	202301331	Interior	3-b	Drywall	White	Intact	A	Center	Room	Wall
150	0.4 mg/cm2	Negative	3/8/2023	13:20:32	202301331	Interior	3-b	Plaster	White	Intact	B	Center	Room	Wall
151	0.8 mg/cm2	Negative	3/8/2023	13:20:54	202301331	Interior	3-b	Plaster	White	Intact	C	Center	Room	Wall
152	0.6 mg/cm2	Negative	3/8/2023	13:21:32	202301331	Interior	3-b	Plaster	White	Deteriorated	D	Center	Room	Wall
153	0.3 mg/cm2	Negative	3/8/2023	13:22:39	202301331	Interior	3-b	Plaster	White	Intact	D	Center	Room	Ceiling
154	0.1 mg/cm2	Negative	3/8/2023	13:23:14	202301331	Interior	3-b	Metal	White	Intact	D	Center	Room	vent
155	0.1 mg/cm2	Negative	3/8/2023	13:24:00	202301331	Interior	3-b	Wood	White	Intact	A	Center	Room	Baseboard
156	0.3 mg/cm2	Negative	3/8/2023	13:25:15	202301331	Interior	3-b	Wood	Stained	Intact	A	Right	Room	Floor
157	0.3 mg/cm2	Negative	3/8/2023	13:25:36	202301331	Interior	3-b	Wood	White	Intact	A	Right	Room	frame
158	0.5 mg/cm2	Negative	3/8/2023	13:25:53	202301331	Interior	3-b	Wood	White	Intact	A	Right	Room	bulletin board
159	0.1 mg/cm2	Negative	3/8/2023	13:26:21	202301331	Interior	3-b	stone	Black	Intact	A	Right	Room	blackboard
160	0.2 mg/cm2	Negative	3/8/2023	13:26:59	202301331	Interior	3-b	Wood	White	Intact	C	Right	Room	Cabinet
161	0.2 mg/cm2	Negative	3/8/2023	13:27:20	202301331	Interior	3-b	Wood	Yellow	Intact	C	Center	Room	Cabinet door
162	0.5 mg/cm2	Negative	3/8/2023	13:28:03	202301331	Interior	3-b	Metal	White	Intact	D	Center	Room	conduit
163	0.1 mg/cm2	Negative	3/8/2023	13:28:31	202301331	Interior	3-b	Wood	Gray	Intact	D	Right	Door	Door
164	0.3 mg/cm2	Negative	3/8/2023	13:28:48	202301331	Interior	3-b	Wood	White	Intact	D	Right	Door	R Casing
165	0.4 mg/cm2	Negative	3/8/2023	13:29:03	202301331	Interior	3-b	Wood	White	Intact	D	Right	Door	R Jamb
166	0.3 mg/cm2	Negative	3/8/2023	13:31:09	202301331	Interior	3-c	Drywall	White	Intact	A	Center	Room	Wall
167	1.8 mg/cm2	Positive	3/8/2023	13:31:36	202301331	Interior	3-c	Plaster	Various	Intact	B	Center	Room	Wall
168	2.2 mg/cm2	Positive	3/8/2023	13:31:51	202301331	Interior	3-c	Plaster	Various	Intact	C	Center	Room	Wall
169	3.2 mg/cm2	Positive	3/8/2023	13:32:15	202301331	Interior	3-c	Plaster	White	Intact	D	Center	Room	Wall
170	0.1 mg/cm2	Negative	3/8/2023	13:32:42	202301331	Interior	3-c	Drywall	White	Intact	D	Right	Room	Wall
171	0.1 mg/cm2	Negative	3/8/2023	13:33:30	202301331	Interior	3-c	Concrete	Gray	Intact	B	Center	Room	Baseboard
172	0.4 mg/cm2	Negative	3/8/2023	13:34:17	202301331	Interior	3-c	Concrete	Gray	Intact	A	Center	Room	Ceiling
173	0.2 mg/cm2	Negative	3/8/2023	13:34:44	202301331	Interior	3-c	Metal	Gray	Intact	A	Center	Railing	Railing
174	0.5 mg/cm2	Negative	3/8/2023	13:35:14	202301331	Interior	3-c	Wood	White	Intact	B	Center	Railing	Railing
175	0.3 mg/cm2	Negative	3/8/2023	13:35:43	202301331	Interior	3-c	Metal	White	Intact	D	Center	Railing	Railing
176	0.7 mg/cm2	Negative	3/8/2023	13:36:48	202301331	Interior	3-c	Concrete	Gray	Intact	A	Center	Stairs	Tread
177	6.8 mg/cm2	Positive	3/8/2023	13:37:14	202301331	Interior	3-c	Concrete	Gray	Intact	A	Center	Stairs	Riser
178	0.2 mg/cm2	Negative	3/8/2023	13:37:58	202301331	Interior	3-c	Wood	Gray	Intact	C	Center	Door	Door
179	0.3 mg/cm2	Negative	3/8/2023	13:38:17	202301331	Interior	3-c	Metal	Gray	Intact	C	Center	Door	R Casing
180	0.2 mg/cm2	Negative	3/8/2023	13:38:31	202301331	Interior	3-c	Metal	Gray	Intact	C	Center	Door	R Jamb
181	0.5 mg/cm2	Negative	3/8/2023	13:38:57	202301331	Interior	3-c	Metal	White	Intact	D	Center	Room	conduit
182	0.2 mg/cm2	Negative	3/8/2023	13:39:58	202301331	Interior	3-c	Wood	Gray	Intact	A	Left	Door	Door
183	0.3 mg/cm2	Negative	3/8/2023	13:40:15	202301331	Interior	3-c	Metal	Gray	Intact	A	Left	Door	R Casing
184	0.2 mg/cm2	Negative	3/8/2023	13:40:31	202301331	Interior	3-c	Metal	Gray	Intact	A	Left	Door	R Jamb
185	0.6 mg/cm2	Negative	3/8/2023	13:43:25	202301331	Interior	3-d	Plaster	White	Intact	A	Center	Room	Wall
186	0.1 mg/cm2	Negative	3/8/2023	13:43:43	202301331	Interior	3-d	Plaster	White	Intact	B	Center	Room	Wall
187	0.5 mg/cm2	Negative	3/8/2023	13:43:59	202301331	Interior	3-d	Plaster	White	Intact	C	Center	Room	Wall
188	0.6 mg/cm2	Negative	3/8/2023	13:44:16	202301331	Interior	3-d	Plaster	White	Intact	D	Center	Room	Wall
189	0.2 mg/cm2	Negative	3/8/2023	13:44:42	202301331	Interior	3-d	Drywall	White	Intact	D	Right	Room	Wall
190	0.2 mg/cm2	Negative	3/8/2023	13:45:06	202301331	Interior	3-d	Drywall	White	Intact	A	Left	Room	Wall
191	0.1 mg/cm2	Negative	3/8/2023	13:46:09	202301331	Interior	3-d	Wood	White	Intact	D	Center	Room	Shelf
192	0.2 mg/cm2	Negative	3/8/2023	13:46:21	202301331	Interior	3-d	Wood	White	Intact	D	Center	Room	Shelf Support
193	0.4 mg/cm2	Negative	3/8/2023	13:46:46	202301331	Interior	3-d	Metal	White	Intact	D	Center	Room	conduit
194	0.3 mg/cm2	Negative	3/8/2023	13:47:12	202301331	Interior	3-d	Metal	White	Intact	A	Center	Room	frame
195	0.4 mg/cm2	Negative	3/8/2023	13:47:25	202301331	Interior	3-d	Metal	White	Intact	A	Center	Room	bulletin board
196	0.1 mg/cm2	Negative	3/8/2023	13:47:48	202301331	Interior	3-d	Wood	White	Intact	A	Center	Room	bulletin board
197	0.3 mg/cm2	Negative	3/8/2023	13:48:08	202301331	Interior	3-d	Wood	White	Intact	B	Center	Room	frame

198	0.6 mg/cm2	Negative	3/8/2023	13:48:31	202301331	Interior	3-d	stone	Black	Intact	B	Center	Room	blackboard
199	0.2 mg/cm2	Negative	3/8/2023	13:49:22	202301331	Interior	3-d	Wood	Gray	Intact	A	Center	Door	Door
200	0.2 mg/cm2	Negative	3/8/2023	13:49:42	202301331	Interior	3-d	Wood	White	Intact	A	Center	Door	R Casing
201	0.4 mg/cm2	Negative	3/8/2023	13:49:54	202301331	Interior	3-d	Wood	White	Intact	A	Center	Door	R Jamb
202	0.1 mg/cm2	Negative	3/8/2023	13:51:00	202301331	Interior	3-d	Wood	White	Intact	D	Center	Door	Door
203	0.1 mg/cm2	Negative	3/8/2023	13:51:18	202301331	Interior	3-d	Wood	White	Intact	D	Center	Door	R Casing
204	0.2 mg/cm2	Negative	3/8/2023	13:51:30	202301331	Interior	3-d	Wood	White	Intact	D	Center	Door	R Jamb
205	0.3 mg/cm2	Negative	3/8/2023	13:51:55	202301331	Interior	3-d	Wood	White	Intact	D	Center	Closet	Door
206	0.1 mg/cm2	Negative	3/8/2023	13:52:21	202301331	Interior	3-d	Wood	Stained	Intact	D	Center	Closet	Shelf
207	0.1 mg/cm2	Negative	3/8/2023	13:52:35	202301331	Interior	3-d	Wood	Stained	Intact	D	Center	Closet	Shelf Support
208	0.3 mg/cm2	Negative	3/8/2023	13:53:22	202301331	Interior	3-d	Plaster	White	Intact	D	Center	Room	Ceiling
209	0.1 mg/cm2	Negative	3/8/2023	13:54:15	202301331	Interior	3-d	Metal	White	Intact	A	Center	Room	vent
210	0.2 mg/cm2	Negative	3/8/2023	13:54:50	202301331	Interior	3-d	Wood	White	Intact	A	Center	Room	Crown Moulding
211	0.5 mg/cm2	Negative	3/8/2023	13:55:06	202301331	Interior	3-d	Wood	White	Intact	A	Center	Room	Baseboard
212	0.3 mg/cm2	Negative	3/8/2023	13:55:33	202301331	Interior	3-d	Wood	Stained	Intact	A	Center	Room	Floor
213	0.1 mg/cm2	Negative	3/8/2023	14:01:25	202301331	Interior	3-e	Plaster	White	Intact	A	Center	Room	Wall
214	0.4 mg/cm2	Negative	3/8/2023	14:01:39	202301331	Interior	3-e	Plaster	White	Intact	B	Center	Room	Wall
215	0.1 mg/cm2	Negative	3/8/2023	14:02:03	202301331	Interior	3-e	Plaster	White	Intact	C	Center	Room	Wall
216	0.4 mg/cm2	Negative	3/8/2023	14:02:19	202301331	Interior	3-e	Plaster	White	Intact	D	Center	Room	Wall
217	0.2 mg/cm2	Negative	3/8/2023	14:02:50	202301331	Interior	3-e	Drywall	White	Intact	A	Center	Room	Wall
218	0.2 mg/cm2	Negative	3/8/2023	14:03:09	202301331	Interior	3-e	Drywall	White	Intact	B	Center	Room	Wall
219	0.2 mg/cm2	Negative	3/8/2023	14:03:56	202301331	Interior	3-e	Drywall	White	Intact	D	Center	Room	Wall
220	0 mg/cm2	Negative	3/8/2023	14:04:56	202301331	Interior	3-e	Plaster	White	Intact	A	Center	Room	Ceiling
221	0.1 mg/cm2	Negative	3/8/2023	14:05:22	202301331	Interior	3-e	Metal	White	Intact	A	Center	Room	vent
222	0.4 mg/cm2	Negative	3/8/2023	14:06:02	202301331	Interior	3-e	Wood	White	Intact	A	Center	Room	Crown Moulding
223	0.3 mg/cm2	Negative	3/8/2023	14:06:24	202301331	Interior	3-e	Wood	White	Intact	A	Center	Room	Baseboard
224	0.3 mg/cm2	Negative	3/8/2023	14:06:43	202301331	Interior	3-e	Wood	Stained	Intact	A	Center	Room	Floor
225	0.5 mg/cm2	Negative	3/8/2023	14:07:09	202301331	Interior	3-e	Wood	White	Intact	A	Center	Room	frame
226	0.1 mg/cm2	Negative	3/8/2023	14:07:29	202301331	Interior	3-e	stone	Black	Intact	A	Center	Room	blackboard
227	0.3 mg/cm2	Negative	3/8/2023	14:07:56	202301331	Interior	3-e	Wood	White	Intact	A	Center	Room	bulletin board
228	0 mg/cm2	Negative	3/8/2023	14:08:53	202301331	Interior	3-e	Wood	White	Intact	A	Right	Room	access
229	0.3 mg/cm2	Negative	3/8/2023	14:09:13	202301331	Interior	3-e	Wood	White	Intact	B	Left	Room	panel
230	0.1 mg/cm2	Negative	3/8/2023	14:09:32	202301331	Interior	3-e	Wood	White	Intact	B	Center	Room	Shelf
231	0.1 mg/cm2	Negative	3/8/2023	14:09:44	202301331	Interior	3-e	Wood	White	Intact	B	Center	Room	Shelf Support
232	0.3 mg/cm2	Negative	3/8/2023	14:10:25	202301331	Interior	3-e	Metal	White	Intact	C	Center	Room	conduit
233	0 mg/cm2	Negative	3/8/2023	14:11:01	202301331	Interior	3-e	Wood	White	Intact	B	Center	Door	L casing
234	0.1 mg/cm2	Negative	3/8/2023	14:11:16	202301331	Interior	3-e	Wood	White	Intact	B	Center	Door	L Jamb
235	0.3 mg/cm2	Negative	3/8/2023	14:11:51	202301331	Interior	3-e	Wood	Gray	Intact	A	Center	Door	Door
236	0.2 mg/cm2	Negative	3/8/2023	14:12:10	202301331	Interior	3-e	Wood	White	Intact	A	Center	Door	R Casing
237	0.1 mg/cm2	Negative	3/8/2023	14:12:23	202301331	Interior	3-e	Wood	White	Intact	A	Center	Door	R Jamb
238	0.3 mg/cm2	Negative	3/8/2023	14:14:01	202301331	Interior	3-e	Wood	White	Intact	B	Center	Room	board
239	0.2 mg/cm2	Negative	3/8/2023	14:15:22	202301331	Interior	3f	Drywall	White	Intact	A	Center	Room	Wall
240	0.1 mg/cm2	Negative	3/8/2023	14:15:40	202301331	Interior	3f	Drywall	White	Intact	B	Center	Room	Wall
241	2.5 mg/cm2	Positive	3/8/2023	14:16:03	202301331	Interior	3f	Plaster	White	Intact	B	Right	Room	Wall
242	4 mg/cm2	Positive	3/8/2023	14:16:19	202301331	Interior	3f	Plaster	White	Intact	C	Center	Room	Wall
243	3.9 mg/cm2	Positive	3/8/2023	14:16:33	202301331	Interior	3f	Plaster	White	Intact	D	Center	Room	Wall
244	0.3 mg/cm2	Negative	3/8/2023	14:17:02	202301331	Interior	3f	Drywall	White	Intact	D	Right	Room	Wall
245	0.3 mg/cm2	Negative	3/8/2023	14:17:29	202301331	Interior	3f	Plaster	White	Intact	A	Center	Room	Ceiling
246	0.9 mg/cm2	Negative	3/8/2023	14:17:50	202301331	Interior	3f	Plaster	White	Intact	A	Right	Room	Wall
247	2.4 mg/cm2	Positive	3/8/2023	14:18:41	202301331	Interior	3f	Plaster	Gray	Intact	D	Right	Room	Baseboard
248	0.4 mg/cm2	Negative	3/8/2023	14:19:18	202301331	Interior	3f	Plaster	White	Intact	B	Center	Room	conduit

249	0.2 mg/cm2	Negative	3/8/2023	14:20:19	202301331	Interior	3f	Wood	Gray	Intact	C	Center	Door	Door
250	0.4 mg/cm2	Negative	3/8/2023	14:20:39	202301331	Interior	3f	Metal	Gray	Intact	C	Center	Door	R Casing
251	0.2 mg/cm2	Negative	3/8/2023	14:20:52	202301331	Interior	3f	Metal	Gray	Intact	C	Center	Door	R Jamb
252	1.7 mg/cm2	Positive	3/8/2023	14:21:18	202301331	Interior	3f	Concrete	Gray	Intact	C	Center	Room	Floor
253	0.3 mg/cm2	Negative	3/8/2023	14:21:47	202301331	Interior	3f	Wood	Gray	Intact	A	Center	Door	Door
254	0.4 mg/cm2	Negative	3/8/2023	14:22:09	202301331	Interior	3f	Metal	Gray	Intact	A	Center	Door	L casing
255	0.2 mg/cm2	Negative	3/8/2023	14:22:21	202301331	Interior	3f	Metal	Gray	Intact	A	Center	Door	L Jamb
256	6.1 mg/cm2	Positive	3/8/2023	14:23:13	202301331	Interior	3f	Concrete	Gray	Intact	A	Center	Stairs	Riser
257	0.8 mg/cm2	Negative	3/8/2023	14:23:26	202301331	Interior	3f	Concrete	Gray	Intact	A	Center	Stairs	Tread
258	0.7 mg/cm2	Negative	3/8/2023	14:24:01	202301331	Interior	3f	Wood	Gray	Intact	B	Center	Railing	Railing
259	0.2 mg/cm2	Negative	3/8/2023	14:24:21	202301331	Interior	3f	Wood	White	Intact	D	Center	Railing	Railing
260	0.3 mg/cm2	Negative	3/8/2023	14:24:55	202301331	Interior	3f	Metal	Gray	Intact	D	Right	Railing	Railing
261	0.7 mg/cm2	Negative	3/8/2023	14:26:36	202301331	Interior	3-g	Plaster	White	Intact	A	Center	Room	Wall
262	0.8 mg/cm2	Negative	3/8/2023	14:26:55	202301331	Interior	3-g	Plaster	White	Intact	B	Center	Room	Wall
263	0.4 mg/cm2	Negative	3/8/2023	14:27:22	202301331	Interior	3-g	Plaster	White	Intact	C	Center	Room	Wall
264	0.5 mg/cm2	Negative	3/8/2023	14:27:36	202301331	Interior	3-g	Plaster	White	Intact	D	Center	Room	Wall
265	0.1 mg/cm2	Negative	3/8/2023	14:28:03	202301331	Interior	3-g	Plaster	White	Intact	B	Right	Room	Wall
266	0.2 mg/cm2	Negative	3/8/2023	14:28:20	202301331	Interior	3-g	Plaster	White	Intact	C	Left	Room	Wall
267	0.6 mg/cm2	Negative	3/8/2023	14:28:50	202301331	Interior	3-g	Plaster	White	Intact	B	Center	Room	Ceiling
268	0 mg/cm2	Negative	3/8/2023	14:29:12	202301331	Interior	3-g	Metal	White	Intact	B	Center	Room	vent
269	0.3 mg/cm2	Negative	3/8/2023	14:29:38	202301331	Interior	3-g	Metal	White	Intact	A	Center	Room	vent
270	0.9 mg/cm2	Negative	3/8/2023	14:30:33	202301331	Interior	3-g	Metal	White	Intact	D	Center	Window	Part Bead
271	1 mg/cm2	Positive	3/8/2023	14:30:59	202301331	Interior	3-g	Metal	White	Intact	D	Center	Window	Sash
272	0.4 mg/cm2	Negative	3/8/2023	14:31:40	202301331	Interior	3-g	Wood	White	Intact	D	Center	Room	Baseboard
273	0.2 mg/cm2	Negative	3/8/2023	14:32:05	202301331	Interior	3-g	Wood	White	Intact	D	Center	Room	post
274	0.2 mg/cm2	Negative	3/8/2023	14:32:30	202301331	Interior	3-g	Wood	Stained	Intact	D	Center	Room	Floor
275	0.4 mg/cm2	Negative	3/8/2023	14:33:08	202301331	Interior	3-g	Wood	White	Intact	D	Center	Room	frame
276	0.2 mg/cm2	Negative	3/8/2023	14:33:23	202301331	Interior	3-g	Wood	White	Intact	D	Center	Room	bulletin board
277	0.6 mg/cm2	Negative	3/8/2023	14:34:01	202301331	Interior	3-g	stone	Black	Intact	A	Center	Room	blackboard
278	0.2 mg/cm2	Negative	3/8/2023	14:34:26	202301331	Interior	3-g	Metal	Offwhite	Intact	A	Center	Room	vent
279	0.1 mg/cm2	Negative	3/8/2023	14:34:57	202301331	Interior	3-g	Wood	Offwhite	Intact	C	Center	Room	Shelf
280	0 mg/cm2	Negative	3/8/2023	14:35:15	202301331	Interior	3-g	Wood	Offwhite	Intact	C	Center	Room	Shelf Support
281	0.4 mg/cm2	Negative	3/8/2023	14:35:52	202301331	Interior	3-g	Metal	Offwhite	Intact	C	Center	Room	conduit
282	0.3 mg/cm2	Negative	3/8/2023	14:36:42	202301331	Interior	3-g	Wood	Gray	Intact	B	Center	Door	Door
283	0.2 mg/cm2	Negative	3/8/2023	14:37:08	202301331	Interior	3-g	Wood	White	Intact	B	Center	Door	L casing
284	0.4 mg/cm2	Negative	3/8/2023	14:37:20	202301331	Interior	3-g	Wood	White	Intact	B	Center	Door	L Jamb
285	0.1 mg/cm2	Negative	3/8/2023	14:38:09	202301331	Interior	3-g	Wood	Blue	Intact	B	Center	Room	bulletin board
286	0.6 mg/cm2	Negative	3/8/2023	14:39:45	202301331	Interior	3-h	Plaster	White	Intact	A	Center	Room	Wall
287	0.4 mg/cm2	Negative	3/8/2023	14:40:06	202301331	Interior	3-h	Plaster	White	Intact	B	Center	Room	Wall
288	0.3 mg/cm2	Negative	3/8/2023	14:40:25	202301331	Interior	3-h	Drywall	White	Intact	C	Center	Room	Wall
289	0.4 mg/cm2	Negative	3/8/2023	14:40:55	202301331	Interior	3-h	Plaster	White	Intact	D	Center	Room	Wall
290	0.8 mg/cm2	Negative	3/8/2023	14:41:31	202301331	Interior	3-h	Plaster	White	Intact	D	Center	Room	Ceiling
291	0.6 mg/cm2	Negative	3/8/2023	14:42:02	202301331	Interior	3-h	Metal	White	Intact	D	Center	Room	vent
292	0.3 mg/cm2	Negative	3/8/2023	14:42:24	202301331	Interior	3-h	Wood	White	Intact	D	Center	Room	Crown Moulding
293	0.2 mg/cm2	Negative	3/8/2023	14:42:41	202301331	Interior	3-h	Wood	White	Intact	D	Center	Room	Baseboard
294	0.2 mg/cm2	Negative	3/8/2023	14:43:03	202301331	Interior	3-h	Wood	Stained	Intact	D	Center	Room	Floor
295	0.2 mg/cm2	Negative	3/8/2023	14:44:06	202301331	Interior	3-h	Wood	White	Intact	D	Center	Room	frame
296	0.6 mg/cm2	Negative	3/8/2023	14:44:27	202301331	Interior	3-h	Wood	Black	Intact	D	Center	Room	blackboard
297	0.1 mg/cm2	Negative	3/8/2023	14:44:56	202301331	Interior	3-h	Wood	Yellow	Intact	B	Center	Room	bulletin board
298	0.9 mg/cm2	Negative	3/8/2023	14:45:40	202301331	Interior	3-h	Metal	White	Intact	D	Center	Window	Part Bead
299	1.3 mg/cm2	Positive	3/8/2023	14:46:07	202301331	Interior	3-h	Metal	White	Intact	D	Center	Window	R Casing

300	0.9 mg/cm2	Negative	3/8/2023	15:34:28	Calibration										
301	0.9 mg/cm2	Negative	3/8/2023	15:34:43	Calibration										
302	0.9 mg/cm2	Negative	3/8/2023	15:34:58	Calibration										
303	0.1 mg/cm2	Negative	3/8/2023	15:35:13	Calibration										
304	0.1 mg/cm2	Negative	3/8/2023	15:35:20	Calibration										
305	0.1 mg/cm2	Negative	3/8/2023	15:35:26	Calibration										
306	0.4 mg/cm2	Negative	3/8/2023	15:36:35	202301331	Interior	3-i	Plaster	White	Intact	A	Center	Room	Wall	
307	0.5 mg/cm2	Negative	3/8/2023	15:36:52	202301331	Interior	3-i	Plaster	White	Intact	B	Center	Room	Wall	
308	0.3 mg/cm2	Negative	3/8/2023	15:37:12	202301331	Interior	3-i	Plaster	White	Intact	C	Center	Room	Wall	
309	0.7 mg/cm2	Negative	3/8/2023	15:37:25	202301331	Interior	3-i	Plaster	White	Intact	D	Center	Room	Wall	
310	0.3 mg/cm2	Negative	3/8/2023	15:37:48	202301331	Interior	3-i	Plaster	White	Intact	D	Left	Room	Wall	
311	0.3 mg/cm2	Negative	3/8/2023	15:38:05	202301331	Interior	3-i	Plaster	White	Intact	C	Right	Room	Wall	
312	0.3 mg/cm2	Negative	3/8/2023	15:38:27	202301331	Interior	3-i	Plaster	White	Intact	C	Center	Room	Ceiling	
313	0.1 mg/cm2	Negative	3/8/2023	15:39:06	202301331	Interior	3-i	Metal	White	Intact	C	Center	Room	vent	
314	0.2 mg/cm2	Negative	3/8/2023	15:39:27	202301331	Interior	3-i	Metal	White	Intact	C	Center	Room	panel	
315	0.2 mg/cm2	Negative	3/8/2023	15:40:03	202301331	Interior	3-i	Wood	White	Intact	C	Center	Room	frame	
316	0.7 mg/cm2	Negative	3/8/2023	15:40:39	202301331	Interior	3-i	stone	Black	Intact	C	Center	Room	blackboard	
317	0.4 mg/cm2	Negative	3/8/2023	15:41:23	202301331	Interior	3-i	Wood	White	Intact	C	Center	Room	bulletin board	
318	0.5 mg/cm2	Negative	3/8/2023	15:41:56	202301331	Interior	3-i	Metal	White	Intact	C	Center	Room	conduit	
319	0.4 mg/cm2	Negative	3/8/2023	15:42:39	202301331	Interior	3-i	Wood	White	Intact	C	Center	Room	Baseboard	
320	0.2 mg/cm2	Negative	3/8/2023	15:42:59	202301331	Interior	3-i	Wood	Stained	Intact	C	Center	Room	Floor	
321	0.2 mg/cm2	Negative	3/8/2023	15:43:47	202301331	Interior	3-i	Wood	Gray	Intact	C	Center	Door	Door	
322	0.3 mg/cm2	Negative	3/8/2023	15:44:06	202301331	Interior	3-i	Wood	White	Intact	C	Center	Door	L casing	
323	0.2 mg/cm2	Negative	3/8/2023	15:44:18	202301331	Interior	3-i	Wood	White	Intact	C	Center	Door	L Jamb	
324	0.3 mg/cm2	Negative	3/8/2023	15:44:39	202301331	Interior	3-i	Wood	White	Intact	A	Center	Closet	Door	
325	0.1 mg/cm2	Negative	3/8/2023	15:45:00	202301331	Interior	3-i	Wood	Stained	Intact	A	Center	Closet	Shelf	
326	0.1 mg/cm2	Negative	3/8/2023	15:45:12	202301331	Interior	3-i	Wood	Stained	Intact	A	Center	Closet	Shelf Support	
327	0.5 mg/cm2	Negative	3/8/2023	15:46:57	202301331	Interior	3-j	Plaster	White	Intact	A	Center	Room	Wall	
328	0.3 mg/cm2	Negative	3/8/2023	15:47:16	202301331	Interior	3-j	Plaster	White	Intact	B	Center	Room	Wall	
329	0.4 mg/cm2	Negative	3/8/2023	15:47:50	202301331	Interior	3-j	Plaster	White	Intact	C	Center	Room	Wall	
330	0.7 mg/cm2	Negative	3/8/2023	15:48:24	202301331	Interior	3-j	Plaster	White	Intact	D	Center	Room	Wall	
331	0.4 mg/cm2	Negative	3/8/2023	15:49:15	202301331	Interior	3-j	Plaster	White	Intact	C	Center	Room	Ceiling	
332	0 mg/cm2	Negative	3/8/2023	15:49:53	202301331	Interior	3-j	Metal	White	Intact	C	Center	Room	vent	
333	0.4 mg/cm2	Negative	3/8/2023	15:50:28	202301331	Interior	3-j	Wood	White	Intact	C	Center	Room	Crown Moulding	
334	0.1 mg/cm2	Negative	3/8/2023	15:50:44	202301331	Interior	3-j	Wood	White	Intact	C	Center	Room	Baseboard	
335	0.3 mg/cm2	Negative	3/8/2023	15:51:05	202301331	Interior	3-j	Wood	Stained	Intact	C	Center	Room	Floor	
336	0.3 mg/cm2	Negative	3/8/2023	15:52:11	202301331	Interior	3-j	Wood	Gray	Intact	C	Right	Door	Door	
337	0.2 mg/cm2	Negative	3/8/2023	15:52:28	202301331	Interior	3-j	Wood	White	Intact	C	Right	Door	R Casing	
338	0.3 mg/cm2	Negative	3/8/2023	15:52:40	202301331	Interior	3-j	Wood	White	Intact	C	Right	Door	R Jamb	
339	0.4 mg/cm2	Negative	3/8/2023	15:54:52	202301331	Interior	3-j	Wood	White	Intact	D	Right	Door	L casing	
340	0.2 mg/cm2	Negative	3/8/2023	15:55:18	202301331	Interior	3-j	Wood	White	Intact	D	Right	Door	L Jamb	
341	0.4 mg/cm2	Negative	3/8/2023	15:56:16	202301331	Interior	3-j	Wood	White	Intact	C	Right	Room	frame	
342	0.3 mg/cm2	Negative	3/8/2023	15:56:29	202301331	Interior	3-j	Wood	White	Intact	C	Right	Room	bulletin board	
343	0.1 mg/cm2	Negative	3/8/2023	15:56:47	202301331	Interior	3-j	stone	Black	Intact	C	Right	Room	bulletin board	
344	0.4 mg/cm2	Negative	3/8/2023	15:57:08	202301331	Interior	3-j	Metal	White	Intact	C	Right	Room	conduit	
345	0.2 mg/cm2	Negative	3/8/2023	15:58:01	202301331	Interior	3-j	Wood	Blue	Intact	B	Center	Room	bulletin board	
346	0.2 mg/cm2	Negative	3/8/2023	15:58:37	202301331	Interior	3-j	Wood	White	Intact	C	Center	Closet	Door	
347	0.1 mg/cm2	Negative	3/8/2023	15:59:04	202301331	Interior	3-j	Wood	Stained	Intact	C	Center	Closet	Shelf	
348	0.2 mg/cm2	Negative	3/8/2023	15:59:17	202301331	Interior	3-j	Wood	Stained	Intact	C	Center	Closet	Shelf Support	
349	0.4 mg/cm2	Negative	3/8/2023	15:59:58	202301331	Interior	3-j	Metal	White	Intact	C	Center	Room	panel	
350	1.8 mg/cm2	Positive	3/8/2023	16:00:54	202301331	Interior	3-k	Plaster	Various	Intact	A	Center	Room	Wall	

351	3.3 mg/cm2	Positive	3/8/2023	16:01:19	202301331	Interior	3-k	Plaster	Various	Intact	B	Center	Room	Wall
352	4.3 mg/cm2	Positive	3/8/2023	16:01:36	202301331	Interior	3-k	Plaster	Various	Intact	C	Center	Room	Wall
353	4.1 mg/cm2	Positive	3/8/2023	16:02:27	202301331	Interior	3-k	Plaster	White	Intact	D	Center	Room	Wall
354	3.2 mg/cm2	Positive	3/8/2023	16:03:25	202301331	Interior	3-k	Plaster	White	Intact	C	Center	Room	Ceiling
355	0.3 mg/cm2	Negative	3/8/2023	16:04:34	202301331	Interior	3-k	Wood	Gray	Intact	A	Left	Closet	Door
356	0.2 mg/cm2	Negative	3/8/2023	16:04:52	202301331	Interior	3-k	Wood	Gray	Intact	A	Left	Closet	R Casing
357	0.3 mg/cm2	Negative	3/8/2023	16:05:10	202301331	Interior	3-k	Wood	Gray	Intact	A	Left	Closet	R Jamb
358	0.1 mg/cm2	Negative	3/8/2023	16:06:29	202301331	Interior	3-k	Wood	Gray	Intact	A	Center	Door	Door
359	0.5 mg/cm2	Negative	3/8/2023	16:06:49	202301331	Interior	3-k	Wood	Gray	Intact	A	Center	Door	L casing
360	0.5 mg/cm2	Negative	3/8/2023	16:07:05	202301331	Interior	3-k	Wood	Offwhite	Intact	A	Center	Door	L Jamb
361	0.2 mg/cm2	Negative	3/8/2023	16:07:45	202301331	Interior	3-k	Wood	Gray	Intact	B	Center	Door	Door
362	0.4 mg/cm2	Negative	3/8/2023	16:08:02	202301331	Interior	3-k	Wood	Gray	Intact	B	Left	Door	R Casing
363	0.3 mg/cm2	Negative	3/8/2023	16:08:31	202301331	Interior	3-k	Wood	White	Intact	B	Left	Door	R Jamb
364	0.1 mg/cm2	Negative	3/8/2023	16:09:15	202301331	Interior	3-k	Wood	White	Intact	C	Left	Room	Chair Rail
365	0.6 mg/cm2	Negative	3/8/2023	16:09:25	202301331	Interior	3-k	Wood	White	Intact	C	Left	Room	Chair Rail
366	2.2 mg/cm2	Positive	3/8/2023	16:09:48	202301331	Interior	3-k	Wood	Gray	Intact	C	Left	Room	Baseboard
367	0.4 mg/cm2	Negative	3/8/2023	16:10:27	202301331	Interior	3-k	Wood	White	Intact	C	Center	Room	frame
368	0.5 mg/cm2	Negative	3/8/2023	16:10:59	202301331	Interior	3-k	Wood	Various	Intact	C	Center	Room	bulletin board
369	0.5 mg/cm2	Negative	3/8/2023	16:11:28	202301331	Interior	3-k	Wood	Various	Intact	C	Center	Room	bulletin board
370	1.3 mg/cm2	Positive	3/8/2023	16:15:53	202301331	Exterior	school	Stucco	White	Intact	C	Center	Exterior	Wall
371	0.2 mg/cm2	Negative	3/8/2023	16:16:39	202301331	Exterior	school	Stucco	Yellow	Intact	A	Right	Exterior	Wall
372	1.2 mg/cm2	Positive	3/8/2023	16:17:05	202301331	Exterior	school	Stucco	Red	Intact	A	Right	Window	Sill
373	0.6 mg/cm2	Negative	3/8/2023	16:17:57	202301331	Exterior	school	Stucco	Red	Intact	A	Left	Window	Sill
374	0.2 mg/cm2	Negative	3/8/2023	16:18:36	202301331	Exterior	school	Metal	Green	Intact	A	Center	Door	Door
375	0.2 mg/cm2	Negative	3/8/2023	16:18:53	202301331	Exterior	school	Metal	Green	Intact	A	Center	Door	R Casing
376	0.2 mg/cm2	Negative	3/8/2023	16:19:17	202301331	Exterior	school	Metal	Gray	Intact	A	Center	Door	R Jamb
377	0.2 mg/cm2	Negative	3/8/2023	16:19:59	202301331	Exterior	school	Metal	Green	Intact	A	Right	Door	Door
378	0.2 mg/cm2	Negative	3/8/2023	16:20:12	202301331	Exterior	school	Metal	Green	Intact	A	Right	Door	R Casing
379	0.2 mg/cm2	Negative	3/8/2023	16:20:48	202301331	Exterior	school	Concrete	Yellow	Intact	A	Right	Exterior	Foundation
380	0.6 mg/cm2	Negative	3/8/2023	16:22:03	202301331	Exterior	school	Stucco	Yellow	Intact	B	Center	Exterior	Wall
381	0.3 mg/cm2	Negative	3/8/2023	16:22:41	202301331	Exterior	school	Stucco	Red	Intact	B	Right	Window	Sill
382	0.2 mg/cm2	Negative	3/8/2023	16:23:10	202301331	Exterior	school	Wood	Red	Intact	B	Center	Door	Door
383	0.2 mg/cm2	Negative	3/8/2023	16:23:25	202301331	Exterior	school	Wood	Red	Intact	B	Center	Door	R Casing
384	0.6 mg/cm2	Negative	3/8/2023	16:24:15	202301331	Exterior	school	Metal	Yellow	Intact	B	Center	Exterior	Pipe
385	0.7 mg/cm2	Negative	3/8/2023	16:24:40	202301331	Exterior	school	Metal	Yellow	Intact	B	Left	Exterior	Pipe
386	6.5 mg/cm2	Positive	3/8/2023	16:25:50	202301331	Exterior	school	Metal	Red	Intact	B	Left	Railing	Railing
387	0.2 mg/cm2	Negative	3/8/2023	16:26:35	202301331	Exterior	school	Metal	Brown	Intact	C	Right	Railing	Railing
388	0.4 mg/cm2	Negative	3/8/2023	16:27:06	202301331	Exterior	school	Stucco	Red	Intact	C	Center	Railing	Railing
389	0.4 mg/cm2	Negative	3/8/2023	16:27:49	202301331	Exterior	school	Stucco	Yellow	Intact	C	Center	Exterior	column
390	0.3 mg/cm2	Negative	3/8/2023	16:28:31	202301331	Exterior	school	Metal	Brown	Intact	C	Right	Door	Door
391	0.5 mg/cm2	Negative	3/8/2023	16:28:44	202301331	Exterior	school	Metal	Brown	Intact	C	Right	Door	R Casing
392	0.1 mg/cm2	Negative	3/8/2023	16:29:34	202301331	Exterior	school	Stucco	Offwhite	Intact	C	Center	Exterior	Wall
393	0.1 mg/cm2	Negative	3/8/2023	16:30:47	202301331	Exterior	school	Metal	Gray	Intact	C	Center	Exterior	Pipe
394	0.2 mg/cm2	Negative	3/8/2023	16:32:10	202301331	Exterior	school	Metal	White	Intact	C	Center	Exterior	drinking fountain
395	0.7 mg/cm2	Negative	3/8/2023	16:33:17	202301331	Exterior	school	Stucco	Yellow	Intact	D	Center	Exterior	Wall
396	16.5 mg/cm2	Positive	3/8/2023	16:36:36	202301331	Exterior	school	Wood	Gray	Intact	D	Right	Window	Sill
397	6.5 mg/cm2	Positive	3/8/2023	16:36:55	202301331	Exterior	school	Wood	Gray	Intact	D	Right	Window	Part Bead
398	2 mg/cm2	Positive	3/8/2023	16:37:15	202301331	Exterior	school	Wood	Gray	Intact	D	Right	Window	L Jamb
399	10.6 mg/cm2	Positive	3/8/2023	16:38:25	202301331	Exterior	school	Metal	Green	Intact	C	Right	Railing	Railing
400	0.5 mg/cm2	Negative	3/8/2023	16:38:59	202301331	Exterior	school	Concrete	Gray	Intact	C	Left	Stairs	Riser
401	0.4 mg/cm2	Negative	3/8/2023	16:39:12	202301331	Exterior	school	Concrete	Gray	Intact	C	Left	Stairs	Tread

Company Viken Detection
 Model Pb200i
 Instrument XRF Lead Paint Analyzer
 Serial Num 2627
 App Versio Pb200i-4.1-11

XRF 4 /c /data /202301331 /ATCA

Reading #	Concentrat Units	Result	Action Lev	Date	Time	User	Mode	Analytic M-	Job Id	Job name	Interior/exte	Room	Substrate	Color	Condition	Wall	Location	Component
1	0.9 mg/cm2	Negative	1	3/10/2023	11:13:27	Fiberquant	Action Lev	Lead	Paint		Calibration				Intact			
2	1 mg/cm2	Positive	1	3/10/2023	11:13:42	Fiberquant	Action Lev	Lead	Paint		Calibration				Intact			
3	0.9 mg/cm2	Negative	1	3/10/2023	11:14:03	Fiberquant	Action Lev	Lead	Paint		Calibration				Intact			
4	0.5 mg/cm2	Negative	1	3/10/2023	11:43:44	Fiberquant	Action Lev	Lead	Paint		Exterior	Exterior	Metal	Beige	Intact	A	Left	Doorjamb
5	0.2 mg/cm2	Negative	1	3/10/2023	11:43:51	Fiberquant	Action Lev	Lead	Paint		Exterior	Exterior	Metal	Beige	Intact	A	Left	Door
6	0.1 mg/cm2	Negative	1	3/10/2023	11:44:07	Fiberquant	Action Lev	Lead	Paint		Exterior	Exterior	Stucco	Beige	Intact	A	Left	Wall
7	0.2 mg/cm2	Negative	1	3/10/2023	11:45:23	Fiberquant	Action Lev	Lead	Paint		Exterior	Exterior	Metal	Brown	Intact	A	Left	Door
8	0.4 mg/cm2	Negative	1	3/10/2023	11:45:30	Fiberquant	Action Lev	Lead	Paint		Exterior	Exterior	Stucco	Beige	Intact	B	Center	Wall
9	0.2 mg/cm2	Negative	1	3/10/2023	11:46:29	Fiberquant	Action Lev	Lead	Paint		Interior	Room A	Brick	White	Intact	A	Right	Wall
10	0.5 mg/cm2	Negative	1	3/10/2023	11:46:37	Fiberquant	Action Lev	Lead	Paint		Interior	Room A	Metal	Brown	Intact	A	Right	Doorjamb
11	0.2 mg/cm2	Negative	1	3/10/2023	11:46:44	Fiberquant	Action Lev	Lead	Paint		Interior	Room A	Metal	Brown	Intact	A	Right	Door
12	0.3 mg/cm2	Negative	1	3/10/2023	11:47:04	Fiberquant	Action Lev	Lead	Paint		Interior	Room A	Drywall	White	Intact	B	Right	Wall
13	0.2 mg/cm2	Negative	1	3/10/2023	11:47:13	Fiberquant	Action Lev	Lead	Paint		Interior	Room A	Brick	White	Intact	B	Right	Wall
14	0.5 mg/cm2	Negative	1	3/10/2023	11:47:32	Fiberquant	Action Lev	Lead	Paint		Interior	Room A	Metal	Brown	Intact	C	Right	Doorjamb
15	0.1 mg/cm2	Negative	1	3/10/2023	11:47:40	Fiberquant	Action Lev	Lead	Paint		Interior	Room A	Metal	Brown	Intact	C	Right	Door
16	0.1 mg/cm2	Negative	1	3/10/2023	11:47:50	Fiberquant	Action Lev	Lead	Paint		Interior	Room A	Brick	White	Intact	C	Right	Wall
17	0.1 mg/cm2	Negative	1	3/10/2023	11:49:42	Fiberquant	Action Lev	Lead	Paint		Interior	Room A	Brick	White	Intact	D	Center	Wall
18	0.5 mg/cm2	Negative	1	3/10/2023	11:49:49	Fiberquant	Action Lev	Lead	Paint		Interior	Room B	Brick	White	Intact	A	Left	Wall
19	0.2 mg/cm2	Negative	1	3/10/2023	11:49:56	Fiberquant	Action Lev	Lead	Paint		Interior	Room B	Metal	Brown	Intact	A	Left	Doorjamb
20	0.1 mg/cm2	Negative	1	3/10/2023	11:50:06	Fiberquant	Action Lev	Lead	Paint		Interior	Room B	Metal	Brown	Intact	A	Left	Door
21	11.1 mg/cm2	Positive	1	3/10/2023	11:50:14	Fiberquant	Action Lev	Lead	Paint		Interior	Room B	Metal	Brown	Intact	A	Center	Handrail
22	0.1 mg/cm2	Negative	1	3/10/2023	11:50:33	Fiberquant	Action Lev	Lead	Paint		Interior	Room B	Brick	White	Intact	B	Center	Wall
23	0 mg/cm2	Negative	1	3/10/2023	11:50:40	Fiberquant	Action Lev	Lead	Paint		Interior	Room B	Brick	White	Intact	C	Left	Wall
24	0.1 mg/cm2	Negative	1	3/10/2023	11:50:50	Fiberquant	Action Lev	Lead	Paint		Interior	Room B	Brick	White	Intact	D	Right	Wall
25	0.1 mg/cm2	Negative	1	3/10/2023	11:50:56	Fiberquant	Action Lev	Lead	Paint		Interior	Room B	Fiberboard	White	Intact	D	Right	Ceiling
26	0.2 mg/cm2	Negative	1	3/10/2023	11:51:24	Fiberquant	Action Lev	Lead	Paint		Interior	Room C	Fiberboard	White	Intact	A	Left	Ceiling
27	0.5 mg/cm2	Negative	1	3/10/2023	11:51:31	Fiberquant	Action Lev	Lead	Paint		Interior	Room C	Metal	Brown	Intact	A	Left	Doorjamb
28	0.2 mg/cm2	Negative	1	3/10/2023	11:51:40	Fiberquant	Action Lev	Lead	Paint		Interior	Room C	Metal	Brown	Intact	A	Left	Door
29	0.1 mg/cm2	Negative	1	3/10/2023	11:51:48	Fiberquant	Action Lev	Lead	Paint		Interior	Room C	Brick	White	Intact	A	Left	Wall
30	0.9 mg/cm2	Negative	1	3/10/2023	11:52:22	Fiberquant	Action Lev	Lead	Paint		Interior	Room C	Drywall	Orange	Intact	B	Center	Wall
31	0.3 mg/cm2	Negative	1	3/10/2023	11:52:44	Fiberquant	Action Lev	Lead	Paint		Interior	Room C	Drywall	White	Intact	C	Right	Wall
32	0.3 mg/cm2	Negative	1	3/10/2023	11:52:52	Fiberquant	Action Lev	Lead	Paint		Interior	Room C	Brick	White	Intact	D	Left	Wall
33	0.3 mg/cm2	Negative	1	3/10/2023	11:52:59	Fiberquant	Action Lev	Lead	Paint		Interior	Room C	Drywall	White	Intact	D	Left	Ceiling
34	0.3 mg/cm2	Negative	1	3/10/2023	11:53:16	Fiberquant	Action Lev	Lead	Paint		Interior	Room C	Fiberboard	White	Intact	D	Left	Ceiling
35	0.3 mg/cm2	Negative	1	3/10/2023	11:53:23	Fiberquant	Action Lev	Lead	Paint		Interior	Room C	Wood	Stained	Intact	C	Center	Cabinet
36	0.2 mg/cm2	Negative	1	3/10/2023	11:54:04	Fiberquant	Action Lev	Lead	Paint		Interior	Room C	Brick	White	Intact	A	Left	Wall
37	12.5 mg/cm2	Positive	1	3/10/2023	11:54:19	Fiberquant	Action Lev	Lead	Paint		Interior	Room D	Metal	Brown	Intact	A	Left	Ladder
38	0.6 mg/cm2	Negative	1	3/10/2023	11:54:38	Fiberquant	Action Lev	Lead	Paint		Interior	Room D	Drywall	White	Intact	A	Left	Ceiling
39	0 mg/cm2	Negative	1	3/10/2023	11:54:45	Fiberquant	Action Lev	Lead	Paint		Interior	Room D	Fiberboard	White	Intact	A	Left	Ceiling
40	0.3 mg/cm2	Negative	1	3/10/2023	11:54:54	Fiberquant	Action Lev	Lead	Paint		Interior	Room D	Metal	White	Intact	A	Left	Pipe
41	0.4 mg/cm2	Negative	1	3/10/2023	11:55:01	Fiberquant	Action Lev	Lead	Paint		Interior	Room D	Metal	Brown	Intact	D	Right	Doorjamb
42	0.2 mg/cm2	Negative	1	3/10/2023	11:55:08	Fiberquant	Action Lev	Lead	Paint		Interior	Room D	Metal	Brown	Intact	D	Right	Door
43	0.2 mg/cm2	Negative	1	3/10/2023	11:55:16	Fiberquant	Action Lev	Lead	Paint		Interior	Room D	Metal	White	Intact	D	Right	Pipe
44	0.3 mg/cm2	Negative	1	3/10/2023	11:56:11	Fiberquant	Action Lev	Lead	Paint		Interior	Room D	Brick	White	Intact	D	Right	Wall
45	0.1 mg/cm2	Negative	1	3/10/2023	11:56:19	Fiberquant	Action Lev	Lead	Paint		Interior	Room D	Wood	White	Intact	D	Right	Panel
46	0.1 mg/cm2	Negative	1	3/10/2023	11:56:41	Fiberquant	Action Lev	Lead	Paint		Interior	Room D	Brick	White	Intact	C	Center	Wall
47	0.1 mg/cm2	Negative	1	3/10/2023	11:56:47	Fiberquant	Action Lev	Lead	Paint		Interior	Room D	Drywall	White	Intact	B	Left	Wall
48	0.4 mg/cm2	Negative	1	3/10/2023	11:57:09	Fiberquant	Action Lev	Lead	Paint		Interior	Room E	Drywall	White	Intact	A	Right	Wall

49	0.2 mg/cm2	Negative	1	3/10/2023	11:57:16	Fiberquant Action Levi Lead Paint	Interior	Room E	Drywall	White	Intact	A	Right	Ceiling
50	0.2 mg/cm2	Negative	1	3/10/2023	11:57:27	Fiberquant Action Levi Lead Paint	Interior	Room E	Drywall	White	Intact	B	Right	Wall
51	0.2 mg/cm2	Negative	1	3/10/2023	11:57:34	Fiberquant Action Levi Lead Paint	Interior	Room E	Metal	Brown	Intact	B	Right	Doorjamb
52	0.2 mg/cm2	Negative	1	3/10/2023	11:57:42	Fiberquant Action Levi Lead Paint	Interior	Room E	Metal	Brown	Intact	B	Right	Door
53	0.2 mg/cm2	Negative	1	3/10/2023	11:58:03	Fiberquant Action Levi Lead Paint	Interior	Room E	Drywall	White	Intact	C	Center	Wall
54	0.2 mg/cm2	Negative	1	3/10/2023	11:58:11	Fiberquant Action Levi Lead Paint	Interior	Room E	Drywall	White	Intact	D	Center	Wall
55	0.1 mg/cm2	Negative	1	3/10/2023	11:58:18	Fiberquant Action Levi Lead Paint	Interior	Room F	Metal	Brown	Intact	A	Right	Doorjamb
56	0.5 mg/cm2	Negative	1	3/10/2023	11:58:26	Fiberquant Action Levi Lead Paint	Interior	Room F	Metal	Brown	Intact	A	Right	Door
57	0.5 mg/cm2	Negative	1	3/10/2023	11:58:45	Fiberquant Action Levi Lead Paint	Interior	Room F	Brick	White	Intact	A	Right	Wall
58	0.1 mg/cm2	Negative	1	3/10/2023	11:58:53	Fiberquant Action Levi Lead Paint	Interior	Room F	Brick	White	Intact	B	Center	Wall
59	0.6 mg/cm2	Negative	1	3/10/2023	11:59:03	Fiberquant Action Levi Lead Paint	Interior	Room F	Metal	White	Intact	B	Right	Pipe
60	0.1 mg/cm2	Negative	1	3/10/2023	11:59:11	Fiberquant Action Levi Lead Paint	Interior	Room F	Drywall	White	Intact	C	Left	Wall
61	0.5 mg/cm2	Negative	1	3/10/2023	11:59:23	Fiberquant Action Levi Lead Paint	Interior	Room F	Fiberboard	White	Intact	C	Left	Ceiling
62	0 mg/cm2	Negative	1	3/10/2023	11:59:30	Fiberquant Action Levi Lead Paint	Interior	Room F	Brick	White	Intact	D	Right	Wall
63	0.2 mg/cm2	Negative	1	3/10/2023	11:59:40	Fiberquant Action Levi Lead Paint	Interior	Room F	Metal	White	Intact	D	Right	Duct
64	11.7 mg/cm2	Positive	1	3/10/2023	11:59:48	Fiberquant Action Levi Lead Paint	Interior	Room F	Metal	Brown	Intact	D	Right	Ladder
65	0.2 mg/cm2	Negative	1	3/10/2023	12:00:16	Fiberquant Action Levi Lead Paint	Interior	Room G	Brick	White	Intact	A	Center	Wall
66	0.1 mg/cm2	Negative	1	3/10/2023	12:00:25	Fiberquant Action Levi Lead Paint	Interior	Room G	Brick	White	Intact	D	Right	Wall
67	0.2 mg/cm2	Negative	1	3/10/2023	12:00:34	Fiberquant Action Levi Lead Paint	Interior	Room G	Drywall	White	Intact	B	Left	Wall
68	0.1 mg/cm2	Negative	1	3/10/2023	12:00:41	Fiberquant Action Levi Lead Paint	Interior	Room G	Drywall	White	Intact	C	Left	Wall
69	0.2 mg/cm2	Negative	1	3/10/2023	12:00:51	Fiberquant Action Levi Lead Paint	Interior	Room G	Fiberboard	White	Intact	C	Center	Ceiling
70	0.3 mg/cm2	Negative	1	3/10/2023	12:00:59	Fiberquant Action Levi Lead Paint	Interior	Room G	Metal	Brown	Intact	A	Left	Doorjamb
71	0.5 mg/cm2	Negative	1	3/10/2023	12:01:44	Fiberquant Action Levi Lead Paint	Interior	Room G	Metal	Brown	Intact	A	Left	Door
72	5.2 mg/cm2	Positive	1	3/10/2023	12:01:59	Fiberquant Action Levi Lead Paint	Interior	Room H	Ceramic	Yellow	Intact	A	Left	Wall
73	5.6 mg/cm2	Positive	1	3/10/2023	12:02:06	Fiberquant Action Levi Lead Paint	Interior	Room H	Ceramic	Orange	Intact	B	Center	Wall
74	5.1 mg/cm2	Positive	1	3/10/2023	12:02:14	Fiberquant Action Levi Lead Paint	Interior	Room H	Ceramic	Yellow	Intact	C	Center	Wall
75	5.5 mg/cm2	Positive	1	3/10/2023	12:02:22	Fiberquant Action Levi Lead Paint	Interior	Room H	Ceramic	Yellow	Intact	D	Right	Wall
76	0.4 mg/cm2	Negative	1	3/10/2023	12:02:33	Fiberquant Action Levi Lead Paint	Interior	Room H	Drywall	White	Intact	D	Right	Ceiling
77	0.6 mg/cm2	Negative	1	3/10/2023	12:02:51	Fiberquant Action Levi Lead Paint	Interior	Room H	Metal	Brown	Intact	D	Right	Doorjamb
78	0.1 mg/cm2	Negative	1	3/10/2023	12:02:59	Fiberquant Action Levi Lead Paint	Interior	Room H	Metal	Brown	Intact	D	Right	Door
79	0.2 mg/cm2	Negative	1	3/10/2023	12:03:18	Fiberquant Action Levi Lead Paint	Interior	Room I	Brick	White	Intact	A	Center	Wall
80	0.3 mg/cm2	Negative	1	3/10/2023	12:03:25	Fiberquant Action Levi Lead Paint	Interior	Room I	Brick	White	Intact	B	Right	Wall
81	0.1 mg/cm2	Negative	1	3/10/2023	12:03:36	Fiberquant Action Levi Lead Paint	Interior	Room I	Brick	White	Intact	D	Right	Wall
82	0.1 mg/cm2	Negative	1	3/10/2023	12:03:44	Fiberquant Action Levi Lead Paint	Interior	Room I	Drywall	White	Intact	C	Center	Wall
83	0.5 mg/cm2	Negative	1	3/10/2023	12:03:59	Fiberquant Action Levi Lead Paint	Interior	Room I	Drywall	White	Intact	C	Left	Ceiling
84	0.5 mg/cm2	Negative	1	3/10/2023	12:04:07	Fiberquant Action Levi Lead Paint	Interior	Room I	Metal	Brown	Intact	A	Center	Doorjamb
85	0.2 mg/cm2	Negative	1	3/10/2023	12:04:14	Fiberquant Action Levi Lead Paint	Interior	Room I	Metal	Brown	Intact	A	Center	Door
86	0 mg/cm2	Negative	1	3/10/2023	12:04:21	Fiberquant Action Levi Lead Paint	Interior	Room I	Wood	White	Intact	A	Right	Pipe
87	0.3 mg/cm2	Negative	1	3/10/2023	12:04:31	Fiberquant Action Levi Lead Paint	Interior	Room J	Metal	Brown	Intact	B	Left	Doorjamb
88	0.2 mg/cm2	Negative	1	3/10/2023	12:04:41	Fiberquant Action Levi Lead Paint	Interior	Room J	Metal	Brown	Intact	B	Left	Door
89	0.2 mg/cm2	Negative	1	3/10/2023	12:04:49	Fiberquant Action Levi Lead Paint	Interior	Room J	Drywall	White	Intact	B	Left	Ceiling
90	6.7 mg/cm2	Positive	1	3/10/2023	12:04:56	Fiberquant Action Levi Lead Paint	Interior	Room J	Ceramic	Yellow	Intact	B	Left	Wall
91	6.7 mg/cm2	Positive	1	3/10/2023	12:05:05	Fiberquant Action Levi Lead Paint	Interior	Room J	Ceramic	Yellow	Intact	A	Center	Wall
92	4.9 mg/cm2	Positive	1	3/10/2023	12:05:12	Fiberquant Action Levi Lead Paint	Interior	Room J	Ceramic	Yellow	Intact	C	Right	Wall
93	5.7 mg/cm2	Positive	1	3/10/2023	12:05:21	Fiberquant Action Levi Lead Paint	Interior	Room J	Ceramic	Orange	Intact	D	Center	Wall
94	0.3 mg/cm2	Negative	1	3/10/2023	12:05:29	Fiberquant Action Levi Lead Paint	Interior	Room A	Drywall	White	Intact	C	Left	Ceiling
95	0.2 mg/cm2	Negative	1	3/10/2023	12:05:37	Fiberquant Action Levi Lead Paint	Interior	Room A	Fiberboard	White	Intact	C	Left	Ceiling
96	11.3 mg/cm2	Positive	1	3/10/2023	12:06:00	Fiberquant Action Levi Lead Paint	Interior	Room A	Metal	Brown	Intact	B	Left	Handrail
97	0.9 mg/cm2	Negative	1	3/10/2023	12:09:16	Fiberquant Action Levi Lead Paint	Calibration				Intact			
98	0.9 mg/cm2	Negative	1	3/10/2023	12:09:32	Fiberquant Action Levi Lead Paint	Calibration				Intact			
99	1 mg/cm2	Negative	1	3/10/2023	12:09:55	Fiberquant Action Levi Lead Paint	Calibration				Intact			




Figure 5
Property Features Map



Phase I Environmental Site Assessment
Miami Unified School District Property;
912 W. Rose Road; Miami, Arizona



Not to Scale


— — — — — Underground Drainage Pipes

APPENDIX E
FIGURES



USGS TOPO MAP, INSPIRATION & GLOBE, AZ QUADS, 2021

SITE VICINITY MAP
 INSPIRATION SCHOOL
 912 W. ROSE ROAD
 MIAMI, AZ

PROJECT NUMBER: 1052000242	DATE: 3/10/23	FIGURE
APPROVED BY: TH	DRAWN BY: BK	1
 9185 S. Farmer Ave., Ste. #111 Tempe, Arizona 85284-2912 Ph: (480) 894-2056 *** Fax: (480) 894-2497		




LEGEND

--- UNDERGROUND DRAINAGE PIPES

NOT TO SCALE
NOTE: ALL LOCATIONS ARE APPROXIMATE




SITE PLAN
NORTHWEST BUILDING & SOUTHEAST BUILDING
 INSPIRATION SCHOOL
 912 W. ROSE ROAD
 MIAMI, AZ

PROJECT NUMBER: 1052000242-5	DATE: 3/2/23	FIGURE
APPROVED BY: TH	DRAWN BY: BK	2
		
9185 S. Farmer Ave., Ste. #111 Tempe, Arizona 85284-2912 *** Ph: (480) 894-2056 Fax: (480) 894-2497		

D

A



B

C

LEGEND


- LEAD STUCCO (~1 S.F.)
- LEAD WOOD (~1 S.F.)
- LEAD PLASTER (~1 S.F.)
- LEAD VINYL (~1 S.F.)
- LEAD CONCRETE (~1 S.F.)
- LEAD METAL (~1 S.F.)

NOT TO SCALE
NOTE: ALL LOCATIONS ARE APPROXIMATE

LEAD LOCATION MAP
NORTHWEST BUILDING - FIRST FLOOR
 INSPIRATION SCHOOL
 912 W. ROSE ROAD
 MIAMI, AZ


PROJECT NUMBER: 1052000242-5	DATE: 6/7/23	FIGURE
APPROVED BY: TH	DRAWN BY: BK	2


ATLAS
 9185 S. Farmer Ave., Ste. #111
 Tempe, Arizona 85284-2912
 Ph: (480) 894-2056 *** Fax: (480) 894-2497



NOT TO SCALE
NOTE: ALL LOCATIONS ARE APPROXIMATE


LEGEND

-  LEAD WOOD (~1 S.F.)
-  LEAD PLASTER (~1 S.F.)
-  LEAD DRYWALL (~1 S.F.)
-  LEAD CONCRETE (~1 S.F.)



LEAD LOCATION MAP
NORTHWEST BUILDING - SECOND FLOOR
 INSPIRATION SCHOOL
 912 W. ROSE ROAD
 MIAMI, AZ

PROJECT NUMBER: 1052000242-5
 APPROVED BY: TH
 DATE: 6/7/23
 DRAWN BY: BK
ATLAS
 9185 S. Farmer Ave., Ste. #111
 Tempe, Arizona 85284-2912
 Ph: (480) 894-2056 *** Fax: (480) 894-2497
FIGURE 3




NOT TO SCALE
NOTE: ALL LOCATIONS ARE APPROXIMATE

LEGEND

— LEAD WOOD (~1 S.F.)

— LEAD PLASTER (~1 S.F.)

D



C


A

B



LEAD LOCATION MAP
NORTHWEST BUILDING - THIRD FLOOR
 INSPIRATION SCHOOL
 912 W. ROSE ROAD
 MIAMI, AZ


PROJECT NUMBER: 1052000242-5	DATE: 6/7/23	FIGURE
APPROVED BY: TH	DRAWN BY: BK	4

ATLAS 9185 S. Farmer Ave., Ste. #111
 Tempe, Arizona 85284-2912
 Ph: (480) 894-2056 *** Fax: (480) 894-2497



LEGEND

-  LEAD METAL (~80 S.F.)
-  LEAD STUCCO (~1,200 S.F.)



NOT TO SCALE
NOTE: ALL LOCATIONS ARE APPROXIMATE

LEAD LOCATION MAP
SOUTHEAST BUILDING
 INSPIRATION SCHOOL
 912 W. ROSE ROAD
 MIAMI, AZ

PROJECT NUMBER: 1052000242-5
 APPROVED BY: TH
 DATE: 6/7/23
 DRAWN BY: BK
ATLAS
 9185 S. Farmer Ave., Ste. #111
 Tempe, Arizona 85284-2912
 Ph: (480) 894-2056 *** Fax: (480) 894-2497
FIGURE 5

Lead-Based Paint Inspection
Miami Unified School District #40 – Inspiration School
912 West Rose Road
Miami, Arizona 85539

APPENDIX F

EPA LBP DISCLOSURE REQUIREMENTS

DEPARTMENT OF HOUSING AND URBAN DEVELOPMENT**24 CFR Part 35**

RIN 2501-AB58

ENVIRONMENTAL PROTECTION AGENCY**40 CFR Part 745**

[OPPTS-62130A; FRL-5347-9]

RIN 2070-AC75

Lead; Requirements for Disclosure of Known Lead-Based Paint and/or Lead-Based Paint Hazards in Housing

AGENCIES: Department of Housing and Urban Development (HUD) and the Environmental Protection Agency (EPA).

ACTION: Final rule.

SUMMARY: As a result of past Federal, State, and local efforts to reduce lead in the environment, the percentage of children with elevated levels of lead in their blood has declined considerably over the last 20 years. Approximately 1.7 million children, however, still have blood-lead levels high enough to raise health concerns. Studies suggest that lead exposure from deteriorated residential lead-based paint, contaminated soil, and lead in dust are among the major existing sources of lead exposure among children in the United States. Section 1018 of the Residential Lead-Based Paint Hazard Reduction Act of 1992 directs EPA and HUD to jointly issue regulations requiring disclosure of known lead-based paint and/or lead-based paint hazards by persons selling or leasing housing constructed before the phaseout of residential lead-based paint use in 1978. Under that authority, EPA and HUD are establishing the following requirements: (1) Sellers and lessors of most residential housing built before 1978 must disclose the presence of known lead-based paint and/or lead-based paint hazards in the housing; (2) sellers and lessors must provide purchasers and lessees with any available records or reports pertaining to the presence of lead-based paint and/or lead-based paint hazards; (3) sellers and lessors must provide purchasers and lessees with a federally approved lead hazard information pamphlet; (4) sellers must provide purchasers with a 10-day opportunity to conduct a risk assessment or inspection for the presence of lead-based paint and/or lead-based paint hazards before the purchaser is obligated under any purchase contract; (5) sales and leasing contracts must include certain

disclosure and acknowledgment language; and (6) agents must ensure compliance with these requirements. These provisions ensure that families receive both specific information on the housing's lead history and general information on lead exposure prevention. With this information, consumers can make more informed decisions concerning home purchase, lease, and maintenance to protect their families from lead hazard exposure.

DATES: Effective date: March 6, 1996 except for 24 CFR 35.88, 35.90, 35.92, and 35.94 and 40 CFR 745.107, 745.110, 745.113, and 745.115 which contain information collection requirements that have not been approved by OMB. Once OMB has approved these information collection requirements, EPA and HUD will publish a document giving notice of the effective date and adding the OMB approval number to 24 CFR part 35 and 40 CFR part 9.

The requirements in this final rule are applicable in the following manner: (1) For owners of more than four residential dwellings, the requirements are applicable on September 6, 1996 and (2) For owners of one to four residential dwellings, the requirements are applicable on December 6, 1996.

FOR FURTHER INFORMATION CONTACT: For general information or to obtain copies of the final rule, pamphlet, or background materials, contact the National Lead Information Clearinghouse (NLIC), toll free, at (800) 424-LEAD or fax requests to the NLIC at (202) 659-1192. Copies of the final rule, a brief question-and-answer document, and the pamphlet *Protect Your Family From Lead In Your Home*, are available on the Internet at the National Safety Council's gopher at cais.com and on the World Wide Web at <http://www.nsc.org/nsc/ehc/ehc.html>. For technical information: At HUD, contact Conrad C. Arnolts, Office of Lead-Based Paint Abatement and Poisoning Prevention, Department of Housing and Urban Development, 451 7th St., SW., Washington, DC 20410, Telephone: (202) 755-1810, E-mail: conrad—c.—arnolts@hud.gov (use underscore characters), or John B. Shumway, Office of General Counsel, Telephone: (202) 708-9988, E-mail: John—B.—Shumway@hud.gov (use underscore characters). Persons who are hearing impaired may access these telephone numbers by calling the Federal Information Relay Service at 1-800-877-TDDY.

At EPA, contact Charles Franklin, Chemical Management Division, Office of Pollution Prevention and Toxics, Environmental Protection Agency, 401

M St., SW., Washington, DC 20460, Telephone: (202) 260-1781, E-mail: franklin.charles@epamail.epa.gov.

For general information or to obtain copies of the final rule, pamphlet, or background materials, contact the National Lead Information Clearinghouse (NLIC), toll free, at (800) 424-LEAD or fax requests to the NLIC at (202) 659-1192.

Copies of the final rule, a brief question-and-answer document, and the pamphlet *Protect Your Family From Lead In Your Home*, are available on the Internet at the National Safety Council's gopher at cais.com and on the World Wide Web at <http://www.nsc.org/nsc/ehc/ehc.html>.

SUPPLEMENTARY INFORMATION:**I. Authority**

This final rule is issued under the authority of section 1018 of the Residential Lead-Based Paint Hazard Reduction Act of 1992 (42 U.S.C. 4852d). The Residential Lead-Based Paint Hazard Reduction Act is Title X of the Housing and Community Development Act of 1992, Pub. L. 102-550.

II. Background**A. Legal Background**

Congress passed the Residential Lead-Based Paint Hazard Reduction Act of 1992 (hereafter referred to as Title X or the Act) to address the need to control exposure to lead-based paint hazards. In addition to amending the Toxic Substances Control Act (TSCA) and the Lead-Based Paint Poisoning Prevention Act (LBPAPA), Title X established the infrastructure and standards necessary to reduce lead-based paint hazards in housing. Within this law, Congress recognized lead poisoning as a particular threat to children under age 6 and emphasized the needs of this vulnerable population (section 1003 of Title X).

Section 1018 of Title X requires EPA and HUD to promulgate joint regulations for disclosure of any known lead-based paint or any known lead-based paint hazards in target housing offered for sale or lease. (Target housing is defined in section 1004(27) of Title X, section 401(17) of TSCA, and is discussed in Unit IV.C. of this preamble.) Specifically, section 1018 requires the following activities before a purchaser or lessee is obligated under a contract to purchase or lease target housing: (1) Sellers and lessors must provide purchasers and lessees with a lead hazard information pamphlet, as developed under section 406(a) of TSCA; (2) sellers and lessors must

disclose the presence of known lead-based paint and/or lead-based paint hazards in such housing and provide purchasers and lessees with any lead hazard evaluation report available to the seller or lessor; (3) sellers must permit purchasers a 10-day opportunity to conduct a risk assessment or inspection for the presence of lead-based paint hazards; and (4) sales contracts must include an attached Lead Warning Statement and acknowledgment, signed by the purchaser.

Violation of section 1018 may result in civil and criminal penalties and potential triple damages in a private civil suit.

Section 1018 mandated that EPA and HUD promulgate these requirements no later than 2 years after the date of enactment of Title X (October 28, 1994), to take effect 3 years after enactment of Title X (October 28, 1995). Due to promulgation delays, EPA and HUD have revised the effective date provisions for this rule.

This rule represents one of a broad range of interrelated lead exposure reduction activities mandated under Title X. Many of these other activities support and affect the development of the section 1018 rule. Several of the activities most closely related to the disclosure requirements are briefly discussed below.

The statutory provision most closely tied to section 1018 is section 406(a) of TSCA. Section 406(a) directs EPA to develop and publish, after notice and comment, a lead hazard information pamphlet on lead-based paint hazards in the home. EPA developed the pamphlet in consultation with HUD, the Centers for Disease Control and Prevention (CDC), and the Consumer Product Safety Commission (CPSC), which has joined as a co-sponsor of the pamphlet. EPA issued a notice of availability in the Federal Register of August 1, 1995 (60 FR 39167), to announce the pamphlet's completion. As mandated under section 1018 of Title X, this lead hazard information pamphlet must be given to purchasers and lessees of target housing.

Under section 403 of TSCA, EPA is charged with issuing regulations that identify lead-based paint hazards, lead-contaminated dust, and lead-contaminated soil, based on the definitions provided in section 401 of TSCA. In July 1994, EPA released an interim guidance document to provide public and private decisionmakers with guidance on identifying and prioritizing lead-based paint hazards for control before the issuance of the final section 403 standards. EPA subsequently issued the interim guidance document in the

Federal Register of September 11, 1995 (60 FR 47248). EPA is in the process of developing the proposed section 403 standards.

Section 402 of TSCA directs EPA (in consultation with HUD, the Department of Labor (DOL), and the Department of Health and Human Services (HHS)) to promulgate regulations on accreditation of training programs and training and certification of individuals and contractors engaging in lead-based paint evaluation and reduction activities. This section also requires that EPA, in consultation with the above agencies, develop standards for performance of such lead-based paint evaluation and reduction activities. EPA issued the proposed section 402 rule on September 2, 1994 (59 FR 45872), and expects to issue the final rule shortly. Under the section 1018 disclosure requirements issued today, available reports resulting from such evaluation and reduction activities must be provided to the purchaser or lessee.

Pursuant to sections 1012 and 1013 of Title X, HUD is drafting regulations setting out procedures for all federally owned residential property and housing receiving Federal assistance. These procedures concern occupant notification as well as evaluation (such as inspection and risk assessment) and reduction (such as interim controls and abatement) of lead-based paint and/or lead-based paint hazards. The regulations implementing sections 1012 and 1013 will not address the provision of a lead hazard information pamphlet to new purchasers and lessees of target housing, nor any of the other requirements under section 1018. HUD will release these regulations in proposed form as soon as possible for public comment.

Pursuant to section 1015 of Title X, HUD and EPA established a Task Force on Lead-Based Paint Hazard Reduction and Financing, made up of private and public organizations representing the spectrum of interests affected by the lead-based paint issue. The Task Force developed recommendations on evaluating and reducing lead-based paint hazards in private housing. The Task Force released its recommendations on July 11, 1995, in a report entitled *Putting the Pieces Together: Controlling Lead Hazards in the Nation's Housing*. A copy of this report has been entered into the public record for this rule.

Pursuant to section 1017 of Title X, HUD and EPA, in cooperation with other Federal Agencies, have revised HUD's guidelines for lead-based paint hazard evaluation and reduction activities. These revised guidelines,

entitled *Guidelines for the Evaluation and Control of Lead-Based Paint Hazards in Housing* (hereafter referred to as the "HUD Guidelines"), were released to the public in June 1995. A copy of the HUD Guidelines is included in the public record for this rule.

B. Lead Poisoning in the United States

Lead affects virtually every system of the body. While it is harmful to individuals of all ages, lead exposure can be especially damaging to children, fetuses, and women of childbearing age. As recent studies have identified previously unrecognized effects, there has been increasing concern about blood-lead levels once thought to be safe. Since 1978, CDC has lowered the blood-lead level of concern from 60 µg/dL (micrograms per deciliter) to 10 µg/dL (Ref. 2).

Lead poisoning has been called "the silent disease" because its effects may occur gradually and imperceptibly, often showing no obvious symptoms. Blood-lead levels as low as 10 µg/dL have been associated with learning disabilities, growth impairment, permanent hearing and visual impairment, and other damage to the brain and nervous system. In large doses, lead exposure can cause brain damage, convulsions, and even death. Lead exposure before or during pregnancy can also alter fetal development and cause miscarriages.

In 1991, the Secretary of HHS characterized lead poisoning as the "number one environmental threat to the health of children in the United States" (Ref. 1). Although the percentage of children with elevated blood-lead levels has declined over the last 20 years, millions of U.S. children still have blood-lead levels high enough to threaten their health (Ref. 1). The Third National Health and Nutrition Examination Survey (NHANES III) indicates that over the past two decades, the average child's blood-lead level has decreased from 12.8 µg/dL to 2.8 µg/dL (Ref. 8). NHANES III also indicates, however, that in 1991 approximately 1.7 million U.S. children under the age of 6 still had blood-lead levels that exceeded the CDC 10 µg/dL level of concern (Ref. 8).

C. Hazards from Past Uses of Lead-Based Paint

Efforts to reduce exposure to lead from sources like gasoline and food cans have played a large role in the past reductions of blood-lead levels in the United States. Despite these successes, a significant human health hazard remains from improperly managed lead-based paint. From the turn of the

century through the 1940's, paint manufacturers used lead as a primary ingredient in many oil-based interior and exterior house paints. Usage gradually decreased through the 1950's and 1960's, as largely lead-free latex paints became more popular. Although the CPSC banned lead-based paints from residential use in 1978 (currently, paints may not have greater than 0.06 percent lead by weight (Ref. 3)), EPA and HUD estimate that 83 percent of the privately owned housing units built in the United States before 1980 contain some lead-based paint. By these estimations, approximately 64 million homes may contain lead-based paint that may pose a hazard to the occupants if not managed properly (Ref. 4).

Lead from exterior house paint can flake off or leach into the soil around the outside of a home, contaminating children's playing areas. Dust caused during normal lead-based paint wear (especially around windows and doors) can create a hard-to-see film over surfaces in a house. In some cases, cleaning and renovation activities can increase the threat of lead-based paint exposure by dispersing fine lead dust particles in the air and over accessible household surfaces. If managed improperly, both adults and children can receive hazardous exposures by inhaling the fine dust or by ingesting paint dust during hand-to-mouth activities. Children under age 6 are especially susceptible to lead poisoning (Ref. 2).

III. Summary of Proposed Rule and Public Comments

Under the authority of Title X, EPA and HUD issued a proposed rule in the Federal Register of November 2, 1994 (59 FR 54984). The proposed rule described the basic approach for implementing the requirements under section 1018, including draft regulatory text, definitions, and standardized form language for use in all transactions. In many cases, EPA and HUD also included a range of options for implementing the rule along with requests for comment on specific implementation issues.

In response to the proposed rule, identified by docket number OPPTS-62130A, EPA and HUD received responses from 198 commenters during the 60-day comment period. The largest number of responses (approximately 25 percent) came from the real estate industry. Other commenter groups included representatives from the banking/financial industry (9 percent), letters from State and local officials involved with public health or environmental protection (8 percent),

comments from advocacy groups (8 percent), letters from attorneys representing various groups (9 percent), and concerned private citizens (23 percent). Approximately 10 percent of the responses came from education officials, housing authorities, and groups involved with real estate development and construction. The paragraphs that follow briefly describe some of the key areas that were addressed by the commenters.

A number of comments addressed the scope and applicability of the rule. Commenters discussed a range of transaction types for specific exclusion or inclusion.

While numerous comments addressed the various definitions contained in the rule, most suggestions involved revisions and modifications to existing terms as opposed to requests that additional terms be defined. A prevalent theme was consistency of terminology across different rules such as those for sections 402, 404, and 406 of TSCA.

Comments concerning the disclosure requirement targeted issues such as the scope of disclosed information; the precise stage at which disclosures should be made; recordkeeping parameters; and the ways in which common areas of multi-unit buildings will be affected by disclosure.

The lead hazard information pamphlet requirements generated comments in the following three categories: strategies for States and tribes (hereafter, all references to States include Indian tribes) with their own notification materials; making the pamphlet available in other languages; and requests for more varied and active distribution strategies.

The proposed disclosure and acknowledgment form generated requests for simplification and availability in non-English languages. Some suggestions involved revising portions of the Lead Warning Statement.

The section of the proposed rule that received the most comments concerned the proposed 10-day evaluation period. Of particular concern were the commencement and length of the evaluation period; the practical availability of certified inspectors or risk assessors to do the testing; and the practicality and logistics of obligating purchasers to provide a report to sellers.

Other topics that elicited some comment included the role of the agent, the effective date of the rule, and potential penalties for noncompliance.

A more complete summary of the comments received, along with EPA's and HUD's responses, is available in the public record for this rulemaking.

IV. Final Rule Provisions and Key Comments Addressed

EPA and HUD have revised the proposed rule to reflect the Agencies' desire to maximize the rule's clarity, flexibility, consistency with other Federal activities, and consistency with existing real estate practice. These goals are important considerations to ensure quick and widespread implementation of the rule.

In particular, many of the changes to the final rule fall into five general categories. These areas include: (1) Clarifications of the rule's applicability, (2) modification of key definitions, (3) establishment of a clear and common sense disclosure process, (4) development of a concise disclosure record, and (5) development of a flexible framework for the 10-day evaluation period.

Throughout the preamble for this final rule, there are citations to 24 CFR part 35 and 40 CFR part 745. These references reflect the location that the final regulatory text will occupy in the *Code of Federal Regulations* (CFR) following the rule's promulgation. EPA and HUD are adding this final joint EPA/HUD regulation to both titles to ensure that the public can easily locate the requirements. Where the preamble references the actual rule language, therefore, it will regularly include references to the requirements as they appear in each title. While the requirements are identical, in some cases the nomenclature for the two titles may be slightly different.

A. Clarifying the Rule's Scope and Applicability

Section 1018 mandated that the rule apply to sales and leases of target housing. The proposed rule also discussed certain unique types of housing transactions that deserved special attention in implementing the regulations. For example, the preamble of the proposed rule explained the rule's exclusion of the following from the statutory definition of target housing: housing built after 1977, housing for the elderly, housing for the disabled, 0-bedroom dwellings, and commercial lodging. Many commenters recommended that the regulatory text of the final rule clearly designate types of transactions that are included and excluded.

EPA and HUD have expanded the scope and applicability section of the regulatory text to better define the rule's impact on certain types of transactions. Below is a brief discussion of the unique transactions addressed under the scope and applicability section and the

rationale for including or excluding them.

1. *Transactions to sell properties at foreclosure.* The final rule retains the exclusion for foreclosure sales presented in the proposed rule. While some commenters opposed exempting foreclosure transactions due to the lack of protection for the purchaser, EPA and HUD believe that the circumstances typically surrounding foreclosure transactions make pre-sale disclosure and evaluation unworkable and impractical. Access to properties during foreclosure proceedings is often limited, making evaluations impossible. Such properties typically are sold on an "as is" basis with regard to all structural and environmental factors. Further, these transactions do not necessarily involve direct interaction between the property owner and the purchaser, and the mortgage holder or trustee is unlikely to have information on the presence of lead-based paint and/or lead-based paint hazards. In light of these circumstances, EPA and HUD believe that it would be inappropriate to extend Federal disclosure and evaluation requirements to foreclosure transactions.

This exclusion does not apply, however, to the sale of housing originally acquired through a foreclosure sale and subsequently resold (an expansion of the exclusion recommended by some commenters). In such cases, EPA and HUD believe that the rule's provisions can be incorporated into the sales process since many of the extenuating circumstances of foreclosure sales no longer apply.

2. *Rental housing found to be free of lead-based paint.* The final rule exempts from coverage leasing transactions involving target housing that is free of lead-based paint, as determined by a certified inspector. For the purposes of this rule, EPA and HUD have defined "lead-based paint free" as the absence of paint with lead levels above those provided in Title X.

In addition to receiving support by many public commenters, this exclusion was recommended by the Task Force on Lead Hazard Reduction and Financing. EPA and HUD strongly encourage the concept of lead-based paint evaluation in rental housing. Evaluations can help lessors to detect the presence of lead-based paint and to determine whether certain management practices and occupant education efforts are necessary. Where evaluations discover lead-based paint, such results will provide lessors and/or lessees with the information necessary to take appropriate hazard reduction steps. EPA and HUD also believe that the

exemption will provide a valuable incentive to building owners to conduct inspections and remove lead-based paint where present.

Under the provisions of the regulation, disclosure during rental transactions is limited to the disclosure of known lead-based paint and/or lead-based paint hazards, provision of available records and reports, provision of a lead hazard information pamphlet, and creation and retention of lead warning and acknowledgment language. These activities provide substantially fewer benefits in cases where reliable information indicates that the housing is lead-based paint free. At the same time, EPA and HUD expect that the exemption for lead-based paint free units will not dissuade many lessors from providing their inspection reports to prospective lessees on a voluntary basis. Given the value that lead-safe housing would have to an informed consumer, EPA and HUD expect that owners will see a great benefit in informing lessees of the housing's lead-based paint free status.

Because of the distinct disclosure obligations the statute imposes on sellers, obligations that purchasers assume upon purchase of the housing, EPA and HUD are not allowing the lead-based paint free exemption for sales transactions. Unlike lessees, purchasers take on new obligations to comply with the disclosure provisions during all subsequent sales or leasing transactions. Exempting sales transactions could disrupt the flow of information from owner to owner regarding the status of the target housing and the purchaser's potential disclosure obligations. Further, Title X guarantees purchasers more than just known information and available reports. Title X guarantees each purchaser the opportunity to conduct an evaluation for lead-based paint and/or lead-based paint hazards, regardless of the information disclosed by the seller. Exempting sales transactions based on the information in the possession of the seller would deny the purchaser that evaluation right. While many purchasers will accept the seller's information and waive their evaluation opportunity (especially if the seller provides an evaluation by a certified inspector), some purchasers may prefer to have their own evaluation performed.

Because the Federal training and certification program will not take effect until some time after the effective date of this rule, EPA and HUD recognize the need for a process to allow property owners to seek exclusions for lead-based paint free housing in States without federally authorized certification

programs. In the interim period before the Federal certification program (to be issued under subpart L of 40 CFR part 745) takes effect, inspectors qualified under any existing State certification program, and using State-approved methods, are considered qualified to conduct inspections for the purpose of determining whether housing is lead-based paint free. In States without existing certification programs, lessors may use the services of inspectors certified in other States. Once the Federal or federally authorized State certification program has taken effect in a particular State, however, this interim provision will expire and subsequent inspections for the purposes of this exclusion will have to be performed by inspectors with Federal or federally authorized State certification.

Some commenters asked whether lessors hoping to meet the lead-free exemption could correct for possible false (or outdated) positive findings during lead-based paint inspections. The lessor always retains the option of having additional tests performed by certified inspectors. Nothing in either the law or the regulation is intended to revoke or restrict that right. An additional test can sometimes clarify whether or not lead-based paint is present. For example, if a lessor believed that a previous inspection had rendered a false-positive result (all measurement techniques involve some small degree of sampling and analytical error), the lessor could choose to have a certified inspector retest the area in question. If the additional testing by a certified inspector indicated that the initial positive results were false (i.e., that there was in fact no lead-based paint present), then the lessor would qualify for the lead-based paint free exemption. Similarly, suppose a lessor first had a test done in 1982 using an X-ray fluorescence (XRF) device that indicated the presence of lead-based paint. Because testing procedures were less reliable at that time (standard practice often failed to consider the effect of the substrate underneath the paint on the accuracy of the measurement and instrument calibration checks were often deficient), the lessor might choose to conduct a new test using the improved methodology available today. If this second test indicated that lead-based paint was not present, then the lessor would qualify for the lead-based paint free exemption. As a third example, a lessor who had all lead-based paint removed from a rental property following an earlier inspection could choose to have a new inspection or

clearance examination conducted on the abated property. If the new information indicated that lead-based paint was no longer present, then the lessor would qualify for the lead-based paint free exemption. In all three cases, if the second test confirmed the original findings, or if the test was not conducted by a certified inspector, the exemption would not be available.

3. *Short-term leases of 100 days or less.* Many commenters recommended that the final rule clarify the distinction between short-term lodgings and longer term residential housing. The final rule addresses these comments by excluding housing transactions involving leasing agreements of 100 days or less, where no lease renewal or extension can occur. This time period is intended to capture all leasing transactions of 3 months or less, while providing several additional days to allow flexibility in the transaction. Building upon the logic discussed in the proposed rule, the final rule's short-term lease exclusion captures most seasonal vacation rentals and hotel and motel transactions, as well as other forms of short-term lodging. During such transactions, which are typified by short stays and quick occupant turnover, EPA and HUD believe that the disclosure provisions are impractical and counter to Congressional intent. The notification requirements of this rule would apply to vacation rentals in cases where the stay extends beyond a 100-day period. Under such circumstances, EPA and HUD believe that the potential for occupant exposure to lead-based paint and/or lead-based paint hazards merits the disclosure of information required by the rule, regardless of whether the stated purpose of the lease is temporary or permanent housing.

In addition, EPA and HUD have placed a limitation on extensions and renewals of such short-term leases to ensure that month-to-month leasing transactions remain covered by the final rule. Commenters noted that many rental transactions incorporate an open-ended month-to-month leasing agreement. These transactions will still be covered by the final rule unless the parties establish in advance that the term of rental will be no longer than 100 days. In an open-ended month-to-month lease arrangement, for example, the rule still applies since the leasing agreement fails to limit the lease term to 100 days or less, i.e., the lease agreement could possibly be extended beyond 100 days. If both parties wish to extend a previously exempted short-term lease beyond the 100-day limit, all provisions of this rule must be satisfied in full before any such "extension" occurs.

4. *Lease renewals.* The final rule does not require repeated disclosure during the renewal of existing leases in which the lessor has previously disclosed all information required under 24 CFR 35.88 and 40 CFR 745.107 and where no new information has come into the possession of the lessor. As stated in the proposed rule, EPA and HUD do not believe that duplicative disclosure provides significant benefits.

Several commenters noted that in many residential leasing transactions, leasing arrangements switch to month-to-month "at-will" arrangements after an initial period of occupancy. In such cases, the leasing arrangement may continue indefinitely without any "renewal process." Under such circumstances, EPA and HUD interpret renewal to occur at the point when the parties agree to a significant written change in the terms of the lease, such as a rental rate adjustment. Following such alteration of terms, the disclosure requirements apply to any new information obtained subsequent to the original disclosure.

5. *The purchase, sale, or servicing of mortgages.* The final rule does not cover, and was never intended to cover, the purchase, sale, or servicing of mortgages. During the comment period, many commenters expressed concern that the proposed rule could be interpreted to hold liable persons involved in the purchase, sale, or servicing of mortgages where the title of the housing does not change hands as part of the transaction.

6. *The sale or lease of 0-bedroom dwellings.* The final rule does not apply to transactions involving 0-bedroom dwellings, in keeping with the definition of "target housing" provided in section 1004 of Title X. This definition, at the heart of the section 1018 provisions, specifically excludes 0-bedroom dwellings of all types.

7. *Informal rental agreements.* In the proposed rule, EPA and HUD proposed excluding "informal rental agreements which do not involve a lease" (a phrase meant to capture oral leases) because "such arrangements, by virtue of their informality, make the administration and enforcement of these requirements extremely difficult." EPA and HUD have removed any implied exclusion for oral leases. In deciding not to exclude such leases, EPA and HUD drew heavily upon the public comments. Many of these comments suggested that the absence of a written lease may not have bearing on the "formality" of the housing arrangement. Commenters noted that oral leases make up a significant portion of the housing

arrangements in certain areas, especially those that lack rental housing codes.

Further, although the absence of a written lease provides challenges for certain Federal enforcement and compliance monitoring approaches, EPA and HUD now believe that enforcement is possible. Other evidence may exist, for example, to demonstrate that a leasing agreement exists between two parties. Congress also provided lessees with opportunities for redress under its civil penalty provisions at section 1018(b)(3). These safeguards are not dependent upon Agency actions and therefore should not be constrained by EPA and HUD limitations.

EPA and HUD have also considered policy reasons for not excluding oral leases. First, EPA and HUD are sympathetic to commenter concerns that an explicit exclusion for oral leasing transactions could create incentives for lessors to avoid written leases. If the rule's exclusion were to indirectly discourage the use of written leases, lessees would lose both their right to information on lead-based paint poisoning prevention and the many other protections afforded by written leases. Commenters also noted that a disproportionate number of oral transactions occur in low-income, disadvantaged communities. These communities are already at greater risk of exposure to lead-based paint hazards.

Nevertheless, while the final rule does not provide an explicit exclusion for oral leasing arrangements, EPA and HUD expect that many oral lease transactions may be excluded for other reasons (length of arrangements, rental of 0-bedroom dwelling, etc.).

B. Effective Date

In the proposed rule, EPA and HUD requested comment on the issue of extending the effective date for the final rule beyond October 28, 1995, in light of the promulgation delays. EPA and HUD noted Congress' inclusion of a 1-year window between the statutory promulgation deadline and the statutorily mandated effective deadline. EPA and HUD received comments in support of and in opposition to an extension.

Commenters opposed to delaying the effective date generally argued that any delay in implementation would increase the number of preventable exposures to lead-based paint hazards. According to these commenters, given the importance of educating consumers about their options for reducing lead hazards, the positive effects of early implementation outweigh the practical difficulties.

While agreeing that this rule addresses an important consumer

protection and empowerment goal, EPA and HUD believe that the rule's effective implementation requires an informed and prepared general public and regulated community. EPA and HUD believe that a phase-in period is necessary to provide adequate time for the real estate industry, private lessors, and independent housing sellers and lessors to become familiar with the rule requirements and to set up procedures for compliance.

Sellers and lessors who own more than four residential dwellings will have 6 months from the final rule's promulgation to implement full disclosure during sales and leasing transactions. This phase-in schedule ensures that all such property owners, sellers, lessors, and agents will have adequate notice of the new requirements before they take effect. Believing that property owners with four or fewer dwellings are more likely to be non-professional sellers and lessors, EPA and HUD are providing a 9-month phase-in period for such owners. EPA and HUD encourage all sellers and lessors to begin voluntary disclosure in advance of their relevant effective date.

EPA and HUD also received comments recommending delaying the effective date until after EPA issues its standards for lead hazards in paint, dust, and soil. These commenters stated that the regulated community would be unable to disclose adequately the presence of lead-based paint and lead-based paint hazards in the absence of Federal standards.

EPA and HUD do not believe that this rule requires Federal lead hazard standards to be effective. In section 1018, Congress mandated that sellers and lessors disclose not just lead-based paint hazards but also the presence of lead-based paint, a far more inclusive mandate (since not all lead-based paint is necessarily a hazard).

Further, EPA and HUD expect that records will likely provide purchasers and lessees with information on lead-based paint and, where they exist, lead-based paint hazards. Accordingly, if records pertaining to lead-based paint are fully disclosed, disclosure of lead-based paint hazards should also be accomplished.

The statute and now this rule provide a clear definition for the levels of lead in paint that constitute lead-based paint. The statute also provides a qualitative definition of lead-based paint hazard, including certain exposures to lead-based paint that is peeling or chipping; lead-based paint that is on friction, impact, or chewable surfaces; and lead-contaminated dust and soil.

EPA and HUD have augmented these definitions by providing guidance on identifying lead hazards in paint, dust, and soil (60 FR 47248).

Regarding the need for guidance to help prospective purchasers and lessees with the interpretation of disclosed information, EPA and HUD believe that the statutory definition of "lead-based paint hazard," combined with EPA's lead hazard guidance and the HUD Guidelines, provides sellers, purchasers, lessors, and lessees with valuable information for interpreting any disclosed information.

Some commenters have also recommended delaying the effective date of the final rule until after the activation of the Federal standards for training and certifying lead workers, being developed under section 402 of TSCA. After considering the comments and reexamining the statute, EPA and HUD have determined that such a delay is unnecessary. EPA and HUD believe that the HUD Guidelines will provide adequate interim guidance for the evaluation and management of lead-based paint hazards in target housing, prior to the release of the section 402 training and certification standards.

C. Definitions

EPA and HUD received comments on many of the proposed definitions. Below is a brief discussion of the significant definitions being promulgated under this final rule.

1. *Agent* means any party who enters into a contract with a seller or lessor, including any party who enters into a contract with a representative of the seller or lessor, for the purpose of selling or leasing target housing. This term does not apply to purchasers or any purchaser's representative who receives all compensation from the purchaser.

EPA and HUD initially defined "agent" to be "any party who enters into a contract with a seller or lessor to represent the seller or lessor for the purpose of selling or leasing target housing." Several commenters stated that the language in this definition was needlessly vague. Listing agents typically enter into a contract with the seller and represent the seller. "Buyer" agents, however, often enter into a contractual relationship with a seller or the seller's agent but may represent both the seller and the purchaser in the real estate transaction. EPA and HUD have revised this definition so that any party entering into a contractual relationship directly with the seller or lessor (or indirectly with a representative of the seller or lessor) for the purpose of selling or leasing the target housing, is

an "agent" for the purposes of this rule. As a consequence, listing agents, selling agents, and buyer agents (if paid by the seller or through a cooperative brokerage agreement with the listing agent), are "agents" and are responsible for ensuring compliance under the rule. Since section 1018 refers only to agents having entered into a contract with the seller or lessor, buyer's agents paid entirely by the purchaser are not considered "agents" under this rule.

2. *Available* means in the seller's or lessor's possession or reasonably obtainable by the seller or lessor at the time of the disclosure.

Section 1018(a)(1) requires that sellers and lessors provide the purchasers and lessees with "any lead hazard evaluation reports available to the seller or lessor." EPA and HUD interpret available lead hazard evaluation reports to mean records and reports that pertain to lead-based paint and/or lead-based paint hazards in the target housing and that are in the possession of the seller or lessor or that are reasonably obtainable by the seller or lessor at the time of the disclosure.

EPA and HUD expect that most sellers and lessors will retain copies of relevant information in their possession along with other important housing files (title, outstanding leases, etc.). In some cases, however, the seller or lessor may no longer have possession of the records but may have reasonable access to the information. Examples of "reasonably obtainable" records include records retained by a separate or outside entity on behalf of the seller or lessor and copies of reports retained by the original inspector or risk assessor that would be available to the owner in cases where the original records were destroyed or lost. The term "reasonably obtainable" is not intended to impose an obligation on the seller or lessor to conduct further evaluation of the housing.

3. *Common area* means a portion of a building generally accessible to all residents/users including, but not limited to, hallways, stairways, laundry and recreational rooms, playgrounds, community centers, and boundary fences.

This definition is unchanged from the proposed rule. The term "common area" will be used in other TSCA Title IV regulations, some of which may require a broader interpretation of common area. The final rule provides one broadly interpreted term applicable under all of the TSCA rules, to avoid the confusion of multiple rule-specific definitions. Though several commenters recommended minor changes to adjust the scope of the definition, EPA and HUD believe that other regulatory

provisions adequately clarify the relevant scope of the term "common area" as it relates to target housing.

4. *Foreclosure* means any of the various methods, statutory or otherwise, known in different jurisdictions, of enforcing payment of a debt, by the taking and selling of real property.

EPA and HUD added this definition in response to requests that the final rule include a regulatory definition of the term. EPA and HUD believe that this definition will help property owners determine the applicability of the foreclosure exemption to their transactions. Recognizing that different jurisdictions may have differing interpretations of what constitutes "foreclosure," EPA and HUD have developed a general definition that provides flexibility to work within established local laws and customs.

5. *Housing for the elderly* means retirement communities or similar types of housing specifically designed for households composed of one or more persons 62 years of age or more at the time of initial occupancy.

In response to public comments, EPA and HUD have added a definition for this term to the regulatory text. This definition is consistent with the definition used by HUD's Supportive Housing for the Elderly Program (See 24 CFR 277.1(f)). While some commenters recommended the use of a "55 years or older" standard (as used to define "older person" in the Fair Housing Act), HUD believes that the current definition is more consistent with HUD's other programs for the elderly.

6. *Lead-based paint* means paint or other surface coatings that contain lead equal to or in excess of 1.0 milligram per square centimeter or 0.5 percent by weight.

This term has been modified slightly from the language provided in Title X and TSCA to retain consistency with the many HUD programs already using the levels defined under section 302(c) of the Lead-Based Paint Poisoning Prevention Act.

7. *Lead-based paint free housing* means target housing that has been found to be free of paint or other surface coatings that contain lead equal to or in excess of 1.0 milligram per square centimeter or 0.5 percent by weight.

EPA and HUD have added this definition in support of the provision of the rule that allows rental transactions in "lead-based paint free" rental housing to be excluded from the section 1018 requirements. EPA and HUD provide further discussion of this provision in unit IV.A.2. of this preamble.

8. *Lead-based paint hazard* means any condition that causes exposure to lead from lead-contaminated dust, lead-contaminated soil, or lead-contaminated paint that is deteriorated or present in accessible surfaces, friction surfaces, or impact surfaces that would result in adverse human health effects as established by the appropriate Federal agency.

This term, defined in section 1004 of Title X, is unchanged from the proposed rule. EPA has released guidance on identifying lead hazards in paint, dust, and soil (60 FR 47248) and is currently developing Federal standards. In addition, HUD has released comprehensive guidelines for evaluation and control of lead-based paint hazards in housing (Ref. 7).

9. *Lessee* means any entity that enters into an agreement to lease, rent, or sublease target housing, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations.

EPA and HUD received limited comments on this definition and have made minor revisions to the language of the definition to clarify its applicability to trusts and subleases.

10. *Lessor* means any entity that offers target housing for lease, rent, or sublease, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations.

EPA and HUD received limited comments on this definition and have made minor revisions to the language of the definition to clarify its applicability to trusts and subleases.

11. *Owner* means any entity that has legal title to target housing, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations, except where a mortgagee holds legal title to property serving as collateral for a mortgage loan, in which case the owner is considered the mortgagor.

EPA and HUD have revised the definition provided in the proposed rule to clarify its applicability to trusts and to clarify one situation in which mortgage lenders (mortgagees), rather than borrowers (mortgagors), hold title and are therefore owners.

12. *Purchaser* means an entity that enters into an agreement to purchase an interest in target housing, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations.

EPA and HUD received limited comments on this definition and have made minor revisions to the language of the definition to clarify its applicability to trusts.

13. *Risk assessment* means an on-site investigation to determine and report the existence, nature, severity, and location of lead-based paint hazards in residential dwellings, including: (1) Information gathering regarding the age and history of the housing and occupancy by children under age 6; (2) visual inspection; (3) limited wipe sampling or other environmental sampling techniques; (4) other activity as may be appropriate; and (5) provision of a report explaining the results of the investigation.

This definition, provided in section 1004 of Title X, is unchanged from the proposed rule. Under section 402 of TSCA, EPA will promulgate separate regulations regarding the conduct of such activities, as well as a program for training and certifying workers engaged in these activities. Under section 404 of TSCA, these regulations will also include a process for authorizing States to implement their own training and certification programs.

14. *Seller* means any entity that transfers legal title to target housing, in whole or in part, in return for consideration, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations. The term "seller" also includes: (1) An entity that transfers shares in a cooperatively owned project, in return for consideration and (2) an entity that transfers its interest in a leasehold in jurisdictions or circumstances where it is legally permissible to separate the fee title from the title to the improvement, in return for consideration.

EPA and HUD received limited comments on this definition and have made minor revisions to the language of the definition to clarify its applicability to trusts.

15. *Target housing* means any housing constructed prior to 1978, except housing for the elderly or persons with disabilities (unless any child who is less than 6 years of age resides or is expected to reside in such housing) or any 0-bedroom dwelling.

This definition was provided by section 1004 of Title X and is unchanged. Where commenters provided recommendations for revising or clarifying the definition, EPA and HUD have addressed those comments within the scope and applicability section of the final rule. Commenters also noted that the proposed rule

misstated the statutory definition by limiting the 0-bedroom dwelling exception to housing where no children under 6 reside or are expected to reside. EPA and HUD have modified the definition to reflect the statutory language.

16. *0-bedroom dwelling* means any residential dwelling in which the living area is not separated from the sleeping area. Such term includes efficiencies, studio apartments, dormitory housing, military barracks, and rentals of individual rooms in residential dwellings.

In the preamble of the proposed rule, EPA and HUD clarified their interpretation of this term by identifying efficiencies, studio apartments, dormitory housing, military barracks, and other such housing in which the living area is unseparated from the sleeping area as types of dwellings that are not covered under the rule. EPA and HUD have added rentals of individual rooms in a residential dwelling to the types of transactions that would involve a 0-bedroom dwelling. All of these clarifications are included in the regulatory definition in the final rule's regulatory text.

D. Changes to the Disclosure Requirements

Section 1018(a)(1)(B) requires that "before the purchaser or lessee is obligated under any contract to purchase or lease the housing, . . . the seller or lessor shall . . . disclose to the purchaser or lessee the presence of any known lead-based paint or any lead-based paint hazards, in such housing, and provide any lead hazard evaluation report available to the seller or lessor."

EPA and HUD received more than 150 comments on their proposed requirements for such information disclosure, addressing both the proposed disclosure process and the issue of what information should be covered. In particular, recurring themes among the comments included: (1) The need for greater specificity regarding the necessary timing for disclosure activities; (2) concerns over which activities should constitute disclosure; and (3) what kinds of information should be disclosed under this rule. The following is a brief discussion of these key points and a summary of the regulatory requirements.

1. *Timing of disclosure events.* In addressing the need for greater clarity regarding the timing of disclosure activities, EPA and HUD have attempted to maximize the parties' flexibility in incorporating these requirements during negotiations. EPA and HUD believe that this flexibility is important given the

many types of transactions covered by these provisions and the existence of distinct local requirements and customs. Therefore, the final rule identifies only the latest point at which full disclosure must occur. Using the statute as a guide, EPA and HUD have identified this point as before the purchaser or lessee becomes obligated under any contract to purchase or lease the housing.

Some commenters raised the concern, however, that without additional clarification regarding how and when information must be disclosed, the final rule could cause unnecessary confusion regarding how the requirements will work in actual practice. After reviewing the framework set out in the proposed rule, EPA and HUD have revised and clarified the requirements in a number of ways. First, the final rule contains numerous minor changes to the wording of definitions and requirements to clarify that the rule does not require mass disclosure to all prospective purchasers, regardless of their degree of interest. Second, the rule requires that certain disclosure and acknowledgment language become part of the final sale or lease contract. In making these changes, EPA and HUD have considered the typical negotiation process involved in leasing and sales transactions.

During sales transactions, for example, purchasers often take the first step toward formalizing a sales agreement by providing a written offer to purchase the housing. If accepted and signed by the seller, this offer typically becomes the sales contract. The statute's mandate that disclosure and notification take place before the purchaser is obligated imposes a requirement on the seller to disclose information before accepting the purchaser's offer, thereby allowing the purchaser an opportunity to review the information and to possibly amend the offer. If a seller were to accept a purchaser's offer and obligate the purchaser before disclosing known information, such a seller would be in violation of Title X and this rule. Of course, the parties can always agree to conduct the disclosure activities in advance of contract discussions, provided that the final contract includes the signed and dated disclosure elements mandated by this rule.

In leasing transactions, the disclosure process is even simpler. While the parties are free to negotiate when the disclosure process occurs, lessors must provide the information and complete the disclosure portions of the lease (or attachment) before the lessee becomes obligated under a contract to lease the housing. By requiring that the disclosure information be included in or as an attachment to the lease, EPA and

HUD seek to ensure that the disclosure process automatically occurs during lease negotiations.

The requirement that the contract or an attachment include disclosure language fulfills two additional functions. First, the process of completing and signing these sections ensures that all parties are aware of their rights and obligations and are able to confirm that the appropriate actions have already occurred. Second, this disclosure language provides a clear record of compliance.

While sections 1018(a)(2) and (3) mandate lead warning language for all sales transactions, the inclusion of such language as an attachment to leases is not specifically mandated by Title X. EPA and HUD, however, believe that it is necessary to include the warning language in leases as well. Further, the completion and retention of disclosure and acknowledgment language is a necessary component of any effective, enforceable disclosure requirement for leasing transactions.

2. *Components of full disclosure.* EPA and HUD consider full disclosure to have occurred when the seller or lessor has provided the following items to the purchaser or lessee.

a. *A lead hazard information pamphlet approved by EPA.* As required by TSCA section 406, EPA has developed a lead hazard information pamphlet, entitled *Protect Your Family from Lead in Your Home*, and has made it available through government channels and private sources. EPA issued the final notice of the pamphlet's availability in the Federal Register of August 1, 1995 (60 FR 39167). In addition to providing detailed information on how to obtain copies (individually, in bulk, and as camera-ready reprints), the notice describes the process of developing the pamphlet, including considerable public review and comment.

The statute also allows States to develop their own lead hazard information pamphlets under section 406, provided that they obtain authorization and approval from EPA. Several States that already have disclosure provisions have expressed their desire to seek approval to use their own pamphlets in lieu of the Federal pamphlet. EPA and HUD encourage States interested in developing their own materials to seek approval of their pamphlets for distribution under the section 1018 regulations.

b. *Notice of the presence of known lead-based paint and/or lead-based paint hazards.* Sellers and lessors must disclose, based on their actual knowledge, whether the target housing

is known to contain lead-based paint and/or lead-based paint hazards. EPA and HUD received many comments on the types of information under consideration for disclosure under these requirements. Many of the commenters expressed concern that the proposed rule was too vague about what constituted "known information." For example, did EPA and HUD intend for the disclosure requirements to distinguish between information already in the possession of the seller or lessor and information that could be obtained only by some further investigation or inference? Several commenters described this distinction in terms of actual knowledge (knowledge stemming from existing facts and information) versus constructive knowledge (knowledge that could be inferred or obtained by further inquiry). An expectation that the property owners meet a constructive standard for knowledge could create an implied testing requirement.

While the Agencies hope to encourage lead hazard evaluation and reduction efforts through all of their regulatory and non-regulatory programs, neither Agency believes that Congress intended to mandate additional lead hazard evaluation activities in private housing. EPA and HUD believe that Congress intended to limit the disclosure obligation to actual knowledge. The final rule, therefore, embraces an actual knowledge standard as well. With this clear standard, property owners and their agents will be able to take affirmative steps to comply fully with the rule and be confident that they have met the requirements of the law and its implementing regulations. EPA and HUD believe that such finality is a necessary part of this regulation, given the diverse makeup of the regulated community.

c. Provision of records and reports on lead-based paint and/or lead-based paint hazards available to the seller or lessor. As mandated by section 1018(a)(1)(B), sellers and lessors must "provide to the purchaser or lessee any lead hazard evaluation report available to the seller or lessor." EPA and HUD have interpreted "available evaluation reports" to mean records and reports that pertain to lead-based paint and/or lead-based paint hazards in the target housing and that are in the possession of the seller or lessor or that are reasonably obtainable by the seller or lessor at the time of the disclosure.

During the proposed rule phase, EPA and HUD requested comment regarding the disclosure of known lead-based paint and/or lead-based paint hazards in other units within target housing. EPA

and HUD received both supporting and opposing comments on this requirement. Opponents argued that distinct dwelling units can have very different painting histories, making information on one unit an unreliable indicator of other units. Proponents argued that regardless of differences that may exist, the painting histories of different units in a building are usually similar enough to provide valuable information for individuals considering whether lead hazard exposure precautions are prudent.

EPA and HUD believe that information and reports on other units in the target housing are directly relevant to prospective purchasers and lessees if the information stems from evaluation or reduction efforts in the target housing as a whole. In large multifamily properties, evaluations do not necessarily examine every dwelling unit in the housing. Rather, inspectors or risk assessors examine a representative sample of the dwelling units and apply the findings to the housing as a whole. While such evaluations might not include data on a specific unit, the fact that the evaluation was designed to provide information on the housing as a whole makes the report's findings relevant.

The proposed rule also requested comment on whether sellers and lessors should have to disclose information on past elevated blood-lead levels in other occupants of target housing. Based on the comments and further deliberation, EPA and HUD decided against requiring disclosure of medical information for several reasons. As commenters pointed out, lead exposure, elevated blood-lead levels, or lead poisoning may come from sources other than lead-based paint hazards in the housing. Where elevated blood-lead levels were determined to stem from lead-based paint hazards in the housing, the follow-up environmental assessment activities in the affected person's housing will likely generate more germane records regarding lead-based paint exposure hazards in the housing.

Commenters also questioned whether disclosure requires the actual transfer of all documentation from the seller or lessor, or whether simply making the information accessible for the purchaser's or lessee's evaluation is adequate. Based on the mandate in section 1018(a)(1)(B), EPA and HUD believe that Congress clearly intended for purchasers and lessees to receive their own copies of the records and reports available to the seller or lessor. Therefore, the seller or lessor remains obligated to provide copies of all

relevant materials to the purchaser or lessee.

d. Completed Lead Warning Statement and acknowledgment language, attached to the sales or lease contract. This information, set out in 24 CFR 35.92 and 40 CFR 745.113, documents the disclosure and acknowledgment process, and serves as the primary confirmation tool for all parties in ensuring full compliance with the regulatory requirements. This information is especially important in cases where purchasers or lessees conduct contract negotiations through their own representatives (requiring sellers, lessors, or their agents to provide documents to the representative instead of the purchaser or lessee). In such cases, the attachment provides a record that sellers, lessors, and agents can use to confirm that purchasers and lessees have received the necessary disclosure materials.

The proposed rule required the use of disclosure forms as attachments to each contract to purchase or lease target housing. These forms would have served as the key mechanisms for documenting compliance with the requirements. EPA and HUD carefully considered the merits of each element, limiting the rule to information necessary for demonstrating full compliance.

The final rule includes some changes to the information that must be included in the contract. Where the proposed rule required that sellers and lessors use federally developed disclosure forms, the final rule provides greater flexibility for negotiating parties to develop their own language, provided that it contains the mandated elements. EPA and HUD eliminated the requirement that parties use a single form. Instead, the final rule mandates only the information elements that must be included without mandating specific formats or forms.

This flexibility is especially important to States that have developed, or are considering developing, their own disclosure requirements. During the comment period, several States requested that the final rule provide flexibility for States to merge their forms with the Federal form, eliminating unnecessary duplication. Under the final rule, States and jurisdictions will be able to make changes to the format as necessary to retain consistency with State and local laws and customs.

The following is a discussion of the required elements.

(i) Seller, agent, and purchaser requirements. The final rule requires that each contract to sell target housing include an attachment containing specific disclosure and acknowledgment

elements, in the language of the contract (e.g., English, Spanish). The elements required are described below:

(A) The first required element is the Lead Warning Statement, consisting of the following language:

Every purchaser of any interest in residential real property on which a residential dwelling was built prior to 1978 is notified that such property may present exposure to lead from lead-based paint that may place young children at risk of developing lead poisoning. Lead poisoning in young children may produce permanent neurological damage, including learning disabilities, reduced intelligence quotient, behavioral problems, and impaired memory. Lead poisoning also poses a particular risk to pregnant women. The seller of any interest in residential real property is required to provide the buyer with any information on lead-based paint hazards from risk assessments or inspections in the seller's possession and notify the buyer of any known lead-based paint hazards. A risk assessment or inspection for possible lead-based paint hazards is recommended prior to purchase.

Congress mandated this language in section 1018(a)(3) of Title X. While several commenters recommended providing simpler language, EPA and HUD are constrained by the mandate and have retained the statement as proposed.

(B) The second required element is a statement disclosing the presence of any known lead-based paint and/or lead-based paint hazards in the target housing or indicating no knowledge of the presence of lead-based paint and/or lead-based paint hazards. The seller must also provide any additional information available concerning the known lead-based paint and/or lead-based paint hazards, such as the basis for the determination that lead-based paint and/or lead-based paint hazards exist in the housing, the location of the lead-based paint and/or lead-based paint hazards, and the condition of the painted surfaces. The statement must also list all records and reports pertaining to lead-based paint and/or lead-based paint hazards that are available to the seller and that have been provided to the purchaser. If no such records or reports are available to the seller, the statement must so indicate.

(C) The third element is a statement affirming that the purchaser has received the information noted in paragraph (B) above and the lead hazard information pamphlet required under section 406 of TSCA (15 U.S.C. 2696).

The pamphlet described above may be the Federal pamphlet entitled *Protect Your Family from Lead in Your Home* or a State-developed pamphlet that has been approved by EPA.

(D) The fourth required element is a statement that the purchaser has received a 10-day opportunity to conduct a risk assessment or inspection for the presence of lead-based paint and/or lead-based paint hazards (unless the parties have mutually agreed to a different period of time), before becoming obligated under the contract to purchase the housing. Alternatively, a purchaser who chooses to waive the risk assessment or inspection opportunity must so indicate in writing.

(E) The fifth required element is a statement by any agent involved in the transaction that the agent has informed the seller of the seller's obligations under 42 U.S.C. 4852d and that the agent is aware of his/her duty to ensure compliance with the requirements of this rule.

(F) The sixth required element is the signatures of the seller(s), agent(s), and purchaser(s), certifying the accuracy of their statements on the attachment, along with their dates of signature. These signatures document the acceptance by the parties of the information they have provided on the attachment as a whole and alert the various parties to their respective roles and responsibilities.

(ii) *Lessor, agent, and lessee requirements.* Each contract to lease target housing must include the following elements, as an attachment or within the contract, in the language of the contract (e.g., English, Spanish).

(A) The first required element is a Lead Warning Statement with the following language:

Housing built before 1978 may contain lead-based paint. Lead from paint, paint chips, and dust can pose health hazards if not managed properly. Lead exposure is especially harmful to young children and pregnant women. Before renting pre-1978 housing, lessors must disclose the presence of known lead-based paint and/or lead-based paint hazards in the dwelling. Lessees must also receive a federally approved pamphlet on lead poisoning prevention.

EPA and HUD received a considerable amount of comment regarding the language of the Lead Warning Statement used in the leasing disclosure attachment. EPA and HUD have developed a modified Lead Warning Statement for leasing transactions that uses simpler words and syntax than the

purchase warning statement required by Title X.

(B) The second required element is a statement disclosing the presence of any known lead-based paint and/or lead-based paint hazards in the target housing or indicating no knowledge of the presence of lead-based paint and/or lead-based paint hazards. The lessor shall also provide any additional information available concerning the known lead-based paint and/or lead-based paint hazards, such as the basis for the determination that lead-based paint and/or lead-based paint hazards exist; the location of the lead-based paint and/or lead-based paint hazards; and the condition of the painted surfaces. The statement must also list any records or reports pertaining to lead-based paint and/or lead-based paint hazards that are available to the lessor and that have been provided to the lessee. If no such records or reports are available to the lessor, the statement must so indicate.

(C) The third required element is a statement affirming that the lessee received the information noted in paragraph (B) above and the lead hazard information pamphlet required under section 406 of TSCA (15 U.S.C. 2686).

(D) The fourth required element is a statement by any agent involved in the transaction that the agent has informed the lessor of the lessor's obligations under the law and that the agent is aware of his/her duty to ensure compliance with the requirements of this rule.

(E) The fifth required element is the signatures of the lessor(s), agent(s), and lessee(s), certifying the accuracy of their statements, along with their dates of signature. These signatures document the acceptance by the parties of the information they have provided as a whole and alert the various parties to the roles and responsibilities of each party.

3. *Sample disclosure attachments.* Recognizing that many parties may prefer having access to a sample format, EPA and HUD have developed sample disclosure formats for sales and leasing contracts for public reference. These samples are not included in the regulatory text itself. Nothing in the rule requires the use of these specific formats if a seller or lessor wishes to develop a separate format that includes all of the required elements.

(Sample Disclosure Format for Target Housing Sales)

Disclosure of Information on Lead-Based Paint and/or Lead-Based Paint Hazards

Lead Warning Statement

Every purchaser of any interest in residential real property on which a residential dwelling was built prior to 1978 is notified that such property may present exposure to lead from lead-based paint that may place young children at risk of developing lead poisoning. Lead poisoning in young children may produce permanent neurological damage, including learning disabilities, reduced intelligence quotient, behavioral problems, and impaired memory. Lead poisoning also poses a particular risk to pregnant women. The seller of any interest in residential real property is required to provide the buyer with any information on lead-based paint hazards from risk assessments or inspections in the seller's possession and notify the buyer of any known lead-based paint hazards. A risk assessment or inspection for possible lead-based paint hazards is recommended prior to purchase.

Seller's Disclosure

(a) Presence of lead-based paint and/or lead-based paint hazards (check (i) or (ii) below):

(i) — Known lead-based paint and/or lead-based paint hazards are present in the housing (explain).

(ii) — Seller has no knowledge of lead-based paint and/or lead-based paint hazards in the housing.

(b) Records and reports available to the seller (check (i) or (ii) below):

(i) — Seller has provided the purchaser with all available records and reports pertaining to lead-based paint and/or lead-based paint hazards in the housing (list documents below).

(ii) — Seller has no reports or records pertaining to lead-based paint and/or lead-based paint hazards in the housing.

Purchaser's Acknowledgment (initial)

(c) — Purchaser has received copies of all information listed above.

(d) — Purchaser has received the pamphlet *Protect Your Family from Lead in Your Home*.

(e) — Purchaser has (check (i) or (ii) below):

(i) — received a 10-day opportunity (or mutually agreed upon period) to conduct a risk assessment or inspection for the presence of lead-based paint and/or lead-based paint hazards; or

(ii) — waived the opportunity to conduct a risk assessment or inspection for the presence of lead-based paint and/or lead-based paint hazards.

Agent's Acknowledgment (initial)

(f) — Agent has informed the seller of the seller's obligations under 42 U.S.C. 4852d and is aware of his/her responsibility to ensure compliance.

Certification of Accuracy

The following parties have reviewed the information above and certify, to the best of their knowledge, that the information they have provided is true and accurate.

_____	_____	_____	_____
Seller	Date	Seller	Date
_____	_____	_____	_____
Purchaser	Date	Purchaser	Date
_____	_____	_____	_____
Agent	Date	Agent	Date

(Sample Disclosure Format for Target Housing Rentals and Leases)

Disclosure of Information on Lead-Based Paint and/or Lead-Based Paint Hazards**Lead Warning Statement**

Housing built before 1978 may contain lead-based paint. Lead from paint, paint chips, and dust can pose health hazards if not managed properly. Lead exposure is especially harmful to young children and pregnant women. Before renting pre-1978 housing, lessors must disclose the presence of known lead-based paint and/or lead-based paint hazards in the dwelling. Lessees must also receive a federally approved pamphlet on lead poisoning prevention.

Lessor's Disclosure

(a) Presence of lead-based paint and/or lead-based paint hazards (Check (i) or (ii) below):

(i)—— Known lead-based paint and/or lead-based paint hazards are present in the housing (explain).

 (ii)——Lessor has no knowledge of lead-based paint and/or lead-based paint hazards in the housing.

(b) Records and reports available to the lessor (Check (i) or (ii) below):

(i)—— Lessor has provided the lessee with all available records and reports pertaining to lead-based paint and/or lead-based paint hazards in the housing (list documents below).

 (ii)——Lessor has no reports or records pertaining to lead-based paint and/or lead-based paint hazards in the housing.

Lessee's Acknowledgment (initial)

(c)——Lessee has received copies of all information listed above.

(d)——Lessee has received the pamphlet *Protect Your Family from Lead in Your Home*.

Agent's Acknowledgment (initial)

(e)—— Agent has informed the lessor of the lessor's obligations under 42 U.S.C. 4852d and is aware of his/her responsibility to ensure compliance.

Certification of Accuracy

The following parties have reviewed the information above and certify, to the best of their knowledge, that the information they have provided is true and accurate.

_____ Lessor	_____ Date	_____ Lessor	_____ Date
_____ Lessee	_____ Date	_____ Lessee	_____ Date
_____ Agent	_____ Date	_____ Agent	_____ Date

4. *Recordkeeping requirements.* EPA and HUD have retained the recordkeeping requirements under this rule largely as proposed. The seller and any agent are required to retain a copy of the completed disclosure and acknowledgment contract attachment (discussed below), required under §§ 35.92(a) and 745.113(a), for 3 years from the completion date of the sale. Similarly, the lessor and any agent are required to retain a copy of the completed lease or attachment, required under § 35.92(b) and § 745.113(b) of this rule for 3 years from the commencement of the leasing period. EPA and HUD have determined that a 3-year period is an appropriate amount of time to ensure compliance with the requirements of Title X and to support Federal compliance monitoring efforts. This recordkeeping requirement is not intended to place any limitations on civil suits under Title X or to otherwise affect a lessee's or purchaser's rights under the civil penalty provisions of section 1018(b)(3) of Title X.

EPA and HUD requested comment on whether the rule should include an additional recordkeeping provision requiring that property owners retain all records and reports of lead-based paint and/or lead-based paint hazards in the housing for the length of their ownership. Based on the statute's use of the term "available" lead hazard evaluation reports, EPA and HUD have determined that a specific recordkeeping requirement for such reports is beyond the scope of this regulation. EPA and HUD have, however, clarified "available" lead hazard evaluation reports to encompass records and reports in the possession of the seller or lessor or reasonably obtainable by the seller or lessor at the time of the disclosure. This approach recognizes that third parties may in some cases play an independent recordkeeping role for the seller or lessor.

While the Agencies do not mandate the retention of these records, EPA and HUD encourage sellers and lessors to retain relevant records in anticipation of future sale or lease. The information provided can help purchasers and occupants take exposure prevention precautions during later ownership or occupancy. The requirement to disclose the presence of known lead-based paint and/or lead-based paint hazards remains even if the seller or lessor is unable to locate the original reports quantifying the data. Section 1018 requires sellers and lessors to both (1) disclose the presence of known lead-based paint and/or lead-based paint hazards in the housing and (2) provide available

written records and reports to the purchaser or lessee. By mandating that both actions occur, Congress recognized the distinction between the two actions, and the fact that the seller or lessor might have actual knowledge of lead-based paint and/or lead-based paint hazards above and beyond that present in available reports.

5. *Failure to fully disclose before ratification of contracts.* As mandated by Title X, the disclosure of information, the provision of the lead hazard information pamphlet, and the purchaser's opportunity to conduct a risk assessment or inspection must occur before the purchaser or lessee becomes obligated under any contract to purchase or lease the dwelling. Section 1018(c) prohibits regulatory provisions that would "affect the validity or enforceability of any sale or contract for the purchase and sale or lease of any interest in residential real property or any loan, loan agreement, mortgage, or lien made or arising in connection with a mortgage loan" and states that nothing in the rule "shall create a defect in title." The disclosure requirements contained in this rule must occur prior to contract ratification and, as such, do not affect the validity of the subsequent contract. Nor does failure to conduct full disclosure before sale or lease affect the validity of the sales or leasing contract itself. Rather, purchasers seeking remedy for the non-disclosure may avail themselves of the civil remedies afforded by section 1018 of Title X.

6. *Opportunity to conduct a risk assessment or inspection.* Section 1018(a) requires that sellers provide purchasers with a 10-day opportunity to conduct a risk assessment or inspection for the presence of lead-based paint and/or lead-based paint hazards before becoming obligated under a purchase contract. The length of time may be shortened or lengthened by mutual agreement. In the proposed rule, EPA and HUD offered several approaches for implementing this provision of section 1018: (1) Establishing Federal standards for the implementation of the evaluation period, providing flexibility for adjustment by mutual consent; (2) limiting the regulatory text to the statutory language, thereby maximizing the discretion of the two parties in negotiating the terms; (3) codifying contract contingency language for use in complying with the final rule; and (4) establishing requirements for providing evaluation opportunities before the preparation of contracts.

Recognizing that home inspections for various hazards and housing defects are common occurrences during housing

transactions around the country, EPA and HUD believe that the market can incorporate this requirement into future transactions without detailed regulatory language. The final rule, therefore, steers away from the proposed rule's preferred approach of codifying Federal standards for the performance of the 10-day evaluation period provision.

However, EPA and HUD also recognize that some private sellers may choose to conduct their housing sales without the aid of a trained agent and may lack familiarity with the standard processes for conducting such evaluations in the sales transaction. For such persons, EPA and HUD are providing the following discussion of several likely approaches for implementing this provision.

First, some purchasers may choose to waive the opportunity for a risk assessment or inspection. Purchasers may be especially inclined to waive the opportunity in cases where the seller provides significant amounts of relevant information on the property during the disclosure process, or in cases where no children are expected to reside in the housing. If the purchaser chooses to waive the evaluation opportunity, the purchaser is still obligated to acknowledge receipt of the evaluation opportunity on the attachment, documenting this voluntary decision to waive the opportunity.

EPA and HUD expect that in most cases where the purchaser chooses to exercise his or her evaluation opportunity, the parties will develop and incorporate into the contract mutually agreeable terms for the conduct and completion of the evaluation opportunity. The final rule provides sellers and purchasers with broad flexibility to develop terms for performing the risk assessment or inspection.

As many commenters noted, home inspections are already common aspects of housing transactions. Frequently, these inspections are incorporated into the sales contracts as contingency clauses, providing mutual agreement on the timing, terms, and conduct of the inspection. Common terms addressed in these clauses include: (i) The starting and ending day of the inspection period; (ii) any contingencies and conditions tied to the contract regarding the inspection period; (iii) the process for removing any contingency or condition following the completion of the inspection; and (iv) the disposition of any earnest money provided by the purchaser before the opportunity to inspect. This general framework is one possible approach that parties can consider when developing mutually

agreeable terms for the evaluation period required by section 1018(a) of Title X.

While most commenters stressed the importance of providing flexibility for the parties to develop mutually

agreeable evaluation terms, many also recommended the inclusion of sample language as a reference. For the purpose of providing guidance on creating contract language, EPA and HUD have included the following sample contract

contingency clause for optional use. This language is offered as a sample only, and nothing in this rule imposes a requirement on either party to accept or reject this language in the current or modified form.

Sample Contract Contingency Language

This contract is contingent upon a risk assessment or inspection of the property for the presence of lead-based paint and/or lead-based paint hazards at the Purchaser's expense until 9 p.m. on the tenth calendar-day after ratification [*Insert date 10 days after contract ratification or a date mutually agreed upon*]. (Intact lead-based paint that is in good condition is not necessarily a hazard. See the EPA pamphlet *Protect Your Family From Lead in Your Home* for more information.) This contingency will terminate at the above predetermined deadline unless the Purchaser (or Purchaser's agent) delivers to the Seller (or Seller's agent) a written contract addendum listing the specific existing deficiencies and corrections needed, together with a copy of the inspection and/or risk assessment report. The Seller may, at the Seller's option, within _____ days after Delivery of the addendum, elect in writing whether to correct the condition(s) prior to settlement. If the Seller will correct the condition, the Seller shall furnish the Purchaser with certification from a risk assessor or inspector demonstrating that the condition has been remedied before the date of the settlement. If the Seller does not elect to make the repairs, or if the Seller makes a counter-offer, the Purchaser shall have _____ days to respond to the counter-offer or remove this contingency and take the property in "as is" condition or this contract shall become void. The Purchaser may remove this contingency at any time without cause.

E. Agent Responsibilities

Title X specifically addresses the responsibilities of agents, requiring them to ensure compliance with the provisions of the law. Agents fulfill this requirement by informing sellers or lessors of their obligations and by making sure that these activities are completed either by the seller or lessor or by the agent personally. Accordingly, 24 CFR 35.94(b) and 40 CFR 745.107(c) identify the seller's affirmative duty to disclose to the agent any known lead-based paint and/or lead-based paint hazards on the property. Provided that the agent has actually informed the seller or lessor of his/her obligation, the final rule notes that the agent will not be responsible for information withheld from the agent by the seller or lessor.

V. Non-Compliance and Enforcement

EPA and HUD received considerable comment on the enforcement provisions discussed in the statute and the proposed rule. Many commenters requested more guidance regarding the Agencies' plans for enforcement of the provisions, as well as assurances that the Agencies recognize the importance of active education and outreach to the regulated community. As all enforcement authority for EPA and HUD

derives directly from the authorizing statutory language, both the proposed rule and the final rule contain enforcement language that is essentially the same as language provided in Title X and TSCA. The following is a discussion of the general enforcement authority provided by Congress, along with some discussion of the process that EPA and HUD will use in developing a sensible, effective enforcement approach.

A. HUD Authority

Section 1018(b)(1) of Title X authorizes HUD to impose civil monetary penalties on any person who knowingly violates section 1018. This authority applies to violations of this final rule as well. HUD can impose penalties under section 102 of the Department of Housing and Urban Development Reform Act of 1989 (42 U.S.C. 3545). These penalties may be up to \$10,000 for each violation. In addition, section 1018(b)(2) of Title X authorizes the Secretary to "take such lawful action as may be necessary to enjoin any violation" of the law's provisions.

B. EPA Authority

1. *Civil.* Section 1018(b)(5) of Title X provides that failure or refusal to comply with section 1018 or its implementing regulations is a violation of TSCA section 409. Violations of TSCA section 409 are subject to TSCA section 16 penalties. Thus, a violator of section 1018 can be subject to the penalty provisions under TSCA section 16 of up to \$10,000 for each violation.

2. *Criminal.* TSCA section 16(b) provides that any person who knowingly or willfully violates section 409 (and thus section 1018) could, in addition to or instead of any civil penalty, be subject, upon conviction, to a fine of not more than \$25,000 for each day of violation or to imprisonment for not more than 1 year, or both. For the purposes of enforcement under section 1018, Congress has modified the application of TSCA section 16, limiting the fine to \$10,000 "for each violation."

C. Enforcement Responses

Because the enforcement provisions of section 1018 are clearly set forth in the statute, the final rule retains largely unchanged the discussion of the enforcement authority.

However, it is EPA's and HUD's intent that outreach and compliance assistance

will be a major component of the section 1018 compliance program so that individuals are fully informed of the new requirements and their obligations. EPA and HUD also intend to bring clarity and predictability to the enforcement process for section 1018, in acknowledgment of the large and diverse population affected by this rule. Concurrent with this rule's release, EPA will issue a short "Statement of Approach" as it relates to ensuring compliance with the requirements of section 1018, for the information of the general public. This informational document will discuss the Agency's approach to the section 1018 compliance assurance program. EPA is also developing a policy for use by EPA enforcement personnel to achieve a common sense result between a particular violation of section 1018 and a particular enforcement response. This policy includes, but is not limited to, issuing notices of warning (without penalties) as appropriate to let people know that they are out of compliance and to give them an opportunity to come into compliance, while maintaining provisions that will ensure that willful and repeat violators are appropriately penalized. This result is reached in the context of an "Enforcement Response Policy" (ERP), which EPA is developing separately for this rule.

Regarding HUD enforcement actions, HUD's civil money penalty procedures are set out in 24 CFR part 30. These procedures include notices of intent to request civil money penalties, civil money penalty panels, administrative hearings and appeals, judicial review, and collection of penalties. A civil money penalty panel develops guidelines to determine the appropriate penalty for a violation of section 1018. These guidelines include the following factors: the gravity of the offense, awareness of procedures, any history of prior offenses, the ability to pay the penalty, the injury to the public, any benefits received by the violator, any potential benefits to other persons, deterrence of future violators, the violator's culpability, and such other matters as justice may require.

D. Civil Liability--Direct Compensation

In addition to the EPA and HUD enforcement authority for the provisions of this final rule, section 1018(b)(3) of Title X states that "[A]ny person who knowingly violates the provisions of this section shall be jointly and severally liable to the purchaser or lessee in an amount equal to 3 times the amount of damages incurred by such individual." This provision allows the

purchaser or lessee to seek direct compensation for any damages incurred based on the seller's or lessor's noncompliance. Section 1018(b)(4) authorizes the court to award court costs, reasonable attorney fees, and expert witness fees to a prevailing plaintiff.

E. Validity of Contracts and Liens

Section 1018(c) provides that nothing in section 1018 (or its implementing rules) "shall affect the validity or enforceability of any sale or contract for the purchase and sale or lease of any interest in residential real property or any loan, loan agreement, mortgage, or lien made or arising in connection with a mortgage loan. . . ." It also provides that nothing in section 1018 (or its implementing rules) shall "create a defect in title."

EPA and HUD have looked at section 1018(c) in the context of other section 1018 provisions, which outline specific clauses that must be attached to contracts for the purchase and sale of target housing and specific procedural protections that must be given to the purchaser or lessee.

The provisions of section 1018 cannot void or nullify the contract after ratification and cannot void any transfer of real estate, even if it can be proven that the seller or lessor violated section 1018 provisions. In such circumstances, the purchaser or lessee is limited to the remedies provided in section 1018. Of course, traditional causes of action under State law would still exist, and possibly could be applied to some section 1018 violations. Also, violations of section 1018 could be subject to civil and criminal penalties administered by EPA and HUD under section 1018(b).

VI. Federal Effect on State and Local Disclosure Requirements

Several commenters noted that some States and municipalities already have requirements for the disclosure of information on lead-based paint in housing. In developing the Federal disclosure requirements, several key questions have been raised regarding such programs: (1) Can States obtain authorization to administer and enforce their programs in lieu of the Federal program? and (2) What effect do the Federal requirements have on the ability of States to run their own programs?

EPA and HUD have determined that Title X does not provide authority to delegate the administration and enforcement of these section 1018 requirements to State programs. Where such authority to authorize State programs was anticipated by Congress

(as in TSCA section 402), Congress provided specific authority.

Where possible, EPA and HUD have developed these requirements to make it possible for State and Federal requirements to complement each other. For example, EPA and HUD had State programs in mind when adding flexibility in the development of disclosure and acknowledgment attachments.

Finally, nothing in this rule is intended to relieve a seller, lessor, or agent from any responsibility for compliance with State or local laws, ordinances, codes, or regulations governing notice or disclosure of known lead-based paint and/or lead-based paint hazards.

VII. Summary of Regulatory Impact Analysis

EPA and HUD have prepared a Regulatory Impact Analysis (RIA) that examines the potential costs, benefits, and impacts of regulations for the disclosure of known lead-based paint hazards in residential property upon the transfer of the property for sale or rental. The analysis is presented in five sections:

- Background and Framework for Analysis
- Profile of Sectors Affected
- Estimated Costs to Private Parties and Government
- Effect of the Lead-Based Paint Hazard Disclosure Rule for Real Estate Transfers on Small Businesses—Regulatory Flexibility Analysis
- Assessment of Benefits

A. Background and Framework for Analysis

Those parties directly affected by the rule are the seller, lessor, agent, property manager, purchaser, and lessee. The required activities that impose regulatory burden on the affected parties fall into four categories for cost estimation purposes:

1. Start-up costs, which include learning the rule's requirements and establishing compliance procedures;
2. Disclosure costs, which refer to the costs resulting from the actual transfer of information and obtaining needed signatures;
3. Recordkeeping costs, which result principally from the requirement that signed acknowledgment forms must be retained by the provider of the information; and
4. Materials costs, which are linked primarily to the disclosure requirement, as the lead hazard information pamphlet must be purchased or photocopied (acknowledgment forms must also be duplicated). Costs may also be incurred

for filing where a large number of acknowledgment statements or documents for disclosure are generated (e.g., by agents), though such burden was estimated to be quite modest.

The requirements of section 1018 of the Act fall primarily on the seller or lessor of "target housing," which is defined to be any housing constructed prior to 1978, except housing for the elderly or persons with disabilities (unless any child who is less than 6 years of age resides or is expected to reside in such housing) or any 0-bedroom dwelling. However, if an agent or property manager acts on behalf of the seller or lessor, which EPA and HUD have estimated to be the case in most transfers, responsibilities to ensure compliance fall to such agents or managers as well.

To estimate the impacts of the rule, EPA and HUD sought data pertaining to the number of affected parties in each classification listed above, the frequency with which affected purchase and lease transactions are completed, and the incremental costs, in labor and materials, added to each transaction by the regulations.

B. Profile of Sectors Affected

The larger of the two affected sectors expected to bear the principal effects of

the rule falls within Standard Industrial Classification (SIC) code 651, Real Estate Operators and Lessors. EPA estimates there to be 92,000 establishments potentially affected by the rule. Also affected are business establishments falling within SIC code 653, Real Estate Agents and Managers. An additional 92,000 establishments could be affected by the rule in this sector.

Employment data were obtained for the occupations most likely to be involved in transactions subject to the rule. EPA and HUD estimate that 324,000 real estate agents and 243,000 property managers will be affected.

With regard to transaction volume, 2.9 million sales transactions and 9.3 million rental transactions were estimated to occur annually in target housing.

C. Estimated Costs to Private Parties and Government

Table 1 below summarizes the estimated annual costs associated with the rule. The four costs to private parties, or compliance costs, are discussed briefly below. Costs to government represent rule administration activities.

The first private party cost category, start-up costs, represents about one-

third of overall annual compliance costs. Factors affecting the magnitude of these costs include the number of employees having to familiarize themselves with the regulations, both initially (employees in the existing workforce) and over time (new entrants to the affected sectors); the time required to learn the activities that must be undertaken in order to comply; and the hourly compensation of affected employees.

As Table 1 shows, disclosure event costs constitute the greatest portion of overall compliance costs. Factors affecting the magnitude of these costs include the frequencies of regulated events; the time involved in performing required activities, such as providing to the prospective purchaser/lessee the required information and obtaining the required signatures; and the hourly compensation of all involved parties. EPA and HUD also took into account the fact that a number of States have similar requirements pertaining to information transfer regarding potential lead hazards in the sale of residential property. Thus, an allowance was made in the burden estimates for transactions occurring in such States to reflect a certain level of current compliance.

Table 1—Summary of Annual Costs of the Disclosure Rule for Residential Property Transfer

Estimated Annual Costs to Private Parties - Sales Transactions

Start-up Costs*	\$25.8 million
Disclosure Event Costs	20.2 million
Recordkeeping Costs	0.6 million
Materials Costs	2.8 million
<hr/>	
<i>Total for Sales Transactions:</i>	\$49.4 million

Estimated Annual Costs to Private Parties - Rental Transactions

Start-up Costs*	\$ 1.1 million
Disclosure Event Costs	\$25.6 million
Recordkeeping Costs	\$1.9 million
Materials Costs	\$3.4 million
<hr/>	
<i>Total for Rental Transactions:</i>	\$32.0 million

Total Estimated Annual Costs to Private Parties:

Costs to Government	\$81.4 million
Low Estimate	\$2.4 million
High Estimate	\$4.3 million

Total Estimated Annual Costs:

Based on Low Estimate of Government Costs:	\$83.8 million
Based on High Estimate of Government Costs:	\$85.7 million

* First-year costs annualized at 3 percent rate over 6 years.

Recordkeeping and materials costs account for a relatively modest share of

overall annual costs. Factors affecting the magnitude of these costs include the

number of affected parties per transaction; the frequency of

transactions, the costs of acquiring/duplicating documents, which include the lead hazard information pamphlet and signed acknowledgment forms; and costs to maintain documents.

Additional, indirect costs resulting from actions taken by consumers in response to the information made available by the rule were not quantified, for reasons detailed in Unit VII.E. of this preamble.

To administer the final regulation, resources will be required to conduct a number of activities, including: inspections; violation case management; establishment and maintenance of cooperative agreements; compliance assistance, development of performance measurement criteria; and management.

D. Effect of the Lead-Based Paint Hazard Disclosure Rule for Real Estate Transfers on Small Businesses--Regulatory Flexibility Analysis

EPA and HUD investigated the potential impacts of the rule on small businesses and have prepared a Regulatory Flexibility Analysis (RFA). Although a large number of small establishments may be affected by the rule, cost impacts were not found to be of sufficient magnitude to cause undue harm to such establishments. The RFA is summarized separately in Unit X.B. of this preamble.

E. Assessment of Benefits

The market imperfection that the rule is intended to correct is the lack of information available to prospective home purchasers and lessees concerning lead-based paint hazards in homes they may be considering for purchase or rent. Under the rule, general information about the risks associated with lead-based paint will be provided through the provision of a brochure. When available, information about the presence of or abatement of lead in the specific unit being considered for purchase or rent must also be disclosed (e.g., information concerning previous testing for the presence of lead-based paint, abatement history, etc.). The failure of the marketplace to provide this information or to provide prospective home purchasers and lessees the opportunity to develop such information means that prospective purchasers and lessees might purchase or lease a property, or make pricing or rental payment decisions regarding properties, without understanding possible lead-related health risks or risk management costs accompanying the transaction.

EPA and HUD expect that this rulemaking will generate benefits by giving prospective home purchasers and

lessees access to information that might otherwise have been unavailable (e.g., information pertaining to abatement activities for a specific residence) or that they might have been able to acquire only through their own effort and at some cost. In addition, EPA believes the information will generate health benefits by leading many purchasers and lessees to modify their behavior in a way that will reduce risks from lead-based paint. For example, purchasers could undertake abatement activities subsequent to taking ownership of a dwelling, change household cleaning practices, or request professional assistance when undertaking renovation activities. The rule may also prompt property owners, due to reluctance on the part of prospective purchasers/lessees to select housing containing lead-based paint, to act to reduce lead-related hazards associated with their residential dwellings. Health benefits resulting from such activities are distinguishable from the more direct benefits of the rule, i.e., the value of improved information. Further, in cases where action is taken to remediate a lead-based paint hazard, additional costs would be incurred, and would have to be subtracted from the expected benefits associated with the remediation.

EPA and HUD note that the regulation does not require actions to reduce lead-based paint hazards in residential housing. Thus, the extent to which lead exposure decreases depends upon how transaction participants (i.e., sellers/lessors and prospective purchasers/lessees) value and respond to the additional information.

The RIA details three approaches that are evolving and that can be seen as a starting point in an effort to expand the level of understanding of how benefits from information products can be valued. However, an information base and the associated accepted analytical methods necessary to predict consumer reaction to information products on lead-based paint hazards are not readily available; thus, quantifying the expected benefits of this rule, either in terms of efficiency gains from improved decisionmaking or risk reduction, would be extremely difficult. Given the high level of uncertainty associated with the results from such a quantitative analysis, and given the prescriptive nature of section 1018 of the Act, EPA and HUD believe that the information provided in the qualitative analysis presented in the RIA served to inform decisionmaking.

VIII. Rulemaking Record

A record for this final rule has been established for both EPA and HUD under docket number "OPPTS-62130." The public version of this record for both agencies (which does not contain any information claimed as Confidential Business Information) is available for inspection from 12 noon to 4 p.m., Monday through Friday, excluding legal holidays. The public record is located in EPA's TSCA Nonconfidential Information Center (NCIC), Rm. NE-B607, 401 M St., SW., Washington, DC 20460.

The docket contains reference works that EPA and HUD referred to in developing this regulation. In addition, other documents, including the Regulatory Impact Analysis, Information Collection Request, and copies of all comments on the proposed rule, are included in the docket for public review. The draft of the final rule submitted by EPA and HUD to OMB for review prior to the final rule's promulgation will also be contained in the docket.

IX. References

1. Alliance to End Childhood Lead Poisoning, 1991. *Preventing Childhood Lead Poisoning: The First Comprehensive National Conference; Final Report*. Washington, DC.
2. CDC, 1991. U.S. Centers for Disease Control and Prevention, *Preventing Lead Poisoning in Young Children: A Statement by the Centers for Disease Control*. Atlanta, GA.
3. CPSC, 1977. *Notice Reducing Allowable Levels of Lead in Lead-Based Paint*. Federal Register. September 1, 1977: 42 FR 44199.
4. EPA, 1995. U.S. Environmental Protection Agency, *Report on the National Survey of Lead-Based Paint in Housing: Base Report*. Washington, DC: EPA747-R95-003.
5. HUD, 1995. U.S. Department of Housing and Urban Development, Task Force on Lead-Based Paint Hazard Reduction and Financing, *Putting the Pieces Together: Controlling Lead Hazards in the Nation's Housing: Final Report*. Washington, DC: HUD-1542-LBP.
6. HUD, 1990. *Lead-Based Paint; Interim Guidelines for Hazard Identification and Abatement in Public and Indian Housing; Notice*. Federal Register. April 18, 1990: 55 FR 14556.
7. HUD, 1995. Department of Housing and Urban Development, *Guidelines for the Evaluation and Control of Lead-Based Paint Hazards in Housing*. Washington, DC.
8. Pirkle, 1994. Pirkle, J.L., D.J. Brody, E.W. Gunter, R.A. Kramer, D.C. Paschal,

K.M. Flegal, T.D. Matte, *The Decline in Blood Lead Levels in the United States*. Journal of the American Medical Association, 272(4): 284-291.

X. Regulatory Assessment Requirements

A. Executive Order 12866

Pursuant to Executive Order 12866 (58 FR 51735, October 4, 1993), it has been determined that this is a "significant regulatory action" because of potential novel legal or policy issues arising out of the new legal mandates this action implements. This action was submitted to OMB for review, and any comments or changes made during that review have been documented in the public record.

In addition, EPA and HUD have prepared a Regulatory Impact Analysis (RIA) in conjunction with their lead information disclosure rule for real estate transfers. EPA and HUD find that the rule will not have an effect on the economy of \$100 million or more, will not result in major increases in costs or prices, and is not anticipated to have significant adverse effects on competition, employment, investment, or productivity in the relevant sectors.

EPA and HUD estimate the overall costs to affected entities to be \$81.4 million and costs to government to range from \$2.4 to \$4.3 million. These estimates include costs for rule familiarization, information disclosure and obtaining required signatures, recordkeeping, materials costs, and government administration costs. EPA and HUD estimate that the provisions of the rule will add about \$2.00 to \$6.00 to the cost of each transaction.

A copy of the RIA is available in the TSCA Public Docket Office for review and public comment. For information on the public docket, see Unit VIII. of this preamble, entitled Rulemaking Record.

B. Regulatory Flexibility Act

The Regulatory Flexibility Act (5 U.S.C. 601 et seq.) requires Federal agencies to consider whether a regulatory action will have an adverse economic impact on small entities. Section 605(b) requires the agencies to either certify that the regulatory action will not have a significant economic impact on a substantial number of small entities, or prepare a Regulatory Flexibility Analysis. Under the EPA policy that implements the Regulatory Flexibility Act, EPA performs a Regulatory Flexibility Analysis whenever a regulatory action is anticipated to have any economic impact on any small entities, and will

also seek to involve these small entities in the development of the regulatory action to the extent possible. As such, in an effort to identify and characterize the rule's effects on small business, EPA and HUD have prepared a Regulatory Flexibility Analysis. This assessment has been included as part of the RIA and is summarized below.

In preparing the RFA, EPA and HUD first developed an establishment profile for each major sector (SIC 651 and SIC 653). This profile indicated that approximately 75 percent of all establishments in SIC 651 (Real Estate Operators and Lessors) and approximately 73 percent of all establishments in SIC 653 (Real Estate Agents and Managers) fell within the 1 to 4 employee size class. These proportions increased to 90 percent and 87 percent, respectively, when employee size class 1 to 9 was examined.

To measure the cost impacts of the rule on these small establishments, representative or model establishments were designed. These model establishments corresponded to typical establishments in each affected sector, with respect to number of employees and annual transaction volume. Since transaction activity was reported to vary widely, a range of transaction volume was estimated for each establishment type.

For each model establishment, annual regulatory costs were then calculated and compared to annual labor and overhead costs. Ratios were computed for both high and low estimates of the range of transaction activity. In the case of a real estate sales organization, regulatory costs were found to represent from 0.20 to 0.42 percent of labor and overhead costs. In the case of a rental establishment, impacts were slightly higher, ranging from 0.21 to 0.47 percent. An establishment engaged in both activities was projected to sustain impacts of 0.28 to 0.63 percent.

Thus, while a large number of small establishments will be potentially affected by the rule, cost impacts were not found to be of sufficient magnitude to cause undue harm to such establishments. Consequently, no regulatory alternatives are being proposed in connection with small business impacts.

C. Paperwork Reduction Act

The information collection requirements in this rule have been submitted for approval to the Office of Management and Budget (OMB) under the Paperwork Reduction Act, 44 U.S.C. 3501 et seq. An Information Collection Request (ICR) document has been

prepared by EPA (EPA ICR No. 1710.02) and a copy may be obtained from Sandy Farmer, OPPE Regulatory Information Division, Environmental Protection Agency (2136), 401 M St., SW., Washington, DC 20460 or by calling (202) 260-2740. The information requirements are not effective until OMB approves them.

The information collection requirements of this rule apply to sellers, lessors, and agents of target housing. Before selling or leasing target housing, the following information collection activities must occur: (1) Disclosure of known lead-based paint and/or lead-based paint hazards; (2) provision of any available records and reports pertaining to lead-based paint in the housing; (3) provision of a federally approved lead hazard information pamphlet; (4) completion and subsequent retention of disclosure and acknowledgment language for 3 years, and (5) provision of a 10-day evaluation opportunity to purchasers before obligation under purchase contracts (this time period can be adjusted or waived by mutual consent).

These requirements will help to: (1) Ensure that purchasers and renters of older housing make informed housing and maintenance decisions before they become obligated under purchase or lease contracts; (2) ensure that all participants in target housing sales and leasing transactions fully understand their rights and obligations under section 1018 and the implementing regulations; (3) document the completion of all disclosure activities by the responsible parties; and (4) provide a record of compliance for use by EPA and HUD enforcement officials. Under the authority of section 1018 of Title X, the information collection requirements of this rule are mandatory for all applicable sales and leasing transactions.

The annual costs to private parties to comply with the requirements of the rule are estimated to be \$81.4 million, with an associated burden of 7.1 million hours. Annual costs may be broken down into two components: Initialization or start-up costs, estimated to be \$26.9 million (annualized at 3 percent over 3 years); and costs for information disclosure and maintenance of records, estimated to be \$54.5 million. Annual burden is estimated to be distributed among 35.1 million responses, averaging 12.2 minutes per response. The number of respondents is estimated to be 15.5 million. Burden means the total time, effort, or financial resources expended by persons to generate, maintain, retain, or disclose or provide information to or for a Federal

agency. This includes the time needed to review instructions; develop, acquire, install, and utilize technology and systems for the purposes of collecting, validating, and verifying information, processing and maintaining information, and disclosing and providing information; adjust the existing ways to comply with any previously applicable instructions and requirements; train personnel to respond to a collection of information; search data sources; complete and review the collection of information; and transmit or otherwise disclose the information.

An Agency may not conduct or sponsor, and a person is not required to respond to, a collection of information unless it displays a currently valid OMB control number. The OMB control numbers for EPA's regulations are listed in 40 CFR part 9 and 48 CFR Chapter 15. Upon OMB approval, EPA will issue a notice in the Federal Register to announce OMB's approval and to make a technical amendment to include a reference to this approval in 40 CFR part 9.

Send comments on the burden estimates and any suggested methods for minimizing respondent burden, including through the use of automated collection techniques, to the Director, OPPE Regulatory Information Division, Environmental Protection Agency (2136), 401 M St., SW., Washington, DC 20460, and to the Office of Information and Regulatory Affairs, Office of Management and Budget, 725 17th St., NW., Washington, DC 20503, marked "Attention: Desk Officer for EPA." Include the ICR number in any correspondence.

D. Environmental Impact

In accordance with 40 CFR 1508.4 of the regulations of the Council on Environmental Quality and 24 CFR 50.19 and 50.20(o)(2) of the HUD regulations, the policies and procedures contained in this final rule relate only to information services and are, therefore, categorically excluded from the requirements of the National Environmental Policy Act.

E. HUD's Regulatory Agenda

This rule was listed as Item No. 1517 in HUD's Semiannual Agenda of Regulations published on April 25, 1994 (59 FR 20424), in accordance with Executive Order 12866 and the Regulatory Flexibility Act, and was requested by and submitted to the Committee on Banking, Finance and Urban Affairs of the House of Representatives under section 7(o) of

the Department of Housing and Urban Development Act.

F. Unfunded Mandates Reform Act

Pursuant to Title II of the Unfunded Mandates Reform Act of 1995, which the President signed into law on March 22, 1995, EPA and HUD have assessed the effects of this regulatory action on State, local, and tribal governments, and the private sector. This action is not an "unfunded mandate" as defined by that statute and will not result in the expenditure of \$100 million or more by any State, local, or tribal government, or by the private sector. Nevertheless, EPA and HUD consulted with several State, local, and tribal governments during the development.

A copy of the RIA is available for public review. For information on the public docket, see Unit VIII. of this preamble, entitled Rulemaking Record.

List of Subjects in 24 CFR Part 35

Environmental protection, Grant programs-housing and community development, Hazardous substances, Lead, Lead poisoning, Mortgage insurance, Rent subsidies, Reporting and recordkeeping requirements.

List of Subjects in 40 CFR Part 745

Environmental protection, Hazardous substances, Lead, Recordkeeping and notification requirements.

Dated: February 29, 1996.
Henry Cisneros,
Secretary, Department of Housing and Urban Development.

Dated: February 29, 1996.
Carol M. Browner,
Administrator, Environmental Protection Agency.

Therefore, 24 CFR subtitle A and 40 CFR Chapter I are amended as follows:
24 CFR Subtitle A

PART 35—LEAD-BASED PAINT POISONING PREVENTION IN CERTAIN RESIDENTIAL STRUCTURES

1. The authority citation for part 35 is revised to read as follows:

Authority: 42 U.S.C. 3535(d), 4821-4846 and 4852d.

2. A new subpart H is added to part 35 to read as follows:

Subpart H—Disclosure of Known Lead-Based Paint and/or Lead-Based Paint Hazards Upon Sale or Lease of Residential Property

Sec.	
35.80	Purpose.
35.82	Scope and applicability.
35.84	Effective dates.
35.86	Definitions.

35.88	Disclosure requirements for sellers and lessors.
35.90	Opportunity to conduct an evaluation.
35.92	Certification and acknowledgment of disclosure.
35.94	Agent responsibilities.
35.96	Enforcement.
35.98	Impact on State and local requirements.

Subpart H—Disclosure of Known Lead-Based Paint and/or Lead-Based Paint Hazards Upon Sale or Lease of Residential Property

§ 35.80 Purpose.

This subpart implements the provisions of 42 U.S.C. 4852d, which impose certain requirements on the sale or lease of target housing. Under this subpart, a seller or lessor of target housing shall disclose to the purchaser or lessee the presence of any known lead-based paint and/or lead-based paint hazards; provide available records and reports; provide the purchaser or lessee with a lead hazard information pamphlet; give purchasers a 10-day opportunity to conduct a risk assessment or inspection; and attach specific disclosure and warning language to the sales or leasing contract before the purchaser or lessee is obligated under a contract to purchase or lease target housing.

§ 35.82 Scope and applicability.

This subpart applies to all transactions to sell or lease target housing, including subleases, with the exception of the following:

- (a) Sales of target housing at foreclosure.
- (b) Leases of target housing that have been found to be lead-based paint free by an inspector certified under the Federal certification program or under a federally accredited State or tribal certification program. Until a Federal certification program or federally accredited State certification program is in place within the State, inspectors shall be considered qualified to conduct an inspection for this purpose if they have received certification under any existing State or tribal inspector certification program. The lessor has the option of using the results of additional test(s) by a certified inspector to confirm or refute a prior finding.
- (c) Short-term leases of 100 days or less, where no lease renewal or extension can occur.

(d) Renewals of existing leases in target housing in which the lessor has previously disclosed all information required under § 35.88 and where no new information described in § 35.88 has come into the possession of the lessor. For the purposes of this

paragraph, renewal shall include both renegotiation of existing lease terms and/or ratification of a new lease.

§ 35.84 Effective dates.

The requirements in this subpart take effect in the following manner:

(a) For owners of more than four residential dwellings, the requirements shall take effect on September 6, 1996.

(b) For owners of one to four residential dwellings, the requirements shall take effect on December 6, 1996.

§ 35.86 Definitions.

The following definitions apply to this subpart.

The Act means the Residential Lead-Based Paint Hazard Reduction Act of 1992, 42 U.S.C. 4852d.

Agent means any party who enters into a contract with a seller or lessor, including any party who enters into a contract with a representative of the seller or lessor, for the purpose of selling or leasing target housing. This term does not apply to purchasers or any purchaser's representative who receives all compensation from the purchaser.

Available means in the possession of or reasonably obtainable by the seller or lessor at the time of the disclosure.

Common area means a portion of a building generally accessible to all residents/users including, but not limited to, hallways, stairways, laundry and recreational rooms, playgrounds, community centers, and boundary fences.

Contract for the purchase and sale of residential real property means any contract or agreement in which one party agrees to purchase an interest in real property on which there is situated one or more residential dwellings used or occupied, or intended to be used or occupied, in whole or in part, as the home or residence of one or more persons.

EPA means the Environmental Protection Agency.

Evaluation means a risk assessment and/or inspection.

Foreclosure means any of the various methods, statutory or otherwise, known in different jurisdictions, of enforcing payment of a debt, by the taking and selling of real property.

Housing for the elderly means retirement communities or similar types of housing reserved for households composed of one or more persons 62 years of age or more at the time of initial occupancy.

Inspection means:

(1) A surface-by-surface investigation to determine the presence of lead-based paint as provided in section 302(c) of

the Lead-Based Paint Poisoning and Prevention Act [42 U.S.C. 4822], and

(2) The provision of a report explaining the results of the investigation.

Lead-based paint means paint or other surface coatings that contain lead equal to or in excess of 1.0 milligram per square centimeter or 0.5 percent by weight.

Lead-based paint free housing means target housing that has been found to be free of paint or other surface coatings that contain lead equal to or in excess of 1.0 milligram per square centimeter or 0.5 percent by weight.

Lead-based paint hazard means any condition that causes exposure to lead from lead-contaminated dust, lead-contaminated soil, or lead-contaminated paint that is deteriorated or present in accessible surfaces, friction surfaces, or impact surfaces that would result in adverse human health effects as established by the appropriate Federal agency.

Lessee means any entity that enters into an agreement to lease, rent, or sublease target housing, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations.

Lessor means any entity that offers target housing for lease, rent, or sublease, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations.

Owner means any entity that has legal title to target housing, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations, except where a mortgagee holds legal title to property serving as collateral for a mortgage loan, in which case the owner would be the mortgagor.

Purchaser means an entity that enters into an agreement to purchase an interest in target housing, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations.

Reduction means measures designed to reduce or eliminate human exposure to lead-based paint hazards through methods including interim controls and abatement.

Residential dwelling means:

(1) A single-family dwelling, including attached structures such as porches and stoops; or
(2) A single-family dwelling unit in a structure that contains more than one separate residential dwelling unit, and

in which each such unit is used or occupied, or intended to be used or occupied, in whole or in part, as the residence of one or more persons.

Risk assessment means an on-site investigation to determine and report the existence, nature, severity, and location of lead-based paint hazards in residential dwellings, including:

(1) Information gathering regarding the age and history of the housing and occupancy by children under age 6;

(2) Visual inspection;

(3) Limited wipe sampling or other environmental sampling techniques;

(4) Other activity as may be appropriate; and

(5) Provision of a report explaining the results of the investigation.

Seller means any entity that transfers legal title to target housing, in whole or in part, in return for consideration, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations. The term "seller" also includes:

(1) An entity that transfers shares in a cooperatively owned project, in return for consideration; and

(2) An entity that transfers its interest in a leasehold, in jurisdictions or circumstances where it is legally permissible to separate the fee title from the title to the improvement, in return for consideration.

Target housing means any housing constructed prior to 1978, except housing for the elderly or persons with disabilities (unless any child who is less than 6 years of age resides or is expected to reside in such housing) or any 0-bedroom dwelling.

TSCA means the Toxic Substances Control Act, 15 U.S.C. 2601.

0-bedroom dwelling means any residential dwelling in which the living area is not separated from the sleeping area. The term includes efficiencies, studio apartments, dormitory housing, military barracks, and rentals of individual rooms in residential dwellings.

§ 35.88 Disclosure requirements for sellers and lessors.

(a) The following activities shall be completed before the purchaser or lessee is obligated under any contract to purchase or lease target housing that is not otherwise an exempt transaction pursuant to § 35.82. Nothing in this section implies a positive obligation on the seller or lessor to conduct any evaluation or reduction activities.

(1) The seller or lessor shall provide the purchaser or lessee with an EPA-approved lead hazard information

pamphlet. Such pamphlets include the EPA document entitled *Protect Your Family From Lead in Your Home* (EPA #747-K-94-001) or an equivalent pamphlet that has been approved for use in that State by EPA.

(2) The seller or lessor shall disclose to the purchaser or lessee the presence of any known lead-based paint and/or lead-based paint hazards in the target housing being sold or leased. The seller or lessor shall also disclose any additional information available concerning the known lead-based paint and/or lead-based paint hazards, such as the basis for the determination that lead-based paint and/or lead-based paint hazards exist, the location of the lead-based paint and/or lead-based paint hazards, and the condition of the painted surfaces.

(3) The seller or lessor shall disclose to each agent the presence of any known lead-based paint and/or lead-based paint hazards in the target housing being sold or leased and the existence of any available records or reports pertaining to lead-based paint and/or lead-based paint hazards. The seller or lessor shall also disclose any additional information available concerning the known lead-based paint and/or lead-based paint hazards, such as the basis for the determination that lead-based paint and/or lead-based paint hazards exist, the location of the lead-based paint and/or lead-based paint hazards, and the condition of the painted surfaces.

(4) The seller or lessor shall provide the purchaser or lessee with any records or reports available to the seller or lessor pertaining to lead-based paint and/or lead-based paint hazards in the target housing being sold or leased. This requirement includes records and reports regarding common areas. This requirement also includes records and reports regarding other residential dwellings in multifamily target housing, provided that such information is part of an evaluation or reduction of lead-based paint and/or lead-based paint hazards in the target housing as a whole.

(b) If any of the disclosure activities identified in paragraph (a) of this section occurs after the purchaser or lessee has provided an offer to purchase or lease the housing, the seller or lessor shall complete the required disclosure activities prior to accepting the purchaser's or lessee's offer and allow the purchaser or lessee an opportunity to review the information and possibly amend the offer.

§ 35.90 Opportunity to conduct an evaluation.

(a) Before a purchaser is obligated under any contract to purchase target housing, the seller shall permit the purchaser a 10-day period (unless the parties mutually agree, in writing, upon a different period of time) to conduct a risk assessment or inspection for the presence of lead-based paint and/or lead-based paint hazards.

(b) Notwithstanding paragraph (a) of this section, a purchaser may waive the opportunity to conduct the risk assessment or inspection by so indicating in writing.

§ 35.92 Certification and acknowledgment of disclosure.

(a) *Seller requirements.* Each contract to sell target housing shall include an attachment containing the following elements, in the language of the contract (e.g., English, Spanish):

(1) A Lead Warning Statement consisting of the following language:

Every purchaser of any interest in residential real property on which a residential dwelling was built prior to 1978 is notified that such property may present exposure to lead from lead-based paint that may place young children at risk of developing lead poisoning. Lead poisoning in young children may produce permanent neurological damage, including learning disabilities, reduced intelligence quotient, behavioral problems, and impaired memory. Lead poisoning also poses a particular risk to pregnant women. The seller of any interest in residential real property is required to provide the buyer with any information on lead-based paint hazards from risk assessments or inspections in the seller's possession and notify the buyer of any known lead-based paint hazards. A risk assessment or inspection for possible lead-based paint hazards is recommended prior to purchase.

(2) A statement by the seller disclosing the presence of known lead-based paint and/or lead-based paint hazards in the target housing being sold or indicating no knowledge of the presence of lead-based paint and/or lead-based paint hazards. The seller shall also provide any additional information available concerning the known lead-based paint and/or lead-based paint hazards, such as the basis for the determination that lead-based paint and/or lead-based paint hazards exist, the location of the lead-based paint and/or lead-based paint hazards, and the condition of the painted surfaces.

(3) A list of any records or reports available to the seller pertaining to lead-based paint and/or lead-based paint hazards in the housing that have been provided to the purchaser. If no such

records or reports are available, the seller shall so indicate.

(4) A statement by the purchaser affirming receipt of the information set out in paragraphs (a)(2) and (a)(3) of this section and the lead hazard information pamphlet required under section 15 U.S.C. 2696.

(5) A statement by the purchaser that he/she has either:

(i) Received the opportunity to conduct the risk assessment or inspection required by § 35.90(a); or
(ii) Waived the opportunity.

(6) When any agent is involved in the transaction to sell target housing on behalf of the seller, a statement that:

(i) The agent has informed the seller of the seller's obligations under 42 U.S.C. 4852d; and

(ii) The agent is aware of his/her duty to ensure compliance with the requirements of this subpart.

(7) The signatures of the sellers, agents, and purchasers, certifying to the accuracy of their statements, to the best of their knowledge, along with the dates of signature.

(b) *Lessor requirements.* Each contract to lease target housing shall include, as an attachment or within the contract, the following elements, in the language of the contract (e.g., English, Spanish):

(1) A Lead Warning Statement with the following language:

Housing built before 1978 may contain lead-based paint. Lead from paint, paint chips, and dust can pose health hazards if not managed properly. Lead exposure is especially harmful to young children and pregnant women. Before renting pre-1978 housing, lessors must disclose the presence of lead-based paint and/or lead-based paint hazards in the dwelling. Lessees must also receive a federally approved pamphlet on lead poisoning prevention.

(2) A statement by the lessor disclosing the presence of known lead-based paint and/or lead-based paint hazards in the target housing being leased or indicating no knowledge of the presence of lead-based paint and/or lead-based paint hazards. The lessor shall also disclose any additional information available concerning the known lead-based paint and/or lead-based paint hazards, such as the basis for the determination that lead-based paint and/or lead-based paint hazards exist in the housing, the location of the lead-based paint and/or lead-based paint hazards, and the condition of the painted surfaces.

(3) A list of any records or reports available to the lessor pertaining to lead-based paint and/or lead-based paint hazards in the housing that have been provided to the lessee. If no such records or reports are available, the lessor shall so indicate.

(4) A statement by the lessee affirming receipt of the information set out in paragraphs (b)(2) and (b)(3) of this section and the lead hazard information pamphlet required under 15 U.S.C. 2696.

(5) When any agent is involved in the transaction to lease target housing on behalf of the lessor, a statement that:

(i) The agent has informed the lessor of the lessor's obligations under 42 U.S.C. 4852d; and

(ii) The agent is aware of his/her duty to ensure compliance with the requirements of this subpart.

(6) The signatures of the lessors, agents, and lessees certifying to the accuracy of their statements to the best of their knowledge, along with the dates of signature.

(c) *Retention of certification and acknowledgment information.*

(1) The seller, and any agent, shall retain a copy of the completed attachment required under paragraph (a) of this section for no less than 3 years from the completion date of the sale. The lessor, and any agent, shall retain a copy of the completed attachment or lease contract containing the information required under paragraph (b) of this section for no less than 3 years from the commencement of the leasing period.

(2) This recordkeeping requirement is not intended to place any limitations on civil suits under the Act, or to otherwise affect a lessee's or purchaser's rights under the civil penalty provisions of 42 U.S.C. 4852d(b)(3).

(d) The seller, lessor, or agent shall not be responsible for the failure of a purchaser's or lessee's legal representative (where such representative receives all compensation from the purchaser or lessee) to transmit disclosure materials to the purchaser or lessee, provided that all required parties have completed and signed the necessary certification and acknowledgment language required under paragraphs (a) and (b) of this section.

§ 35.94 Agent responsibilities.

(a) Each agent shall ensure compliance with all requirements of this subpart. To ensure compliance, the agent shall:

(1) Inform the seller or lessor of his/her obligations under §§ 35.88, 35.90, and 35.92.

(2) Ensure that the seller or lessor has performed all activities required under §§ 35.88, 35.90, and 35.92, or personally ensure compliance with the requirements of §§ 35.88, 35.90, and 35.92.

(b) If the agent has complied with paragraph (a)(1) of this section, the agent shall not be liable for the failure to disclose to a purchaser or lessee the presence of lead-based paint and/or lead-based paint hazards known by a seller or lessor but not disclosed to the agent.

§ 35.96 Enforcement.

(a) Any person who knowingly fails to comply with any provision of this subpart shall be subject to civil monetary penalties in accordance with the provisions of 42 U.S.C. 3545 and 24 CFR part 30.

(b) The Secretary is authorized to take such action as may be necessary to enjoin any violation of this subpart in the appropriate Federal district court.

(c) Any person who knowingly violates the provisions of this subpart shall be jointly and severally liable to the purchaser or lessee in an amount equal to 3 times the amount of damages incurred by such individual.

(d) In any civil action brought for damages pursuant to 42 U.S.C. 4852d(b)(3), the appropriate court may award court costs to the party commencing such action, together with reasonable attorney fees and any expert witness fees, if that party prevails.

(e) Failure or refusal to comply with §§ 35.88 (disclosure requirements for sellers and lessors), § 35.90 (opportunity to conduct an evaluation), § 35.92 (certification and acknowledgment of disclosure), or § 35.94 (agent responsibilities) is a violation of 42 U.S.C. 4852d(b)(5) and of TSCA section 409 (15 U.S.C. 2689).

(f) Violators may be subject to civil and criminal sanctions pursuant to TSCA section 16 (15 U.S.C. 2615) for each violation. For purposes of enforcing this subpart, the penalty for each violation applicable under 15 U.S.C. 2615 shall be not more than \$10,000.

§ 35.98 Impact on State and local requirements.

Nothing in this subpart shall relieve a seller, lessor, or agent from any responsibility for compliance with State or local laws, ordinances, codes, or regulations governing notice or disclosure of known lead-based paint and/or lead-based paint hazards. Neither HUD nor EPA assumes any responsibility for ensuring compliance with such State or local requirements.

40 CFR Chapter I

1. Part 745 is added to read as follows:

PART 745—LEAD-BASED PAINT POISONING PREVENTION IN CERTAIN RESIDENTIAL STRUCTURES

Subparts A—E [Reserved]

Subpart F—Disclosure of Known Lead-Based Paint and/or Lead-Based Paint Hazards Upon Sale or Lease of Residential Property

Sec.

745.100	Purpose.
745.101	Scope and applicability.
745.102	Effective dates.
745.103	Definitions.
745.107	Disclosure requirements for sellers and lessors.
745.110	Opportunity to conduct an evaluation.
745.113	Certification and acknowledgment of disclosure.
745.115	Agent responsibilities.
745.118	Enforcement.
745.119	Impact on State and local requirements.

Authority: 15 U.S.C. 2615, 15 U.S.C. 2689, and 42 U.S.C. 4852d.

Subparts A—E [Reserved]

Subpart F—Disclosure of Known Lead-Based Paint and/or Lead-Based Paint Hazards Upon Sale or Lease of Residential Property

§ 745.100 Purpose.

This subpart implements the provisions of 42 U.S.C. 4852d, which impose certain requirements on the sale or lease of target housing. Under this subpart, a seller or lessor of target housing shall disclose to the purchaser or lessee the presence of any known lead-based paint and/or lead-based paint hazards; provide available records and reports; provide the purchaser or lessee with a lead hazard information pamphlet; give purchasers a 10-day opportunity to conduct a risk assessment or inspection; and attach specific disclosure and warning language to the sales or leasing contract before the purchaser or lessee is obligated under a contract to purchase or lease target housing.

§ 745.101 Scope and applicability.

This subpart applies to all transactions to sell or lease target housing, including subleases, with the exception of the following:

(a) Sales of target housing at foreclosure.

(b) Leases of target housing that have been found to be lead-based paint free by an inspector certified under the Federal certification program or under a federally accredited State or tribal certification program. Until a Federal certification program or federally accredited State certification program is

in place within the State, inspectors shall be considered qualified to conduct an inspection for this purpose if they have received certification under any existing State or tribal inspector certification program. The lessor has the option of using the results of additional test(s) by a certified inspector to confirm or refute a prior finding.

(c) Short-term leases of 100 days or less, where no lease renewal or extension can occur.

(d) Renewals of existing leases in target housing in which the lessor has previously disclosed all information required under § 745.107 and where no new information described in § 745.107 has come into the possession of the lessor. For the purposes of this paragraph, renewal shall include both renegotiation of existing lease terms and/or ratification of a new lease.

§ 745.102 Effective dates.

The requirements in this subpart take effect in the following manner:

(a) For owners of more than four residential dwellings, the requirements shall take effect on September 6, 1996.

(b) For owners of one to four residential dwellings, the requirements shall take effect on December 6, 1996.

§ 745.103 Definitions.

The following definitions apply to this subpart.

The Act means the Residential Lead-Based Paint Hazard Reduction Act of 1992, 42 U.S.C. 4852d.

Agent means any party who enters into a contract with a seller or lessor, including any party who enters into a contract with a representative of the seller or lessor, for the purpose of selling or leasing target housing. This term does not apply to purchasers or any purchaser's representative who receives all compensation from the purchaser.

Available means in the possession of or reasonably obtainable by the seller or lessor at the time of the disclosure.

Common area means a portion of a building generally accessible to all residents/users including, but not limited to, hallways, stairways, laundry and recreational rooms, playgrounds, community centers, and boundary fences.

Contract for the purchase and sale of residential real property means any contract or agreement in which one party agrees to purchase an interest in real property on which there is situated one or more residential dwellings used or occupied, or intended to be used or occupied, in whole or in part, as the home or residence of one or more persons.

EPA means the Environmental Protection Agency.

Evaluation means a risk assessment and/or inspection.

Foreclosure means any of the various methods, statutory or otherwise, known in different jurisdictions, of enforcing payment of a debt, by the taking and selling of real property.

Housing for the elderly means retirement communities or similar types of housing reserved for households composed of one or more persons 62 years of age or more at the time of initial occupancy.

HUD means the U.S. Department of Housing and Urban Development.

Inspection means:

(1) A surface-by-surface investigation to determine the presence of lead-based paint as provided in section 302(c) of the Lead-Based Paint Poisoning and Prevention Act [42 U.S.C. 4822], and

(2) The provision of a report explaining the results of the investigation.

Lead-based paint means paint or other surface coatings that contain lead equal to or in excess of 1.0 milligram per square centimeter or 0.5 percent by weight.

Lead-based paint free housing means target housing that has been found to be free of paint or other surface coatings that contain lead equal to or in excess of 1.0 milligram per square centimeter or 0.5 percent by weight.

Lead-based paint hazard means any condition that causes exposure to lead from lead-contaminated dust, lead-contaminated soil, or lead-contaminated paint that is deteriorated or present in accessible surfaces, friction surfaces, or impact surfaces that would result in adverse human health effects as established by the appropriate Federal agency.

Lessee means any entity that enters into an agreement to lease, rent, or sublease target housing, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations.

Lessor means any entity that offers target housing for lease, rent, or sublease, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations.

Owner means any entity that has legal title to target housing, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations, except where a mortgagee holds legal title to property serving as collateral for

a mortgage loan, in which case the owner would be the mortgagor.

Purchaser means an entity that enters into an agreement to purchase an interest in target housing, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations.

Reduction means measures designed to reduce or eliminate human exposure to lead-based paint hazards through methods including interim controls and abatement.

Residential dwelling means:

(1) A single-family dwelling, including attached structures such as porches and stoops; or

(2) A single-family dwelling unit in a structure that contains more than one separate residential dwelling unit, and in which each such unit is used or occupied, or intended to be used or occupied, in whole or in part, as the residence of one or more persons.

Risk assessment means an on-site investigation to determine and report the existence, nature, severity, and location of lead-based paint hazards in residential dwellings, including:

(1) Information gathering regarding the age and history of the housing and occupancy by children under age 6;

(2) Visual inspection;

(3) Limited wipe sampling or other environmental sampling techniques;

(4) Other activity as may be appropriate; and

(5) Provision of a report explaining the results of the investigation.

Secretary means the Secretary of Housing and Urban Development.

Seller means any entity that transfers legal title to target housing, in whole or in part, in return for consideration, including but not limited to individuals, partnerships, corporations, trusts, government agencies, housing agencies, Indian tribes, and nonprofit organizations. The term "seller" also includes:

(1) An entity that transfers shares in a cooperatively owned project, in return for consideration; and

(2) An entity that transfers its interest in a leasehold, in jurisdictions or circumstances where it is legally permissible to separate the fee title from the title to the improvement, in return for consideration.

Target housing means any housing constructed prior to 1978, except housing for the elderly or persons with disabilities (unless any child who is less than 6 years of age resides or is expected to reside in such housing) or any 0-bedroom dwelling.

TSCA means the Toxic Substances Control Act, 15 U.S.C. 2601.

0-bedroom dwelling means any residential dwelling in which the living area is not separated from the sleeping area. The term includes efficiencies, studio apartments, dormitory housing, military barracks, and rentals of individual rooms in residential dwellings.

§ 745.107 Disclosure requirements for sellers and lessors.

(a) The following activities shall be completed before the purchaser or lessee is obligated under any contract to purchase or lease target housing that is not otherwise an exempt transaction pursuant to § 745.101. Nothing in this section implies a positive obligation on the seller or lessor to conduct any evaluation or reduction activities.

(1) The seller or lessor shall provide the purchaser or lessee with an EPA-approved lead hazard information pamphlet. Such pamphlets include the EPA document entitled *Protect Your Family From Lead in Your Home* (EPA #747-K-94-001) or an equivalent pamphlet that has been approved for use in that State by EPA.

(2) The seller or lessor shall disclose to the purchaser or lessee the presence of any known lead-based paint and/or lead-based paint hazards in the target housing being sold or leased. The seller or lessor shall also disclose any additional information available concerning the known lead-based paint and/or lead-based paint hazards, such as the basis for the determination that lead-based paint and/or lead-based paint hazards exist, the location of the lead-based paint and/or lead-based paint hazards, and the condition of the painted surfaces.

(3) The seller or lessor shall disclose to each agent the presence of any known lead-based paint and/or lead-based paint hazards in the target housing being sold or leased and the existence of any available records or reports pertaining to lead-based paint and/or lead-based paint hazards. The seller or lessor shall also disclose any additional information available concerning the known lead-based paint and/or lead-based paint hazards, such as the basis for the determination that lead-based paint and/or lead-based paint hazards exist, the location of the lead-based paint and/or lead-based paint hazards, and the condition of the painted surfaces.

(4) The seller or lessor shall provide the purchaser or lessee with any records or reports available to the seller or lessor pertaining to lead-based paint and/or lead-based paint hazards in the target housing being sold or leased. This requirement includes records or reports

regarding common areas. This requirement also includes records or reports regarding other residential dwellings in multifamily target housing, provided that such information is part of an evaluation or reduction of lead-based paint and/or lead-based paint hazards in the target housing as a whole.

(b) If any of the disclosure activities identified in paragraph (a) of this section occurs after the purchaser or lessee has provided an offer to purchase or lease the housing, the seller or lessor shall complete the required disclosure activities prior to accepting the purchaser's or lessee's offer and allow the purchaser or lessee an opportunity to review the information and possibly amend the offer.

§ 745.110 Opportunity to conduct an evaluation.

(a) Before a purchaser is obligated under any contract to purchase target housing, the seller shall permit the purchaser a 10-day period (unless the parties mutually agree, in writing, upon a different period of time) to conduct a risk assessment or inspection for the presence of lead-based paint and/or lead-based paint hazards.

(b) Notwithstanding paragraph (a) of this section, a purchaser may waive the opportunity to conduct the risk assessment or inspection by so indicating in writing.

§ 745.113 Certification and acknowledgment of disclosure.

(a) *Seller requirements.* Each contract to sell target housing shall include an attachment containing the following elements, in the language of the contract (e.g., English, Spanish):

(1) A Lead Warning Statement consisting of the following language:

Every purchaser of any interest in residential real property on which a residential dwelling was built prior to 1978 is notified that such property may present exposure to lead from lead-based paint that may place young children at risk of developing lead poisoning. Lead poisoning in young children may produce permanent neurological damage, including learning disabilities, reduced intelligence quotient, behavioral problems, and impaired memory. Lead poisoning also poses a particular risk to pregnant women. The seller of any interest in residential real property is required to provide the buyer with any information on lead-based paint hazards from risk assessments or inspections in the seller's possession and notify the buyer of any known lead-based paint hazards. A risk assessment or inspection for possible lead-based paint hazards is recommended prior to purchase.

(2) A statement by the seller disclosing the presence of known lead-based paint and/or lead-based paint

hazards in the target housing being sold or indicating no knowledge of the presence of lead-based paint and/or lead-based paint hazards. The seller shall also provide any additional information available concerning the known lead-based paint and/or lead-based paint hazards, such as the basis for the determination that lead-based paint and/or lead-based paint hazards exist, the location of the lead-based paint and/or lead-based paint hazards, and the condition of the painted surfaces.

(3) A list of any records or reports available to the seller pertaining to lead-based paint and/or lead-based paint hazards in the housing that have been provided to the purchaser. If no such records or reports are available, the seller shall so indicate.

(4) A statement by the purchaser affirming receipt of the information set out in paragraphs (a)(2) and (a)(3) of this section and the lead hazard information pamphlet required under 15 U.S.C. 2696.

(5) A statement by the purchaser that he/she has either:

(i) Received the opportunity to conduct the risk assessment or inspection required by § 745.110(a); or
(ii) Waived the opportunity.

(6) When one or more agents are involved in the transaction to sell target housing on behalf of the seller, a statement that:

(i) The agent has informed the seller of the seller's obligations under 42 U.S.C. 4852d; and

(ii) The agent is aware of his/her duty to ensure compliance with the requirements of this subpart.

(7) The signatures of the sellers, agents, and purchasers certifying to the accuracy of their statements to the best of their knowledge, along with the dates of signature.

(b) *Lessor requirements.* Each contract to lease target housing shall include, as an attachment or within the contract, the following elements, in the language of the contract (e.g., English, Spanish):

(1) A Lead Warning Statement with the following language:

Housing built before 1978 may contain lead-based paint. Lead from paint, paint chips, and dust can pose health hazards if not managed properly. Lead exposure is especially harmful to young children and pregnant women. Before renting pre-1978 housing, lessors must disclose the presence of lead-based paint and/or lead-based paint hazards in the dwelling. Lessees must also receive a federally approved pamphlet on lead poisoning prevention.

(2) A statement by the lessor disclosing the presence of known lead-based paint and/or lead-based paint

hazards in the target housing being leased or indicating no knowledge of the presence of lead-based paint and/or lead-based paint hazards. The lessor shall also disclose any additional information available concerning the known lead-based paint and/or lead-based paint hazards, such as the basis for the determination that lead-based paint and/or lead-based paint hazards exist, the location of the lead-based paint and/or lead-based paint hazards, and the condition of the painted surfaces.

(3) A list of any records or reports available to the lessor pertaining to lead-based paint and/or lead-based paint hazards in the housing that have been provided to the lessee. If no such records or reports are available, the lessor shall so indicate.

(4) A statement by the lessee affirming receipt of the information set out in paragraphs (b)(2) and (b)(3) of this section and the lead hazard information pamphlet required under 15 U.S.C. 2696.

(5) When one or more agents are involved in the transaction to lease target housing on behalf of the lessor, a statement that:

(i) The agent has informed the lessor of the lessors obligations under 42 U.S.C. 4852d; and

(ii) The agent is aware of his/her duty to ensure compliance with the requirements of this subpart.

(6) The signatures of the lessors, agents, and lessees, certifying to the accuracy of their statements, to the best of their knowledge, along with the dates of signature.

(c) Retention of Certification and Acknowledgment Information.

(1) The seller, and any agent, shall retain a copy of the completed attachment required under paragraph (a) of this section for no less than 3 years from the completion date of the sale. The lessor, and any agent, shall retain a copy of the completed attachment or lease contract containing the

information required under paragraph (b) of this section for no less than 3 years from the commencement of the leasing period.

(2) This recordkeeping requirement is not intended to place any limitations on civil suits under the Act, or to otherwise affect a lessee's or purchaser's rights under the civil penalty provisions of 42 U.S.C. 4852d(b)(3).

(d) The seller, lessor, or agent shall not be responsible for the failure of a purchaser's or lessee's legal representative (where such representative receives all compensation from the purchaser or lessee) to transmit disclosure materials to the purchaser or lessee, provided that all required parties have completed and signed the necessary certification and acknowledgment language required under paragraphs (a) and (b) of this section.

§ 745.115 Agent responsibilities.

(a) Each agent shall ensure compliance with all requirements of this subpart. To ensure compliance, the agent shall:

(1) Inform the seller or lessor of his/her obligations under §§745.107, 745.110, and 745.113.

(2) Ensure that the seller or lessor has performed all activities required under §§ 745.107, 745.110, and 745.113, or personally ensure compliance with the requirements of §§ 745.107, 745.110, and 745.113.

(b) If the agent has complied with paragraph (a)(1) of this section, the agent shall not be liable for the failure to disclose to a purchaser or lessee the presence of lead-based paint and/or lead-based paint hazards known by a seller or lessor but not disclosed to the agent.

§ 745.118 Enforcement.

(a) Any person who knowingly fails to comply with any provision of this subpart shall be subject to civil monetary penalties in accordance with

the provisions of 42 U.S.C. 3545 and 24 CFR part 30.

(b) The Secretary is authorized to take such action as may be necessary to enjoin any violation of this subpart in the appropriate Federal district court.

(c) Any person who knowingly violates the provisions of this subpart shall be jointly and severally liable to the purchaser or lessee in an amount equal to 3 times the amount of damages incurred by such individual.

(d) In any civil action brought for damages pursuant to 42 U.S.C. 4852d(b)(3), the appropriate court may award court costs to the party commencing such action, together with reasonable attorney fees and any expert witness fees, if that party prevails.

(e) Failure or refusal to comply with § 745.107 (disclosure requirements for sellers and lessors), § 745.110 (opportunity to conduct an evaluation), § 745.113 (certification and acknowledgment of disclosure), or § 745.115 (agent responsibilities) is a violation of 42 U.S.C. 4852d(b)(5) and of TSCA section 409 (15 U.S.C. 2689).

(f) Violators may be subject to civil and criminal sanctions pursuant to TSCA section 16 (15 U.S.C. 2615) for each violation. For purposes of enforcing this subpart, the penalty for each violation applicable under 15 U.S.C. 2615 shall be not more than \$10,000.

§ 745.119 Impact on State and local requirements.

Nothing in this subpart shall relieve a seller, lessor, or agent from any responsibility for compliance with State or local laws, ordinances, codes, or regulations governing notice or disclosure of known lead-based paint or lead-based paint hazards. Neither HUD nor EPA assumes any responsibility for ensuring compliance with such State or local requirements.

[FR Doc. 96-5243 Filed 3-5-96; 8:45 am]

BILLING CODE 6560-50-F

APPENDIX G

EPA PAMPHLET “Protect Your Family From Lead in Your Home”



Protect Your Family From Lead in Your Home



United States
Environmental
Protection Agency



United States
Consumer Product
Safety Commission



United States
Department of Housing
and Urban Development

Are You Planning to Buy or Rent a Home Built Before 1978?

Did you know that many homes built before 1978 have **lead-based paint**? Lead from paint, chips, and dust can pose serious health hazards.

Read this entire brochure to learn:

- How lead gets into the body
- How lead affects health
- What you can do to protect your family
- Where to go for more information

Before renting or buying a pre-1978 home or apartment, federal law requires:

- Sellers must disclose known information on lead-based paint or lead-based paint hazards before selling a house.
- Real estate sales contracts must include a specific warning statement about lead-based paint. Buyers have up to 10 days to check for lead.
- Landlords must disclose known information on lead-based paint or lead-based paint hazards before leases take effect. Leases must include a specific warning statement about lead-based paint.

If undertaking renovations, repairs, or painting (RRP) projects in your pre-1978 home or apartment:

- Read EPA's pamphlet, *The Lead-Safe Certified Guide to Renovate Right*, to learn about the lead-safe work practices that contractors are required to follow when working in your home (see page 12).



Simple Steps to Protect Your Family from Lead Hazards

If you think your home has lead-based paint:

- Don't try to remove lead-based paint yourself.
- Always keep painted surfaces in good condition to minimize deterioration.
- Get your home checked for lead hazards. Find a certified inspector or risk assessor at [epa.gov/lead](https://www.epa.gov/lead).
- Talk to your landlord about fixing surfaces with peeling or chipping paint.
- Regularly clean floors, window sills, and other surfaces.
- Take precautions to avoid exposure to lead dust when remodeling.
- When renovating, repairing, or painting, hire only EPA- or state-approved Lead-Safe certified renovation firms.
- Before buying, renting, or renovating your home, have it checked for lead-based paint.
- Consult your health care provider about testing your children for lead. Your pediatrician can check for lead with a simple blood test.
- Wash children's hands, bottles, pacifiers, and toys often.
- Make sure children eat healthy, low-fat foods high in iron, calcium, and vitamin C.
- Remove shoes or wipe soil off shoes before entering your house.

Lead Gets into the Body in Many Ways

Adults and children can get lead into their bodies if they:

- Breathe in lead dust (especially during activities such as renovations, repairs, or painting that disturb painted surfaces).
- Swallow lead dust that has settled on food, food preparation surfaces, and other places.
- Eat paint chips or soil that contains lead.

Lead is especially dangerous to children under the age of 6.

- At this age, children's brains and nervous systems are more sensitive to the damaging effects of lead.
- Children's growing bodies absorb more lead.
- Babies and young children often put their hands and other objects in their mouths. These objects can have lead dust on them.



Women of childbearing age should know that lead is dangerous to a developing fetus.


- Women with a high lead level in their system before or during pregnancy risk exposing the fetus to lead through the placenta during fetal development.

Health Effects of Lead

Lead affects the body in many ways. It is important to know that even exposure to low levels of lead can severely harm children.

In children, exposure to lead can cause:

- Nervous system and kidney damage
- Learning disabilities, attention-deficit disorder, and decreased intelligence
- Speech, language, and behavior problems
- Poor muscle coordination
- Decreased muscle and bone growth
- Hearing damage



While low-lead exposure is most common, exposure to high amounts of lead can have devastating effects on children, including seizures, unconsciousness, and in some cases, death.

Although children are especially susceptible to lead exposure, lead can be dangerous for adults, too.

In adults, exposure to lead can cause:

- Harm to a developing fetus
- Increased chance of high blood pressure during pregnancy
- Fertility problems (in men and women)
- High blood pressure
- Digestive problems
- Nerve disorders
- Memory and concentration problems
- Muscle and joint pain

Check Your Family for Lead

Get your children and home tested if you think your home has lead.

Children's blood lead levels tend to increase rapidly from 6 to 12 months of age, and tend to peak at 18 to 24 months of age.

Consult your doctor for advice on testing your children. A simple blood test can detect lead. Blood lead tests are usually recommended for:

- Children at ages 1 and 2
- Children or other family members who have been exposed to high levels of lead
- Children who should be tested under your state or local health screening plan

Your doctor can explain what the test results mean and if more testing will be needed.

Where Lead-Based Paint Is Found

In general, the older your home or childcare facility, the more likely it has lead-based paint.¹

Many homes, including private, federally-assisted, federally-owned housing, and childcare facilities built before 1978 have lead-based paint. In 1978, the federal government banned consumer uses of lead-containing paint.²

Learn how to determine if paint is lead-based paint on page 7.

Lead can be found:

- In homes and childcare facilities in the city, country, or suburbs,
- In private and public single-family homes and apartments,
- On surfaces inside and outside of the house, and
- In soil around a home. (Soil can pick up lead from exterior paint or other sources, such as past use of leaded gas in cars.)

Learn more about where lead is found at [epa.gov/lead](https://www.epa.gov/lead).

¹ “Lead-based paint” is currently defined by the federal government as paint with lead levels greater than or equal to 1.0 milligram per square centimeter (mg/cm²), or more than 0.5% by weight.

² “Lead-containing paint” is currently defined by the federal government as lead in new dried paint in excess of 90 parts per million (ppm) by weight.

Identifying Lead-Based Paint and Lead-Based Paint Hazards

Deteriorated lead-based paint (peeling, chipping, chalking, cracking, or damaged paint) is a hazard and needs immediate attention. **Lead-based paint** may also be a hazard when found on surfaces that children can chew or that get a lot of wear and tear, such as:

- On windows and window sills
- Doors and door frames
- Stairs, railings, banisters, and porches

Lead-based paint is usually not a hazard if it is in good condition and if it is not on an impact or friction surface like a window.

Lead dust can form when lead-based paint is scraped, sanded, or heated. Lead dust also forms when painted surfaces containing lead bump or rub together. Lead paint chips and dust can get on surfaces and objects that people touch. Settled lead dust can reenter the air when the home is vacuumed or swept, or when people walk through it. EPA currently defines the following levels of lead in dust as hazardous:

- 10 micrograms per square foot ($\mu\text{g}/\text{ft}^2$) and higher for floors, including carpeted floors
- 100 $\mu\text{g}/\text{ft}^2$ and higher for interior window sills

Lead in soil can be a hazard when children play in bare soil or when people bring soil into the house on their shoes. EPA currently defines the following levels of lead in soil as hazardous:

- 400 parts per million (ppm) and higher in play areas of bare soil
- 1,200 ppm (average) and higher in bare soil in the remainder of the yard

Remember, lead from paint chips—which you can see—and lead dust—which you may not be able to see—both can be hazards.

The only way to find out if paint, dust, or soil lead hazards exist is to test for them. The next page describes how to do this.

Checking Your Home for Lead

You can get your home tested for lead in several different ways:

- A lead-based paint **inspection** tells you if your home has lead-based paint and where it is located. It won't tell you whether your home currently has lead hazards. A trained and certified testing professional, called a lead-based paint inspector, will conduct a paint inspection using methods, such as:
 - Portable x-ray fluorescence (XRF) machine
 - Lab tests of paint samples
- A **risk assessment** tells you if your home currently has any lead hazards from lead in paint, dust, or soil. It also tells you what actions to take to address any hazards. A trained and certified testing professional, called a risk assessor, will:
 - Sample paint that is deteriorated on doors, windows, floors, stairs, and walls
 - Sample dust near painted surfaces and sample bare soil in the yard
 - Get lab tests of paint, dust, and soil samples
- A combination inspection and risk assessment tells you if your home has any lead-based paint and if your home has any lead hazards, and where both are located.



Be sure to read the report provided to you after your inspection or risk assessment is completed, and ask questions about anything you do not understand.

Checking Your Home for Lead, continued

In preparing for renovation, repair, or painting work in a pre-1978 home, Lead-Safe Certified renovators (see page 12) may:

- Take paint chip samples to determine if lead-based paint is present in the area planned for renovation and send them to an EPA-recognized lead lab for analysis. In housing receiving federal assistance, the person collecting these samples must be a certified lead-based paint inspector or risk assessor
- Use EPA-recognized tests kits to determine if lead-based paint is absent (but not in housing receiving federal assistance)
- Presume that lead-based paint is present and use lead-safe work practices

There are state and federal programs in place to ensure that testing is done safely, reliably, and effectively. Contact your state or local agency for more information, visit [epa.gov/lead](https://www.epa.gov/lead), or call **1-800-424-LEAD (5323)** for a list of contacts in your area.³

³ Hearing- or speech-challenged individuals may access this number through TTY by calling the Federal Relay Service at 1-800-877-8339.

What You Can Do Now to Protect Your Family

If you suspect that your house has lead-based paint hazards, you can take some immediate steps to reduce your family's risk:

- If you rent, notify your landlord of peeling or chipping paint.
- Keep painted surfaces clean and free of dust. Clean floors, window frames, window sills, and other surfaces weekly. Use a mop or sponge with warm water and a general all-purpose cleaner. (Remember: never mix ammonia and bleach products together because they can form a dangerous gas.)
- Carefully clean up paint chips immediately without creating dust.
- Thoroughly rinse sponges and mop heads often during cleaning of dirty or dusty areas, and again afterward.
- Wash your hands and your children's hands often, especially before they eat and before nap time and bed time.
- Keep play areas clean. Wash bottles, pacifiers, toys, and stuffed animals regularly.
- Keep children from chewing window sills or other painted surfaces, or eating soil.
- When renovating, repairing, or painting, hire only EPA- or state-approved Lead-Safe Certified renovation firms (see page 12).
- Clean or remove shoes before entering your home to avoid tracking in lead from soil.
- Make sure children eat nutritious, low-fat meals high in iron, and calcium, such as spinach and dairy products. Children with good diets absorb less lead.

Reducing Lead Hazards

Disturbing lead-based paint or removing lead improperly can increase the hazard to your family by spreading even more lead dust around the house.

- In addition to day-to-day cleaning and good nutrition, you can **temporarily** reduce lead-based paint hazards by taking actions, such as repairing damaged painted surfaces and planting grass to cover lead-contaminated soil. These actions are not permanent solutions and will need ongoing attention.
- You can minimize exposure to lead when renovating, repairing, or painting by hiring an EPA- or state-certified renovator who is trained in the use of lead-safe work practices. If you are a do-it-yourselfer, learn how to use lead-safe work practices in your home.
- To remove lead hazards permanently, you should hire a certified lead abatement contractor. Abatement (or permanent hazard elimination) methods include removing, sealing, or enclosing lead-based paint with special materials. Just painting over the hazard with regular paint is not permanent control.



Always use a certified contractor who is trained to address lead hazards safely.

- Hire a Lead-Safe Certified firm (see page 12) to perform renovation, repair, or painting (RRP) projects that disturb painted surfaces.
- To correct lead hazards permanently, hire a certified lead abatement contractor. This will ensure your contractor knows how to work safely and has the proper equipment to clean up thoroughly.

Certified contractors will employ qualified workers and follow strict safety rules as set by their state or by the federal government.

Reducing Lead Hazards, continued

If your home has had lead abatement work done or if the housing is receiving federal assistance, once the work is completed, dust cleanup activities must be conducted until clearance testing indicates that lead dust levels are below the following levels:

- 10 micrograms per square foot ($\mu\text{g}/\text{ft}^2$) for floors, including carpeted floors
- 100 $\mu\text{g}/\text{ft}^2$ for interior windows sills
- 400 $\mu\text{g}/\text{ft}^2$ for window troughs

Abatements are designed to permanently eliminate lead-based paint hazards. However, lead dust can be reintroduced into an abated area.

- Use a HEPA vacuum on all furniture and other items returned to the area, to reduce the potential for reintroducing lead dust.
- Regularly clean floors, window sills, troughs, and other hard surfaces with a damp cloth or sponge and a general all-purpose cleaner.

Please see page 9 for more information on steps you can take to protect your home after the abatement. For help in locating certified lead abatement professionals in your area, call your state or local agency (see pages 15 and 16), [epa.gov/lead](https://www.epa.gov/lead), or call 1-800-424-LEAD.

Renovating, Repairing or Painting a Home with Lead-Based Paint

If you hire a contractor to conduct renovation, repair, or painting (RRP) projects in your pre-1978 home or childcare facility (such as pre-school and kindergarten), your contractor must:

- Be a Lead-Safe Certified firm approved by EPA or an EPA-authorized state program
- Use qualified trained individuals (Lead-Safe Certified renovators) who follow specific lead-safe work practices to prevent lead contamination
- Provide a copy of EPA's lead hazard information document, *The Lead-Safe Certified Guide to Renovate Right*



RRP contractors working in pre-1978 homes and childcare facilities must follow lead-safe work practices that:

- **Contain the work area.** The area must be contained so that dust and debris do not escape from the work area. Warning signs must be put up, and plastic or other impermeable material and tape must be used.
- **Avoid renovation methods that generate large amounts of lead-contaminated dust.** Some methods generate so much lead-contaminated dust that their use is prohibited. They are:
 - Open-flame burning or torching
 - Sanding, grinding, planing, needle gunning, or blasting with power tools and equipment not equipped with a shroud and HEPA vacuum attachment
 - Using a heat gun at temperatures greater than 1100°F
- **Clean up thoroughly.** The work area should be cleaned up daily. When all the work is done, the area must be cleaned up using special cleaning methods.
- **Dispose of waste properly.** Collect and seal waste in a heavy duty bag or sheeting. When transported, ensure that waste is contained to prevent release of dust and debris.

To learn more about EPA's requirements for RRP projects, visit epa.gov/getleadsafe, or read *The Lead-Safe Certified Guide to Renovate Right*.

Other Sources of Lead

Lead in Drinking Water

The most common sources of lead in drinking water are lead pipes, faucets, and fixtures.

Lead pipes are more likely to be found in older cities and homes built before 1986.

You can't smell or taste lead in drinking water.

To find out for certain if you have lead in drinking water, have your water tested.

Remember older homes with a private well can also have plumbing materials that contain lead.

Important Steps You Can Take to Reduce Lead in Drinking Water

- Use only cold water for drinking, cooking and making baby formula. Remember, boiling water does not remove lead from water.
- Before drinking, flush your home's pipes by running the tap, taking a shower, doing laundry, or doing a load of dishes.
- Regularly clean your faucet's screen (also known as an aerator).
- If you use a filter certified to remove lead, don't forget to read the directions to learn when to change the cartridge. Using a filter after it has expired can make it less effective at removing lead.

Contact your water company to determine if the pipe that connects your home to the water main (called a service line) is made from lead. Your area's water company can also provide information about the lead levels in your system's drinking water.

For more information about lead in drinking water, please contact EPA's Safe Drinking Water Hotline at 1-800-426-4791. If you have other questions about lead poisoning prevention, call 1-800 424-LEAD.*

Call your local health department or water company to find out about testing your water, or visit [epa.gov/safewater](https://www.epa.gov/safewater) for EPA's lead in drinking water information. Some states or utilities offer programs to pay for water testing for residents. Contact your state or local water company to learn more.

* Hearing- or speech-challenged individuals may access this number through TTY by calling the Federal Relay Service at 1-800-877-8339.

Other Sources of Lead, continued

- **Lead smelters** or other industries that release lead into the air.
- **Your job.** If you work with lead, you could bring it home on your body or clothes. Shower and change clothes before coming home. Launder your work clothes separately from the rest of your family's clothes.
- **Hobbies** that use lead, such as making pottery or stained glass, or refinishing furniture. Call your local health department for information about hobbies that may use lead.
- Old **toys** and **furniture** may have been painted with lead-containing paint. Older toys and other children's products may have parts that contain lead.⁴
- Food and liquids cooked or stored in **lead crystal** or **lead-glazed pottery or porcelain** may contain lead.
- Folk remedies, such as "**greta**" and "**azarcon,**" used to treat an upset stomach.

⁴ In 1978, the federal government banned toys, other children's products, and furniture with lead-containing paint. In 2008, the federal government banned lead in most children's products. The federal government currently bans lead in excess of 100 ppm by weight in most children's products.

For More Information

The National Lead Information Center

Learn how to protect children from lead poisoning and get other information about lead hazards on the Web at epa.gov/lead and hud.gov/lead, or call **1-800-424-LEAD (5323)**.

EPA's Safe Drinking Water Hotline

For information about lead in drinking water, call **1-800-426-4791**, or visit epa.gov/safewater for information about lead in drinking water.

Consumer Product Safety Commission (CPSC) Hotline

For information on lead in toys and other consumer products, or to report an unsafe consumer product or a product-related injury, call **1-800-638-2772**, or visit CPSC's website at cpsc.gov or saferproducts.gov.

State and Local Health and Environmental Agencies

Some states, tribes, and cities have their own rules related to lead-based paint. Check with your local agency to see which laws apply to you. Most agencies can also provide information on finding a lead abatement firm in your area, and on possible sources of financial aid for reducing lead hazards. Receive up-to-date address and phone information for your state or local contacts on the Web at epa.gov/lead, or contact the National Lead Information Center at **1-800-424-LEAD**.

Hearing- or speech-challenged individuals may access any of the phone numbers in this brochure through TTY by calling the toll-free Federal Relay Service at **1-800-877-8339**.

U. S. Environmental Protection Agency (EPA)

Regional Offices

The mission of EPA is to protect human health and the environment. Your Regional EPA Office can provide further information regarding regulations and lead protection programs.

Region 1 (Connecticut, Massachusetts, Maine, New Hampshire, Rhode Island, Vermont)

Regional Lead Contact
U.S. EPA Region 1
5 Post Office Square, Suite 100, OES 05-4
Boston, MA 02109-3912
(888) 372-7341

Region 2 (New Jersey, New York, Puerto Rico, Virgin Islands)

Regional Lead Contact
U.S. EPA Region 2
2890 Woodbridge Avenue
Building 205, Mail Stop 225
Edison, NJ 08837-3679
(732) 906-6809

Region 3 (Delaware, Maryland, Pennsylvania, Virginia, DC, West Virginia)

Regional Lead Contact
U.S. EPA Region 3
1650 Arch Street
Philadelphia, PA 19103
(215) 814-2088

Region 4 (Alabama, Florida, Georgia, Kentucky, Mississippi, North Carolina, South Carolina, Tennessee)

Regional Lead Contact
U.S. EPA Region 4
AFC Tower, 12th Floor, Air, Pesticides & Toxics
61 Forsyth Street, SW
Atlanta, GA 30303
(404) 562-8998

Region 5 (Illinois, Indiana, Michigan, Minnesota, Ohio, Wisconsin)

Regional Lead Contact
U.S. EPA Region 5 (LL-17J)
77 West Jackson Boulevard
Chicago, IL 60604-3666
(312) 353-3808

Region 6 (Arkansas, Louisiana, New Mexico, Oklahoma, Texas, and 66 Tribes)

Regional Lead Contact
U.S. EPA Region 6
1445 Ross Avenue, 12th Floor
Dallas, TX 75202-2733
(214) 665-2704

Region 7 (Iowa, Kansas, Missouri, Nebraska)

Regional Lead Contact
U.S. EPA Region 7
11201 Renner Blvd.
Lenexa, KS 66219
(800) 223-0425

Region 8 (Colorado, Montana, North Dakota, South Dakota, Utah, Wyoming)

Regional Lead Contact
U.S. EPA Region 8
1595 Wynkoop St.
Denver, CO 80202
(303) 312-6966

Region 9 (Arizona, California, Hawaii, Nevada)

Regional Lead Contact
U.S. EPA Region 9 (CMD-4-2)
75 Hawthorne Street
San Francisco, CA 94105
(415) 947-4280

Region 10 (Alaska, Idaho, Oregon, Washington)

Regional Lead Contact
U.S. EPA Region 10 (20-C04)
Air and Toxics Enforcement Section
1200 Sixth Avenue, Suite 155
Seattle, WA 98101
(206) 553-1200

Consumer Product Safety Commission (CPSC)

The CPSC protects the public against unreasonable risk of injury from consumer products through education, safety standards activities, and enforcement. Contact CPSC for further information regarding consumer product safety and regulations.

CPSC

4330 East West Highway
Bethesda, MD 20814-4421
1-800-638-2772
cpsc.gov or saferproducts.gov

U. S. Department of Housing and Urban Development (HUD)

HUD's mission is to create strong, sustainable, inclusive communities and quality affordable homes for all. Contact to Office of Lead Hazard Control and Healthy Homes for further information regarding the Lead Safe Housing Rule, which protects families in pre-1978 assisted housing, and for the lead hazard control and research grant programs.

HUD

451 Seventh Street, SW, Room 8236
Washington, DC 20410-3000
(202) 402-7698
hud.gov/lead

This document is in the public domain. It may be produced by an individual or organization without permission. Information provided in this booklet is based upon current scientific and technical understanding of the issues presented and is reflective of the jurisdictional boundaries established by the statutes governing the co-authoring agencies. Following the advice given will not necessarily provide complete protection in all situations or against all health hazards that can be caused by lead exposure.

IMPORTANT!

Lead From Paint, Dust, and Soil in and Around Your Home Can Be Dangerous if Not Managed Properly

- Children under 6 years old are most at risk for lead poisoning in your home.
- Lead exposure can harm young children and babies even before they are born.
- Homes, schools, and child care facilities built before 1978 are likely to contain lead-based paint.
- Even children who seem healthy may have dangerous levels of lead in their bodies.
- Disturbing surfaces with lead-based paint or removing lead-based paint improperly can increase the danger to your family.
- People can get lead into their bodies by breathing or swallowing lead dust, or by eating soil or paint chips containing lead.
- People have many options for reducing lead hazards. Generally, lead-based paint that is in good condition is not a hazard (see page 10).